UNITED STATES

NUCLEAR REGULATORY COMMISSION

In the Matter of

NIAGARA MOHAWK POWER CORPORATION (Nine Mile Point Nuclear Station Unit No. 1)

Docket No. 50-220


APPLICATION FOR AMENDMENT

T0

OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. DPR-63, hereby requests that Specification 4.4.5 and the Bases for Specifications 3.4.5 and 4.4.5 of the Technical Specifications set forth in Appendix A to that License be amended. The proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specifications changes are set forth in Attachment A to this application. Specification 4.4.5 is being proposed for amendment in order to add surveillance requirements to test for positive pressure in the control room. Supporting information and analysis which demonstrate that the proposed changes involve no significant hazards considerations pursuant to 10CFR50.92, are included as Attachment B.



τ.

•

۰ ۰ ۰ ۰ ۰ ۰ ۰

•

r

•

•

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

B٧ Vice Pres dent

Nuclear Generation

Subscribed and sworn to before me on this *R2md*day of August 1986

GAIL M. AHERN Notary Public in the State of New Yot Qualified in Onondaga County My Commission Expires March 30, 19_87

.

. .

به ۲۰۰۰ می ۲۰۰۰ می ۲۰۰۰ می ۲۰۰۰ می