Docket No. 50-410

APPLICANT: Niagara Mohawk Power Corporation

FACILITY: Nine Mile Point, Unit 2

SUBJECT: MEETING SUMMARY CONCERNING THE JULY 31, 1986 MEETING WITH NIAGARA MOHAWK POWER CORPORATION ON NINE MILE POINT, UNIT 2 (SEISMIC QUALIFICATION AND DOSE CALCULATIONS)

On July 31, 1986, the NRC staff met with representatives of Niagara Mohawk Power Corporation (NMPC) to discuss issues still outstanding from the Seismic Qualification Review Team (SQRT) audit of Nine Mile Point, Unit 2 (NMP-2). A list of additional information required to be submitted by NMPC before the NRC staff can complete its review of the SQRT issues is identified in Enclosure 1.

Following the review and discussion of the SQRT issues, a discussion was held concerning the control room dose calculations for NMP-2. As a result of recent revisions to the secondary containment drawdown time, and the secondary containment bypass leakage paths, a new review of the control room dose analysis was required. In the process of that new review, the NRC staff raised questions about how the control room x/q was calculated. Standard NRC practice is to use the Murphy-Campe method for calculating the x/q. NMPC used a method based on wind tunnel tests which reduced the x/q by about a factor of ten. The NRC has requested additional information on the method used for determining the control room x/q.

During the meeting, a temporary exemption to GDC 19 until 5% power operation was discussed. An exemption to GDC 19 would allow NMPC to get a license to load fuel at NMP-2 before the NRC staff completed its evaluation of the methodology used to calculate the x/q. The exemption request would have to include a commitment to make any necessary modifications to meet GDC 19 before exceeding 5% of rated power.

NMPC committed to submit the details of the methodology by August 6, 1986 and a request for exemption by August 14, 1986. A tentative meeting was scheduled for August 20, 1986.

A list of meeting attendees is included in Enclosure 2.

0

Mary F. Haughey, Project Manager BWR Project Directorate No. 3 Division of BWR Licensing

> PDR Α

8608270328 86082

ADOCK

05000410

:DBL

08/*5*7/86

Enclosures: As stated

cc: See<u>next</u> page BWD-3:DBL MHaughey/vag 08/42/86

, . , .

ж ,

•

> . .

Mr. C. V. Mangan Niagara Mohawk Power Corporation

#### cc:

Mr. Troy B. Conner, Jr., Esq. Conner & Wetterhahn Suite 1050 1747 Pennsylvania Avenue, N.W. Washington, D.C. 20006

Richard Goldsmith Syracuse University College of Law E. I. White Hall Campus Syracuse, New York 12223

Ezra I. Bialik Assistant Attornev General Environmental Protection Bureau New York State Department of Law 2 World Trade Center New York, New York 10047

Resident Inspector Nine Mile Point Nuclear Power Station P. O. Box 99 Lycoming, New York 13093

Mr. John W. Keib, Esq. Niagara Mohawk Power Corporation 300 Erie Boulevard West Syracuse, New York 13202

Mr. James Linville U. S. Nuclear Regulatory Commission Region I 631 Park Avenue King of Prussia, Pennsylvania 19406

Norman Rademacher, Licensing Niagara Mohawk Power Corporation 300 Erie Boulevard West Syracuse, New York 13202

Don Hill Niagara Mohawk Power Corporation Suite 550 4520 East West Highway Rethesda, Maryland 20814

सहार संस्थित हे ह

Nine Mile Point Nuclear Station Unit 2

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406

Mr. Paul D. Eddy New York State Public Serice Commission Nine Mile Point Nuclear Station -Unit II P.O. Box 63 Lycoming, New York 13093 .

.

4

,

3

*,* 

· •

#### **ENCLOSURE** 1

#### ADDITIONAL INFORMATION REQUIRED FOR

#### SORT REVIEW OF NMP-2

1. Final master list

- 2. Confirmation of completion of seismic and dynamic qualification program
- 3. Nozzle loads
- 4. NSSS-5; HPCS MCC need confirmation that screws have been tightened.
- 5. BOP-3; Foxboro N-2ES cabinets need acceptance criteria for determining chatter during the OBE test.
- 6. BOP-5; Diesel generator need information identified below concerning anomolies identified during testing:
  - a) NMPC needs to verify that Permatex was used on the threads of the control value set screw to prevent leakage.
  - b) NMPC needs to demonstrate that noise from the main air starting control valwe was related to the air supply and not the g-level of the test.
  - c) NMPC needs to provide a commitment that the differential pressure gauge that needed to be retightened during the test will be checked after an OBE in addition to the annual test already committed to. In addition, the short nipple should be checked annually and after an OBE.

·

.

. •

•

•

3 v 4

## LIST OF MEETING ATTENDEES

#### AT JULY 31, 1986 MEETING ON NMP-2

## SQT AND DOSE ANALYSIS

## NAME

50

# ORGANIZATION

NRC

SWEC

ł

Mary Haughey A. Loveland Mark Durka Donald Hill Norman Rademacher Norman D. Romney Kamal K. Bandyopadhyay Bidyut Niyogi Divakar Bhargava Christian C. Zehrer

A. Chu G. Hulman K. Campe J. Levine M. Stocknoff NRC Project Manager NMPC Engineering Asst. Project Eng.- SWEC NMPC - Licensing NMPC - Licensing NRC / PAEB BNL SWEC - EQS. SWEC - EQS. SWEC - Asst. To Proj. Eng. NRC NRC NRC · · · **۴** 

. •

· ·

۰. ۲

1

## MEETING SUMMARY DISTRIBUTION

t

\_Docket\_No(s): 50-410= NRC PDR Local PDR BWD #3 r/f J. Partlow E. Adensam Attorney, OGC E. Jordan B. Grimes ACRS (10) Project Manager <u>M. Haughey</u> E. Hylton

#### NRC PARTICIPANTS

- M. Haughey
- N. Romney A. Chu G. Hulman

5 ;

· . .

- K. Campe J. Levine

bcc: Applicant & Service List

.

• •

.

**b** 

۰ ۰ •

•

•

, • • · · ·

- . X a '