August 29, 1986

Docket No. 50-410

Mr. C. V. Mangan, Senior Vice President Niagara Mohawk Power Corporation 300 Erie Boulevard West Syracuse, New York 13202

Dear Mr. Mangan:

Subject: FSAR Amendment 27 for Nine Mile Point Unit 2

The NRC staff has reviewed the following sections of FSAR Amendment 27 for the Nine Mile Point Unit 2 Plant: Section 6.2, 9.5.1, 9.5.4, 9A, 11.2, 11.4, 12.3, 12.5, and Table 15.6-13. Because of discrepancies in the design description we request the additional information on the Division III diesel starting system seismic qualification, combustible gas control system, and primary containment isolation system identified in the enclosure be provided in order for the staff to complete its review. A draft of this request for additional information was provided to Don Hill, of your staff, on August 26, 1986.

Sincerely,

/S/

Mary F. Haughey, Project Manager BWR Project Directorate No. 3 Division of BWR Licensing

DISTRIBUTION: Docket No. 50-410

NRC PDR Local PDR

BWD-3 r/f EAdensam MHaughey

EHylton RBernero

LHu1man

JKudrick

PHearn

FWitt

Attorney, OGC

BGrimes

EJordan

JPartlow

ACRS (10)

5

Enclosure: As stated

cc: See next page

M Haugher BWD-3:DBL

BWD-3:DBL MHaughey/hmc 8/29/86

PDR

8607070344 860827 PDR ADDCK 05000410

**DBL** El Con 8/29/86

DEBND-3:DBL EActorsam 8/2/86 r ji ji n ar 

.

۳ ۲ ۱

ب ۲ ۹

• ,;

Mr. C. V. Mangan Niagara Mohawk Power Corporation

cc: Mr. Troy B. Conner, Jr., Esq. Conner & Wetterhahn Suite 1050 1747 Pennsylvania Avenue, N.W. Washington, D.C. 20006

Richard Goldsmith Syracuse University College of Law E. I. White Hall Campus Syracuse, New York 12223

i.

Ezra I. Bialik Assistant Attorney General Environmental Protection Bureau New York State Department of Law 2 World Trade Center New York, New York 10047

Resident Inspector Nine Mile Point Nuclear Power Station P. O. Box 99 Lycoming, New York 13093

Mr. John W. Keib, Esq. Niagara Mohawk Power Corporation 300 Erie Boulevard West Syracuse, New York 13202

Mr. James Linville U. S. Nuclear Regulatory Commission Region I 631 Park Avenue King of Prussia, Pennsylvania 19406

Norman Rademacher, Licensing Niagara Mohawk Power Corporation 300 Erie Boulevard West Syracuse, New York 1320?

Don Hill Niagara Mohawk Power Corporation Suite 550 4520 East West Highway Bethesda, Maryland 20814 Nine Mile Point Nuclear Station Unit 2

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406

Mr. Paul D. Eddy New York State Public Serice Commission Nine Mile Point Nuclear Station -Unit II P.O. Box 63 Lycoming, New York 13093

·

.

• • • -" 

. ,

. . ,

.

# Request For Additional Information From

1

### Niagara Mohawk Power Corporation

# Nine Mile Point Unit 2

Docket No. 50-410

#### 1. Page 9.5-43b

have a min it

The third paragraph is confusing and contradicts Table 3.2-1 and Figure 9.5-46 designation of the seismic classification of piping and components of the Division III diesel starting system. The first sentence indicates the air receiver is seismic Category I, while the second sentence indicates the receiver is not seismic Category I. Page 9.5-43b indicates that the air receiver and the interconnecting piping and components are designed to Category I, ASME Section III, while Figure 9.5-46 indicates only the air receiver meets these requirements. Please reconcile the discrepancy and also indicate the location of the air dryers in relation to the seismic Category I interface. Explain the deletion of seismic qualification to IEEE 344-1975 of the air dryer system in FSAR Amendment 27.

# 2. Page 6.2-73 and 74

£,

Item 11 page 6.2-74 was deleted by Amendment 27 since the applicant claims that it was redundant to item 3 on page 6.2-74. Item 11 indicated that the initiation of the recombiners is based on manual actuation from the control room. Item 3 does specify manual initiation, but not from the control room. Please clarify.

#### 3. Table 6.2-57 page 1

The summary of incorporated changes, page 15 (SIC-15), indicated a change in the combustible gas monitoring system operation from continuous to manual. Amendment 27 specifies continuous. Please Clarify.

#### 4. Table 6.2-56 2 of 24

For penetration No. Z-4A, under valve 2FWS\*AOV23A potential bypass leakage path, a superscript note (30) was added to "yes". This was not in the previous amendment, nor was this change indicated in the SIC list. Please correct.

ł

