

REGULARY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8609250018 DOC. DATE: 86/09/19 NOTARIZED: NO DOCKET #  
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410  
 AUTH. NAME AUTHOR AFFILIATION  
 MANGAN, C. V. Niagara Mohawk Power Corp.  
 RECIP. NAME RECIPIENT AFFILIATION  
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Forwards responses to NRC comments re proposed changes to  
 FSAR submitted in util 860819 ltr. Marked up FSAR pages encl.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 15  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	BWR EB	1 1	BWR EICSB	2 2
	BWR FOB	1 1	BWR PD3 LA	1 1
	BWR PD3 PD	1 1	HAUGHEY, M 01	2 2
	BWR PSB	1 1	BWR RSB	1 1
INTERNAL:	ACRS 41	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	IE FILE	1 1
	IE/DEPER/EPB 36	1 1	IE/DGAVT/QAB 21	1 1
	NRR BWR ADTS	1 0	NRR PWR-B ADTS	1 0
	NRR ROE, M. L	1 1	NRR/DHFT/MTB	1 1
	<u>REG FILE</u> 04	1 1	RGN1	3 3
	RM/DDAMI/MIB	1 0		
EXTERNAL:	BNL (AMDTS ONLY)	1 1	DMB/DSS (AMDTS)	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	PNL GRUEL, R	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 36 ENCL 31

The following information was obtained from the review of the records of the [redacted] and is being furnished to you for your information. The information is being furnished to you on a confidential basis and is not to be disseminated outside your agency.

The information is being furnished to you on a confidential basis and is not to be disseminated outside your agency.

DATE	TIME	LOCATION	ACTIVITY	PERSONNEL
10/15/54	1400	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	1500	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	1600	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	1700	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	1800	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	1900	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2000	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2100	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2200	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2300	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2400	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2500	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2600	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2700	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2800	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	2900	Room 3000	Meeting	Director, SAC, [redacted]
10/15/54	3000	Room 3000	Meeting	Director, SAC, [redacted]

September 19, 1986  
(NMP2L 0881)

Ms. Elinor G. Adensam, Director  
BWR Project Directorate No. 3  
U.S. Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2  
Docket No. 50-410

The NRC staff forwarded two comments to Niagara Mohawk related to our proposed changes to the Final Safety Analysis Report which were submitted by our letter dated August 19, 1986 (NMP2L 0825). This letter provides responses to these comments and, where necessary, marked-up pages of the Final Safety Analysis Report.

Very truly yours,

*C. V. Mangan*

C. V. Mangan  
Senior Vice President

LL/ps  
2060G  
Enclosure

xc: W. A. Cook, NRC Resident Inspector  
Project File (2)

2060G

8609250018 860919  
PDR ADOCK 05000410  
A PDR

Boo1  
1/1



Small, illegible handwritten marks or characters in the top right corner.

Faint, illegible text or markings located in the lower-middle section of the page.

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
Niagara Mohawk Power Corporation )  
(Nine Mile Point Unit 2) )

Docket No. 50-410

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Senior Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.


C. V. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 19<sup>th</sup> day of September, 1986.

Janis M. Macro  
Notary Public in and for  
Onondaga County, New York

My Commission expires:  
JANIS M. MACRO

Notary Public in the State of New York  
Qualified in Onondaga County No. 4784555  
My Commission Expires March 30, 1987



1. FSAR Table 6.2-32

Comment: No basis provided. Some value deleted.

Response: These changes are made to reflect as-built calculations and correction of typographical errors. The values in the Table are not intended to be deleted. The enclosed marked-up page to Table 6.2-32 is provided to clarify the proposed change.

2. FSAR Table 6.2-59D

Comment: Zinc primer number is not accurate.

Response: A footnote which clarifies the consideration of the zinc primer for hydrogen generation was inadvertently left out. Although the consideration of additional hydrogen generation from zinc primer was considered in the calculations, this table and the associated hydrogen generation curves were not updated. In order to resolve your concern, this table, the hydrogen generation curves in figures 6.2-72D, E, H and I, and text pages 6.2-76a and 6.2-81 are updated and are provided in this enclosure. The attached changes will be included in a subsequent Final Safety Analysis Report update. There is no Technical Specification change necessary.

In order to make the Safety Evaluation Report consistent to the above changes, we suggest a change be made to page 6-25, 7th paragraph, of the Safety Evaluation Report from "approximately 2.75 days" to "approximately 2.5 days."



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



Nine Mile Point Unit 2 FSAR

TABLE 6.2-32


SUBCOMPARTMENT NODAL DESCRIPTION

24-Inch Recirculation Suction Line Break  
Drywell Head Subcompartment

Volume No.	Volume (ft <sup>3</sup> )	Initial Conditions			DBA Break Conditions				Calculated Peak Pressure Difference <sup>(1)</sup> (psid)	Design Peak Pressure Difference <sup>(1)</sup> (psid)	Design Margin <sup>(2)</sup> (%)
		Temp (°F)	Pressure (psia)	Humidity (%)	% Break in Vol.	Break Line	Break Area (ft <sup>2</sup> )	Break Type			
1	8,620	150	14.2	0	0				0.00	-	-
2	276,000	150	14.2	0	100	Recirc. Suction	2.54	DER	<del>6.02</del> 6.77 ←	7.22	<del>76.6</del> 6.2 ←

<sup>(1)</sup>Peak pressure difference [(P2-P1) peak] is shown on Figure 6.2-33B.

<sup>(2)</sup>Design margin: 1-(calculated Δ peak/design Δ peak).



Nine Mile Point Unit 2 FSAR

The recombiner unit, which requires a 1 1/2-hr warmup period, is initiated manually from the control room prior to primary containment oxygen or hydrogen concentrations reaching 4.5 volume percent. This occurs for the hydrogen concentration, approximately 2.75 days after the design basis

15

2.5



The combustible gases in the drywell and the suppression chamber would approach the flammability limit, if uncontrolled, after 4.75 days. Prior to this, pressure and temperature within the primary containment are shown by analysis (Section 6.2.1) to have dropped to a level that will permit operation of the recombiner. The recombiner system is manually activated when oxygen or hydrogen concentration reaches 4.5 percent. The recombiner system takes suction from the primary containment atmosphere, recombines the hydrogen and oxygen to form water vapor, and returns the exhaust to the suppression chamber. This results in a small pressure buildup in the suppression chamber that causes the opening of the vacuum breaker valves between the drywell and suppression chamber. As a result, the flow of the gas mixture from the suppression chamber to the drywell is established. This arrangement of recombiner suction and discharge promotes mixing of the two volumes in the primary containment.

15

6.2.5.3.3 Analysis

Based on the preceding hydrogen and oxygen generation sources and the accident description, the oxygen and hydrogen concentration in the drywell and suppression chamber is obtained as a function of time. To calculate the redistribution of the hydrogen and oxygen between the drywell and suppression chamber, a two-region computer model of the primary containment system is used. This model takes into consideration hydrogen and oxygen generation from the metal-water reaction and radiolysis. The calculation determines the inventory, partial pressure, and mole fraction of each atmospheric constituent in both regions as a function of time.

Tables 6.2-58, 6.2-59, 6.2-59C, and 6.2-59D present the parameters used in the analysis of the oxygen and hydrogen buildup within the primary containment. Figures 6.2-72H and 6.2-72I present hydrogen and oxygen concentration transients in the primary containment, assuming only one recombiner is operating. The recombiner is required to be functional approximately 2.75 days after the design basis accident.

15

15

↑  
2.5



24

Nine Mile Point Unit 2 FSAR

TABLE 6.2-59D

ALUMINUM AND ZINC INVENTORY EXPOSED TO SPRAYS

<u>Material Type</u>	<u>Surface Area (ft<sup>2</sup>)</u>	<u>Weight (lbm)</u>
Aluminum	650	<del>41,500</del> 40,300
Galvanized steel	<del>58,540</del> 57,600*	<del>6,968</del> 5,370*
Zinc primer	<del>2,400</del> 39,400*	<del>230</del> 3,780*

15


---

\* The hydrogen generation / control analysis considers 15 percent larger surface area and weight as a conservative allowance for the uncertainty of these inventories.

1944  
1945  
1946

1947  
1948  
1949  
1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025





REPLACE THIS FIGURE WITH ATTACHED FIGURE

FIGURE 6.2-72D  
 HYDROGEN GENERATION RATES FOLLOWING DBA  
 NIAGARA MOHAWK POWER CORPORATION  
 NINE MILE POINT-UNIT 2  
 FINAL SAFETY ANALYSIS REPORT







FIGURE 6.2-72D

HYDROGEN GENERATION RATES  
FOLLOWING DBA

NIAGARA MOHAWK POWER CORPORATION  
NINE MILE POINT-UNIT 2  
FINAL SAFETY ANALYSIS REPORT




11



*REPLACE THIS FIGURE  
WITH ATTACHED FIGURE*

FIGURE 6.2-72E  
 INTEGRATED HYDROGEN GENERATION  
 FOLLOWING DBA  
 NIAGARA MOHAWK POWER CORPORATION  
 NINE MILE POINT-UNIT 2  
 FINAL SAFETY ANALYSIS REPORT







FIGURE 6.2-72E

INTEGRATED HYDROGEN GENERATION  
FOLLOWING DBA

NIAGARA MOHAWK POWER CORPORATION  
NINE MILE POINT-UNIT 2  
FINAL SAFETY ANALYSIS REPORT







*REPLACE THIS FIGURE WITH ATTACHED FIGURE*

FIGURE 6.2-72H  
 OXYGEN CONCENTRATION FOLLOWING DBA  
 NIAGARA MOHAWK POWER CORPORATION  
 NINE MILE POINT-UNIT 2  
 FINAL SAFETY ANALYSIS REPORT







FIGURE 6.2-72H

OXYGEN CONCENTRATION  
FOLLOWING DBA

NIAGARA MOHAWK POWER CORPORATION  
NINE MILE POINT-UNIT 2  
FINAL SAFETY ANALYSIS REPORT



11



REPLACE THIS FIGURE  
WITH ATTACHED FIGURE

FIGURE 6.2-72I  
HYDROGEN CONCENTRATION  
FOLLOWING DBA  
NIAGARA MOHAWK POWER CORPORATION  
NINE MILE POINT-UNIT 2  
FINAL SAFETY ANALYSIS REPORT



1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025

1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025

1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025




FIGURE 6.2-72I

HYDROGEN CONCENTRATION  
FOLLOWING DBA

NIAGARA MOHAWK POWER CORPORATION  
NINE MILE POINT UNIT 2  
FINAL SAFETY ANALYSIS REPORT

