

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8610020187 DDC. DATE: 86/09/26 NOTARIZED: YES DOCKET #  
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410  
 AUTH. NAME AUTHOR AFFILIATION  
 MANGAN, C. V. Niagara Mohawk Power Corp.  
 RECIP. NAME RECIPIENT AFFILIATION  
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Informs that util will commit to implementing containment coating monitoring program, providing addl assurance that any deteriorating paint will be identified early & prompt remedial action taken. Affidavit encl.

DISTRIBUTION CODE: BO01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	BWR EB		1	1		BWR EICSB		2	2
	BWR FOB		1	1		BWR PD3 LA		1	1
	BWR PD3 PD		1	1		HAUGHEY, M 01		2	2
	BWR PSB		1	1		BWR RSB		1	1
INTERNAL:	ACRS	41	6	6		ADM/LFMB		1	0
	ELD/HDS3		1	0		IE FILE		1	1
	IE/DEPER/EPB	36	1	1		IE/DGAVT/QAB	21	1	1
	NRR BWR ADTS		1	0		NRR PWR-B ADTS		1	0
	NRR RSE, M. L.		1	1		NRR/DHFT/MTB		1	1
	REG FILE	04	1	1		RGN1		3	3
	RM/DDAMI/MIB		1	0					
EXTERNAL:	BNL (AMDTS ONLY)		1	1		DMB/DSS (AMDTS)		1	1
	LPDR	03	1	1		NRC PDR	02.	1	1
	NSIC	05	1	1		PNL GRUEL, R		1	1

TOTAL NUMBER OF COPIES REQUIRED: LTR 36 ENCL 31

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

10/10/11  
10/10/11

September 26, 1986  
(NMP2L 0890)

Ms. Elinor G. Adensam, Director  
BWR Project Directorate No. 3  
U.S. Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2  
Docket No. 50-410

During a discussion on the status of Unit 2 licensing activities on September 24, 1986, the Project Manager, Mary Haughey, indicated that the staff reviewers were concerned with the quantities of unqualified paint as indicated in our letter of September 19, 1986 (NMP2L 0883). In order to allay any concerns regarding this matter, Niagara Mohawk will commit to implementing a containment coating monitoring program which will provide additional assurance that any deteriorating paint will be identified early and prompt remedial action taken.

Although Niagara Mohawk has a high level of confidence that the containment paint systems will perform satisfactorily, we will provide added assurance of continued acceptable paint system performance by augmented inspections of the Primary Containment during each refueling outage. The "Primary Containment Structural Integrity Inspection" procedure will be revised to include coating inspection, with special attention given to the unqualified paint surfaces. The procedure will involve a walkdown of containment at each refueling outage to verify general paint condition by visual inspection. Should these inspections identify unacceptable conditions of system performance, the condition will be evaluated and, if required, corrected. This procedural requirement will be continued until the NRC staff agrees that adequate data exists to assure performance equal to that expected from a totally qualified system.

Very truly yours,

*C. V. Mangan*

C. V. Mangan  
Senior Vice President

AFZ/pns  
2099G

xc: W. A. Cook, NRC Resident Inspector  
Project File (2)

8610020187 860926  
PDR ADDCK 05000410  
A PDR

Boo  
11



72

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
Niagara Mohawk Power Corporation )  
(Nine Mile Point Unit 2) )

Docket No. 50-410

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Senior Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. V. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 26 day of September, 1986.

Janis M. Macro  
Notary Public in and for  
Onondaga County, New York

My Commission expires:

JANIS M. MACRO

Notary Public in the State of New York  
Qualified in Onondaga County No. 4784555  
~~My Commission Expires March 30, 1987~~



123456789