

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8610170227 DDC. DATE: 86/10/10 NOTARIZED: NO DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 MANGAN, C. V. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Submits clarification of source of info contained in 860712 response to SER Item 11 re total average & fish diversion withdrawals, blowdown & other discharges & min operative water level.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	BWR EB		1	1		BWR EICSB		2	2
	BWR FOB		1	1		BWR PD3 LA		1	1
	BWR PD3 PD		1	1		HAUGHEY, M 01		2	2
	BWR PSB		1	1		BWR RSB		1	1
INTERNAL:	ACRS	41	6	6		ADM/LFMB		1	0
	ELD/HDS3		1	0		IE FILE		1	1
	IE/DEPER/EPB	36	1	1		IE/DGAVT/QAB 21		1	1
	NRR BWR ADTS		1	0		NRR PWR-B ADTS		1	0
	NRR ROE, M. L		1	1		NRR/DHFT/MTB		1	1
	REG FILE	04	1	1		RGN1		3	3
	RM/DDAMI/MIB		1	0					
EXTERNAL:	BNL (AMDTS ONLY)		1	1		DMB/DSS (AMDTS)		1	1
	LPDR	03	1	1		NRC PDR 02		1	1
	NSIC	05	1	1		PNL GRUEL, R		1	1

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

02000-11

October 10, 1986
(NMP2L 0898)

Ms. Elinor G. Adensam, Director
BWR Project Directorate No. 3
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2
Docket No. 50-410

The Nuclear Regulatory Commission staff has requested a clarification of the source of the information contained in the Niagara Mohawk response to Safety Evaluation Report (SER) Item Number 11 transmitted by letter dated September 12, 1986 (NMP2L-0878). The information was:

- (1) total average withdrawal - 54,671 gpm
- (2) fish diversion withdrawal - 14,925
- (3) blowdown and other discharges - 32,174
- (4) minimum operative water level - 236.3 ft. (minimum postulated lake level) or 233.1 ft. (minimum intake level)

The information for Items 1 and 3 comes directly from FSAR Table 9.2-8, Intake Flow and Discharge Flow, for normal summer operation with 4 service water pumps operating. Item 2 is derived from the same table, same operating conditions, and is the difference between the Intake Flow of 54,671 gpm and the Service Water requirement of 39,746 gpm. Item 4, minimum postulated lake level, can be found in Note 2 to Table 9.2-8 while the minimum design level can be found on FSAR page 9.2-33.

Very truly yours,

B610170227 B61010
PDR ADOCK 05000410
E: PDR

C. V. Mangán

C. V. Mangán
Senior Vice President

TS/pns
2118G
Enclosures
xc: W. A. Cook, NRC Resident Inspector
Project File (2)

Boo1
111



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Niagara Mohawk Power Corporation)
(Nine Mile Point Unit 2))

Docket No. 50-410

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Senior Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. V. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 10th day of October, 1986.

Christine Austin
Notary Public in and for
Onondaga County, New York

My Commission expires:
CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4787687
My Commission Expires March 30, 1987

CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4787627
My Commission Expires March 30, 19__