

October 9, 1986

Docket No. 50-410

APPLICANT: Niagara Mohawk Power Corporation

FACILITY: Nine Mile Point, Unit 2

SUBJECT: MEETING SUMMARY FOR SEPTEMBER 24, 1986, MEETING ON
MAIN STEAM ISOLATION VALVES

On September 24, 1986, the staff met with representatives of Niagara Mohawk Power Corporation (NMPC) and their consultants from Stone and Webster Engineering Corporation (SWEC) to discuss problems with the main steam isolation valves (MSIVs) at Nine Mile Point, Unit 2 (NMP-2). In the last several months NMPC has discovered major problems with the MSIV actuator latching mechanism and galling of the valve ball.

On August 27, 1986, the staff met with NMPC to discuss the August 22, 1986, exemption request on the MSIV actuator problem. Subsequently, the exemption request for the actuators was revised and resubmitted on August 28, 1986. While the staff was in the process of reviewing the revised exemption request the MSIV actuators, NMPC identified an additional problem concerning the leakage rates of the MSIVs. In the process of performing some additional leak rate tests in late August 1986, NMPC discovered these valves were leaking at a rate significantly higher than during tests performed in spring of 1985, and spring of 1986. Upon disassembly, NMPC discovered galling of the tungsten carbide coating on the valve ball. When the ball was rotated during opening and closing of these valves, the galled tungsten carbide was passing over the stellite valve seats and scoring them. This scoring resulted in the much higher valve leakage rates.

NMPC then embarked on a testing program of these valves. The one successful test involved a spare valve ball, a modified spring arrangement for the valve seat, and a modified valve operator which used hydraulics rather than a latching mechanism to hold the valve open. The valve was cycled 75 times. Leak tests were performed after 5, 15, 25, 35, 45, 55, 65 and 75 cycles. The leak rate for all tests was below the 6 SCFH allowable leakage rate.

At the time of the September 24, 1986, meeting, NMPC had scheduled additional testing with an MSIV with a "blended" ball (i.e., the galled surface had been machined to smooth out the rough edges), the new seat assembly, and a modified actuator. This test was completed on September 26, 1986. This valve assembly did not pass the leakage test after 2 cycles. After disassembly it was determined that the galling problems were continuing and that a blended ball was not acceptable.

NMPC has stated in discussions with the staff, that it is proceeding with removing the old tungsten carbide coating and recladding the valves. A revised exemption request was submitted October 2, 1986, and is under review. The complete report is scheduled for submittal October 10, 1986.

8610210015 861009
PDR ADOCK 05000410
A PDR



October 9, 1986

MEETING SUMMARY DISTRIBUTION

Docket No(s): 50-410

NRC PDR

Local PDR

BWD #3 r/f

J. Partlow

E. Adensam

Attorney, OGC

E. Jordan

B. Grimes

ACRS (10)

Project Manager M. Haughey

E. Hylton

NRC PARTICIPANTS

R. K. Shaw

J. D. Page

R. M. Bernero

E. G. Adensam

F. J. Witt

A. J. Fiorente

J. Lombardo

R. G. LaGrange

B. Turovlin

Jack Kudrick

Gus Lainas

Jerry Hulman

Wayne Hodges

Owen Rothberg

H. F. Conrad

R. A. Hermann

bcc: Applicant & Service List



THE UNIVERSITY OF CHICAGO

[The following text is extremely faint and largely illegible due to the quality of the scan. It appears to be a multi-paragraph document, possibly a letter or a report, with several lines of text in each paragraph. Some words are barely discernible, but the overall structure suggests a formal communication.]

[This block contains a vertical column of small, dark marks or characters, possibly a list or a series of data points, which are difficult to read due to the low resolution of the scan.]

Mr. C. V. Mangan
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit 2

cc:

Mr. Troy B. Conner, Jr., Esq.
Conner & Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, N.W.
Washington, D.C. 20006

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, New York 12223

Mr. Paul D. Eddy
New York State Public Service
Commission
Nine Mile Point Nuclear Station -
Unit II
P.O. Box 63
Lycoming, New York 13093

Ezra I. Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

Resident Inspector
Nine Mile Point Nuclear Power Station
P. O. Box 99
Lycoming, New York 13093

Mr. John W. Keib, Esq.
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Mr. James Linville
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Norman Rademacher, Licensing
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Don Hill
Niagara Mohawk Power Corporation
Suite 550
4520 East West Highway
Bethesda, Maryland 20814



The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that proper record-keeping is essential for ensuring the integrity and reliability of financial data. This section also outlines the various methods and tools used to collect and analyze financial information, highlighting the need for consistency and precision in data entry and reporting.

The second part of the document focuses on the application of these principles in a practical setting. It provides a detailed overview of the data collection process, from identifying the sources of information to the final analysis and reporting. This section includes several examples and case studies that illustrate how the theoretical concepts discussed in the first part are applied in real-world scenarios.

The third part of the document addresses the challenges and limitations of data collection and analysis. It discusses the potential for errors and biases in data collection, as well as the impact of these factors on the overall quality and accuracy of the results. This section also explores various strategies and techniques to minimize these risks and ensure the highest possible level of data integrity.

The fourth part of the document provides a comprehensive summary of the key findings and conclusions of the study. It reiterates the importance of rigorous data collection and analysis practices and offers practical recommendations for future research and implementation. This section also includes a final discussion on the broader implications of the findings and the potential for further exploration in this field.

The fifth part of the document contains the references and bibliography, listing the sources of information used throughout the study. This section is organized alphabetically and includes a wide range of academic and professional publications, providing a clear and concise list of the literature that informed the research.

The sixth part of the document includes the appendices, which provide additional data, tables, and figures that support the main text. These appendices are organized into separate sections, each containing detailed information that is too extensive to include in the main body of the document. This section is essential for providing a complete and thorough understanding of the research findings.

ATTENDEESMSIV MEETING 9/ 24/ 86

<u>NAME</u>	<u>ORGANIZATION</u>
R. A. Cushman	NMPC
A. F. Zallnick	NMPC
C. E. Crocker	SWEC
C. D. Terry	NMPC
M. A. Durka	SWEC
M. A. Fachada	SWEC
E. R. Klein	NMPC
T. D. Fay	NMPC
D. L. Hill	NMPC
K. F. Roenick	NYS PSC
H. K. Shaw	NRC/DBL/EB
J. D. Page	NRC/NRR//DSRO/E1B
R. M. Bernero	NRC/DBL
E. G. Adensam	NRC/DBL
F. J. Witt	NRC/DBL/PSB
A. J. Fiorente	SWEC
J. Lombardo	NRC/DBL/EB
B. Miller	BNL
R. G. LaGrange	NRC/DBL/EB
B. Turovlin	NRC/DBL/EB
Jack Kudrick	NRC/DBL/PSB
Gus Lainas	NRC/DBL
T. J. Perkins	NMPC
C. Mangan	NMPC
Jerry Hulman	NRC/DBL/PSB
Wayne Hodges	NRC/DBL/RSB
Owen Rothberg	NRC/NRR/DSRO
H. F. Conrad	NRC/DBL/EB
R. A. Hermann	NRC/DBL/EB

1944
1945
1946
1947
1948
1949
1950
1951
1952
1953
1954
1955
1956
1957
1958
1959
1960
1961
1962
1963
1964
1965
1966
1967
1968
1969
1970
1971
1972
1973
1974
1975
1976
1977
1978
1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997
1998
1999
2000
2001
2002
2003
2004
2005
2006
2007
2008
2009
2010
2011
2012
2013
2014
2015
2016
2017
2018
2019
2020
2021
2022
2023
2024
2025

1944
1945
1946
1947
1948
1949
1950
1951
1952
1953
1954
1955
1956
1957
1958
1959
1960
1961
1962
1963
1964
1965
1966
1967
1968
1969
1970
1971
1972
1973
1974
1975
1976
1977
1978
1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997
1998
1999
2000
2001
2002
2003
2004
2005
2006
2007
2008
2009
2010
2011
2012
2013
2014
2015
2016
2017
2018
2019
2020
2021
2022
2023
2024
2025

The modified actuator design used a solenoid valve with a teflon seat. As teflon does not perform well in a radioactive environment, NMPC is looking for an alternate material for the valve seat.


NMPC is also developing a plan for additional long-term prototype testing of these valves.


Enclosure 1 contains a handout provided by NMPC of the slides used for their presentation.

Enclosure 2 contains a list of meeting attendees.

Mary F. Haughey, Project Manager
BWR Project Directorate No. 3
Division of BWR Licensing

Enclosure:
As stated


BWD-3:DBL
MHaughey/vag
10/9/86


D/BWD-3:DBL
EAdensam
10/9/86

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is essential for the proper management of the organization's finances and for ensuring compliance with applicable laws and regulations.

2. The second part of the document outlines the specific procedures that should be followed when recording transactions. This includes the use of standardized forms and the requirement that all entries be supported by appropriate documentation.

3. The third part of the document discusses the role of the accounting department in the overall financial management process. It highlights the department's responsibility for providing timely and accurate financial information to management and other stakeholders.

4. The fourth part of the document discusses the importance of internal controls in preventing fraud and ensuring the integrity of the financial reporting process. It provides examples of effective internal control measures that can be implemented in an organization.

5.

6.

7.

NRC NMP2 MSIV MEETING

SEPTEMBER 24, 1986

- o GENERAL OVERVIEW
- o NIAGARA MOHAWK MANAGEMENT TEAM AND PROGRAMS
- o TESTING/ROOT CAUSE ANALYSIS
- o SEAT LEAKAGE
- o ACTUATOR FUNCTION
- o CONCLUSION



C. D. TERRY

E. R. KLEIN

J. HUTTON

D. L. PIKE

Valve Operability Programs:

- Seat Leakage
- Closure Time

Testing Programs:

- Prototype Tests
- Mechanical Latch

Contingency Programs:

- Y Pattern Valves
- Leakage Control System



T E S T I N G P R O G R A M S

o THOROUGH ROOT CAUSE ANALYSIS OF LEAKAGE PROBLEMS

- Dedicated Manager
- Consultants - MPR, GE, W, CRCSBY
- Discussions with Other Users - Swiss and Beaver Valley
- Prototype Test Setup Being Expedited

o DEVELOPMENT OF MECHANICAL LATCH FOR VALVE CLOSURE

- Reduction of Inadvertent Actuations
- Will Use Prototype Setup to Verify Operability



1) LEAKAGE


- ORIGINAL DESIGN
 - GENERAL DESCRIPTION
 - SEAL DESIGN
- PROBLEM DESCRIPTION
 - BALL CONDITION
 - BEARING PRESSURE ON BALL
 - LEAKAGE TEST RESULTS
- PROPOSED SOLUTION
 - OPTION 1 - REWORKED BALL
 - OPTION 2 - RECOATED BALL AND REVISED SPRINGS
- TEST RESULTS
 - TEST PROGRAM AND BASIS
 - OPTION 1 RESULTS
 - OPTION 2 RESULTS
- SCHEDULE






2. 1. 2

2. 1. 2







112



MAIN STEAM ISOLATION VALVE. (MSIV)

FIGURE 2-1.








1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100


101


102

103

104









SEE DETAIL "A"
MSIV SEAL ARRANGEMENT

NMP2
MSIV SPOOL SE.
& BALL INTERFA




MSIV SEAL ARRANGEMENT DETAIL "A"







BALL CONDITION


TOP VIEW
















BALL TO SEAL CONTACT




BALL VALVE OPEN



BALL VALVE AT 6°




BALL VALVE AT 12°



BALL VALVE AT 16°




FOOTPRINT STRESS ON BALL




BALL VALVE OPEN

378 PSI

FOOTPRINT STRESS DIAGRAM



BALL VALVE AT 15.8°



FOOTPRINT STRESS DIAGRAM



	PRELIM	ACTUAL	RETEST
	TYPE "C"	TYPE "C"	TYPE "C"
DATE	4/85	3/86	9/2/86
6A	0.89	1.09	22
6B	1.37	0.54	40.2
6C	0.321	0.158	37.3
6D	0.99	0.215	42
7A	0.34	0.084	30.3
7B	2.778	1.183	42
7C	0.798	0.199	23.6
7D	0.306	0.088	16.7

NMP2 MSIV
LEAK TESTS

NOTES:

- 1) ALL VALVES STROKED FOR ACTUATOR TESTING BETWEEN 3/86 AND 9/86
- 2) ALL TESTING DONE BETWEEN SEATS
- 3) ALL VALUES IN SCFH



- OPTION 1 6D -

- ° EXISTING SPRING DESIGN
- ° REWORKED BALL
- ° 75 CYCLES


- OPTION 2 7D-

- ° REVISED SPRING DESIGN
- ° RECOATED BALL
- ° 75 CYCLES




REWORKED
BALL CONDITION

TOP VIEW





REVISED SPRING PACK




TOTAL 64 SPRINGS



MSIV STROKES

BASED ON 1ST REFUELING (30 MONTHS)

ISI & RPS (1 MONTH)	30
UNANTICIPATED TRIPS	25 TO 33
PLANNED TRIPS	5
ACTUATOR CHECK OUT	5
PRE OPERATIONAL TESTS	2
	<hr/>
FOR TESTING USE TOTAL	75



TEST PROGRAM

<u>ACCUMULATED STROKES</u>	<u>BETWEEN SEATS</u>	<u>THROUGH SEATS</u>
5	X	X
15	X	X
25	X	
35	X	
45	X	
55	X	
65	X	
75	X	X

X - RECORD IN LEAKAGE AT STEADY STATE CONDITIONS



TYPE "C" TEST RESULTS

STROKES		5	15	25	35	45	55	65	75
OPTION 1	TS	5.1	5.5	10.9	-	-	-	-	-
6D	BS	11.2	51	132	-	-	-	-	-
OPTION 2	TS	2.3	2.9	-	-	-	-	-	3.2
7D	BS	4.8	4.9	4.7	4.4	4.2	4.0	3.9	4.4

TS - THROUGH SEATS

BS - BETWEEN SEATS

ALL VALUES IN SCFH



MSIV ACTUATOR

- ° ORIGINAL DESIGN
- ° PROBLEM DESCRIPTION
- ° PROPOSED SOLUTION
 - ° DESIGN CONCEPT - HYDRAULIC SYSTEM
 - ° EQUIPMENT
 - ° SAFETY FUNCTION
 - ° SEISMIC QUALIFICATION
- ° TESTING RESULTS
 - ° LEAKAGE
 - ° CYCLE TIMES
 - ° RESPONSE TIMES
- ° SCHEDULE



1 2 3

4

5

6


7

8

9

10

MSIV CLOSURE MECHANISM





MSIV ACTUATOR

- ORIGINAL DESIGN

- A. VALVE OPENING SEQUENCE

- SOVS CLOSED
 - HYDRAULIC PUMP ON
 - VALVE GOES TO OVERTRAVEL
 - LATCH SLIPS INTO PLACE
 - PUMP IS SHUT OFF
 - OPEN SOVs



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

MSIV ACTUATOR

- ORIGINAL DESIGN

- B. TEST MODE

- VALVE IS ON THE LATCH
 - CLOSE SOVS
 - TRIP THE LATCH
 - CATCH VALVE MOTION ON HYDRAULIC SYSTEM
 - DESIGN CAPABILITY TO DUMP SOVS ON COMMAND



.....

MSIV ACTUATOR

- ° PROBLEM DESCRIPTION
 - ° SOLENOIDS DID NOT TRIP THE MSIV
 - ° LOAD REQUIRED TO TRIP INCREASES WITH TIME
 - ° AT 12 HOURS - LOAD INCREASED BY 1.5X
 - ° AT 24 HOURS - LOAD INCREASED BY 2.0X
 - ° AT 7 DAYS - LOAD INCREASED BY 3.0X
 - ° PRESENT SOLENOIDS ARE NOT ADEQUATE TO TRIP MSIV



.....

MSIV ACTUATOR

- PROPOSED MODIFICATION
 - DESIGN CONCEPT
 - USE THE EXISTING HYDRAULIC SYSTEM TO KEEP THE VALVE OPEN
 - ADD NO CAT. I EQUIPMENT
 - MAINTAIN SAFETY OPERATION OF MSIV
 - MINIMAL CHANGES TO THE ACTUATOR



1 1 1 1

MSIV ACTUATOR

- ° PROPOSED MODIFICATION
 - ° EQUIPMENT
 - ° EXISTING HYDRAULIC EQUIPMENT
 - ° PIPING 304SS SCH. 40 .109" To .154"
WALL THK:
 - ° FLEX HOSE 2500 PSI RATING
 - ° HYDRAULIC CYLINDER
 - ° HYDROLINE HL-E-269
 - ° PUMP
 - ° 3 HP, 3 GPM, 1500 PSI
 - ° SOV TARGET ROCK
 - ° BALANCED PISTON DESIGN
 - ° DESIGN PRESSURE 1950 PSI
 - ° SA 182 Tp 316
 - ° MAX. DIFFERENTIAL PRESSURE 1450 PSI



.....

MSIV ACTUATOR

- o PROPOSED MODIFICATIONS
 - o EQUIPMENT
 - o ADDED EQUIPMENT
 - o HYDRAULIC ACCUMULATOR
 - o PARKER PISTON TYPE
 - o PISTON HAS EPR SEALS
 - o 2½ GALLON CAPACITY
 - o JOCKEY PUMP
 - o 3/4 HP, 0.6 GPM, 1800 PSI
 - o PRESSURE SWITCHES (2), STATIC O-RING
 - o MODIFIED EQUIPMENT
 - o HYDRAULIC CYLINDER
 - o MECHANICAL STOP
 - o LIP SEAL EPR
 - o SOV
 - o DISK & O-RING MATERIALS ARE BEING QUALIFIED BY TESTING



1 1 1 1



.....

.....

.

.

.

.

.

MSIV ACTUATOR

- PROPOSED MODIFICATION
 - SAFETY FUNCTION
 - MECHANICAL SAFETY OPERATION IS ESSENTIALLY UNCHANGED
 - RELEASE OF STORED ENERGY IN SPRINGS
 - HYDRAULICS CONTROL VALVE CLOSURE TIME



.....
.....
.....

MSIV ACTUATOR

- PROPOSED MODIFICATION

SEISMIC/DYNAMIC QUALIFICATION

- DETERMINE EFFECTS OF MODIFICATION ON ACTUATOR ASSEMBLY DYNAMIC RESPONSE - COMPLETE
 - WEIGHT CHANGES ARE INSIGNIFICANT
 - STIFFENESS CHANGES ARE INSIGNIFICANT
 - REQUIRED RESPONSE SPECTRA AT THE ACTUATOR ASSEMBLY BASE REMAIN UNCHANGED
 - DYNAMIC TEST RESULTS FOR THE ACTUATOR ASSEMBLY ARE UNAFFECTED AND VALID (EXCEPT FOR SOME COMPONENTS DISCUSSED BELOW)
- DETERMINE QUALIFICATION ADEQUACY OF THE SOVS
 - DETERMINE SEISMIC/DYNAMIC REQUIREMENTS AT THE SOV LOCATION - UTILIZING TEST RESPONSE SPECTRA AND MODAL ANALYSIS
 - ESTABLISH QUALIFICATION OF SOVS BY SIMILARITY TO EXISTING TEST DATA
- QUALIFICATION OF ADDITIONAL PANEL AND RELAYS
 - DETERMINE SEISMIC/DYNAMIC REQUIREMENTS
 - QUALIFICATION OF RELAYS UTILIZING EXISTING TEST DATA
 - QUALIFICATION OF PANEL BY ANALYSIS



.....
.....
.....

.....
.....

.....

.....

MSIV ACTUATOR

TESTING RESULTS


- LEAKAGE
 - SOV
 - UNDETECTABLE
 - HYDRAULIC CYLINDER
 - 2 CU. IN./MIN.
 - OTHER
 - VERY LOW
- CYCLE TIMES
 - DESIGN 30 MINUTES
 - ACTUAL 20 MINUTES TO 3 HOURS
 - PRESSURE BAND 1400 PSI - 1250 PSI
- RESPONSE TIMES
 - WITHIN 5 SEC. VALVE CLOSURE REQUIREMENT
 - TRIPPING EITHER VALVE INDEPENDENTLY



11
12
13
14

SCHEDULE

ADDITIONAL EQUIPMENT	9/25
NEW HYDRAULIC CYLINDER	10/10
NEW DISKS/SEATS	10/15
INSTALL EQUIPMENT	10/15 - 10/21
SEISMIC QUALIFICATION	10/21
TESTING	10/21 - 11/3
MSIVs COMPLETE	11/5



CONCLUSION

MODIFIED HYDRAULIC SYSTEM

- o MINIMAL CHANGES
- o No ADDITIONAL QA CAT, I EQUIPMENT
- o SAME SAFETY OPERATION
- o SUCCESSFUL DEMONSTRATION TESTING



200

200

CONCLUSION

- o LEAKAGE TESTING WITH VALVE CYCLING GIVES CONFIDENCE OF VALVE OPERABILITY THROUGH FIRST REFUELING OUTAGE
- o PREOPERATIONAL AND SHOP TESTING PROGRAM WILL CONFIRM ACTUATOR OPERABILITY BEFORE HEAT UP
- o LEAKAGE TESTING TESTING CONDUCTED SHOWS BETWEEN SEAT TEST IS CONSERVATIVE
- o TESTING PROGRAMS
 - PROVIDE COMPLETE UNDERSTANDING OF ROOT CAUSE
 - DETERMINE NEED AND TYPE OF LONG TERM MODIFICATIONS, IF ANY
 - DEVELOP MECHANICAL ACTUATOR LATCH

