

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8702120092 DDC DATE: 87/02/06 NOTARIZED: YES DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 MANGAN, C. V. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Clarifies B61020 ltr re MSIV leakage data. Table 4-3 through-
 the-seat leakage values used to confirm between-the-seat
 (BTS) data on gross bases. BTS test results conservatively
 factor of 2 greater than obtained through-the-seats.

DISTRIBUTION CODE: A017D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: Append J Containment Leak Rate Testing

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL
BWR ADTS	1	1	BWR EB	1	1
BWR EICSB	2	2	BWR FOB	1	1
BWR PD3 LA	1	0	BWR PD3 PD 01	5	5
HAUGHEY, M	1	1	BWR PSB	1	1
BWR RSB	1	1			

INTERNAL:	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL
	ACRS 07	10	10	ADM/LFMB	1	0
	ELD/HDS3 08	1	1	NRR BWR ADTS	1	1
	NRR PWR-A ADTS	1	1	NRR PWR-B ADTS	1	1
	NRR/DSRO/EIB	1	1	NRR/DSRO/RSIB	1	1
	<u>REG FILE</u> 04	1	1			
EXTERNAL:	LPDR 03	1	1	NRC PDR 02	1	1
	NSIC 05	1	1			



2 72

[The following text is extremely faint and largely illegible due to the quality of the scan. It appears to be a multi-paragraph document with several lines of text per paragraph, possibly containing a list or a series of entries. The text is scattered across the upper and middle portions of the page.]



NIAGARA MOHAWK POWER CORPORATION/301 PLAINFIELD ROAD, SYRACUSE, N.Y. 13212/TELEPHONE (315) 474-1511

February 6, 1987
(NMP2L 0992)

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Re: Nine Mile Point Unit 2
Docket No. 50-410

Gentlemen:

Our October 20, 1986 letter provided data relative to the Main Steam Isolation Valve leakage. Specifically, the leakage values shown on Table 4-3 were not intended to confirm the relationship between the through-the-seat testing and between-the-seat testing. The through-the-seat values were used as a means to confirm on a gross bases the between-the-seat data. The precision necessary to confirm the leakage relationship between through-the-seat and between-the-seat testing was not used. However, our calculations (submitted in our August 21, 1986 letter) and recent test data (which was performed to 10CFR50 Appendix J criteria) confirms that test results between-the-seats are conservatively a factor of 2 greater than those obtained through the seats.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

C. V. Mangan
C. V. Mangan
Senior Vice President

NLR/pns
2622G

xc: Regional Administrator, Region I
Ms. E. G. Adensam, Project Director
Mr. W. A. Cook, Resident Inspector
Project File (2)

8702120092 870206
PDR ADOCK 05000410
PDR

A017
1/1



THE UNIVERSITY OF CHICAGO

PHYSICS DEPARTMENT

PHYSICS 309

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of]
Niagara Mohawk Power Corporation] Docket No. 50-410
(Nine Mile Point Unit 2)]

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Senior Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. V. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 6th day of February, 1987.

Beth A. Menckheim
Notary Public in and for
Onondaga County, New York

My Commission expires:
BETH A. MENTKHEIM
Notary Public in the State of New York
Qualified in Onondaga County No. 4804074
My Commission Expires August 31, 1988

PROF. A. WEINSTEIN
UNIVERSITY OF CALIFORNIA
SAN DIEGO, CALIF. 92161