

February 10, 1987

MEMORANDUM FOR: Sholly Coordinator

FROM: John A. Zwolinski, Director
BWR Project Directorate #1, DBL

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE
(TAC 62287)

Niagara Mohawk Power Corporation, Docket No. 50-220, Nine Mile Point
Nuclear Station, Unit No. 1, Oswego County, New York

Date of amendment request: August 22, 1986

Brief description of amendment: The amendment adds surveillance requirements
to Technical Specification Section 4.4.5 to verify the ability of the control
room air treatment system to maintain a positive pressure in the control
room to maintain control room habitability during accident conditions.

Date of issuance: February 10, 1987

Effective date: February 10, 1987

Amendment No.: 91

Facility Operating License No. DPR-63. Amendment revised the Technical
Specifications.

Date of initial notice in Federal Register: October 8, 1986 (51 FR 36099).

The Commission's related evaluation of the amendment is contained in a
Safety Evaluation dated February 10, 1987

No significant hazards consideration comments received: No.

Local Public Document Room location: State University of New York, Penfield
Library, Reference and Documents Department, Oswego, New York 13126.

8702190428 870210
PDR ADOCK 05000220
P PDR

Original signed by
John A. Zwolinski, Director
BWR Project Directorate #1, DBL

DISTRIBUTION

Docket File JKelly
BWD1 Reading CJamerson
JZwolinski

DBL:BWD1
CJamerson
1/28/87

DBL:BWD1JK
JKelly:JG
1/28/87

AGC-BETH
DBL:BWD1
JZwolinski
2/2/87 2/10/87

