

Enclosure 2

NMP-1 SEISMIC UPGRADE
PROGRAM PLAN AND DESCRIPTION

Revision 1

June, 1987

8707130094 870629
PDR ADDCK 05000220
P PDR



1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33



Handwritten text at the bottom of the page, possibly a signature or date.

CONTENTS

<u>Section</u>		<u>Page</u>
1	INTRODUCTION	1-1
2	APPROACH	2-1
3	DESCRIPTION OF THE SEISMIC UPGRADE PROGRAM	3-1
	Re-evaluation of Original NMP-1 Seismic Design Bases	3-1
	Re-definition of Seismic Design Input	3-6
	Re-evaluation of Class 1 and 2 Structures	3-13
	Generation of Floor Response Spectra	3-27
	Re-evaluation of Selected Class 1 and 2 Piping Systems.	3-30
	Re-evaluation of Piping Supports	3-35
	Seismic Qualification of Equipment	3-35
	Program Administration	3-36
4	APPENDICES	
	A Seismic Classification of NMP-1 Structures, Systems and Equipment	A-1
	B Applicable Codes, Standards and Specifications	B-1
	C Damping Values for Structures and Equipment	C-1



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

FIGURES

<u>Figure</u>		<u>Page</u>
3-1	NMP-1 Seismic Upgrade Program Chart	3-2
3-2	Acceleration Hazard: 16,50 and 84 Percentiles	3-11
3-3	Acceleration Response Spectra (5% Damping)	3-12
3-4	Reactor Building Model	3-16
3-5	Turbine Building Model	3-17
3-6	Turbine Building Extension	3-18
3-7	Screen and Pump House Model	3-19
3-8	Waste Disposal Building and Extension and Off Gas Building Models	3-20
3-9	Administration Building and Extension Model	3-21
3-10	Radwaste Solidification Building Model	3-22
3-11	Reactor Building Exterior Walls and Floors	3-23
3-12	Reactor Building Secondary Shield Wall	3-24
3-13	Screen and Pump House Static Model	3-25
3-14	Milestone Schedule	3-37



TABLES

Table

Page

3-1 Summary of Support Evaluations

3-7

中華民國二十九年四月一日

Section 1 INTRODUCTION

PURPOSE

The purpose of the NMP-1 Seismic Upgrade Program (SUP) is to incorporate advances in seismic design methodology and criteria to develop a more modern definition of the seismic adequacy of NMP-1. The SUP will also provide Niagara Mohawk with new, up-to-date methods and criteria for analysis and control of plant data and for future plant modifications.

BACKGROUND

This report describes the NMP-1 Seismic Upgrade Program (SUP). The SUP is a follow-on activity from the Systematic Evaluation Program (SEP) and Integrated Safety Assessment Program (ISAP), in which Niagara Mohawk voluntarily participated between 1981 and 1986. These programs involved a significant investment in the re-evaluation of the seismic design and adequacy of NMP-1, including reviews of original seismic design bases, evaluations of structures and piping, and plant walkdowns. The SEP/ISAP review has demonstrated that NMP-1 is a well-designed, safe plant, but that documentation to demonstrate the seismic design adequacy of the plant is limited. Further, there have been extensive changes in seismic design methodology and criteria since the mid-60's when NMP-1 was designed. For these reasons, Niagara Mohawk plans to complete a systematic re-assessment and upgrade, if necessary, of all important aspects of the seismic design of NMP-1. This effort, the NMP-1 SUP, will build on seismic evaluation work completed in the SEP/ISAP project and will address:

- ° The design ground motion response spectra,

公

漢

帝

紀

卷

之

八

上

卷

之

八

上

卷

之

八

上

卷

之

八

上

卷

之

八

上

卷

之

八

上

卷

之

八

上

卷

之

八

- ° Seismic Class 1 and 2 structures, piping and supports, and
- ° Safe shutdown mechanical and electrical equipment.

As part of this effort, we plan to develop and use consistent and modern seismic design methodology and criteria, such that the seismic safety of the plant can be judged in a realistic and consistent manner and can be compared with that of more modern nuclear plants. Eventually, the criteria which evolve from this program will be NMP-1's licensing design basis and will be used for future plant modifications and additions.

OBJECTIVES

This program has several objectives:

- ° To provide state-of-the-art criteria and methodology to be used for future plant modifications and additions.
- ° To re-assess the adequacy of the NMP-1 seismic design based on up-to-date, improved methods and acceptance criteria.
- ° To demonstrate and document the seismic adequacy of NMP-1 compared to that of modern nuclear plants.
- ° To provide a comprehensive, as-built structural data base for plant structures and piping systems. This data base is intended to provide up-to-date, state-of-the-art design and computer models (three-dimensional, finite element) of Class 1 structures and important piping and support systems.
- ° To prepare for future seismic evaluation programs currently being developed by the USNRC.

蘇聯科學院

地質研究所

地質研究所

SCOPE

The scope of the SUP will include all seismic Class 1 and 2 structures, piping and supports as defined in the NMP-1 FSAR and listed in Appendix A of this report, so that resulting SUP criteria and methodology may form a new licensing basis for the plant. In addition, other active mechanical and electrical equipment, heat exchangers, tanks and electrical cable tray/ conduit systems will be evaluated in accordance with the USI A-46 program.

TIMING

The SUP will be undertaken by NMPC as a voluntary effort over the next several years. In the near term, the objective is to develop and obtain NRC approval of new seismic criteria for use in the Spring, 1988 Outage of NMP-1, for the USI A-46 program, and for other seismic evaluations which may be performed.

REPORT CONTENT

The sections of this report which follow provide an overview of the technical approach to be followed, a summary of the seismic re-evaluation work already completed and a description of the plans, methodology and criteria for the NMP-1 SUP.

一、

二、

三、

Section 2

APPROACH

GENERAL APPROACH

This program will approach the seismic qualification issue by developing and using new, realistic methodology and acceptance criteria to re-assess the seismic design of NMP-1 structures, systems and equipment. It is recognized that significant progress and changes have been made in the industry's refinement of seismic loads, seismic methodology and seismic acceptance criteria since NMP-1 was designed in the mid-1960's, and over the intervening years. This has led to inconsistencies in the seismic design bases for plant systems and structures and uncertainties in the seismic margins provided. It is also clear that the original seismic design bases for NMP-1 are in some cases inappropriate compared to current seismic design practice. As a result, it is considered essential that realistic, self-consistent criteria, methods and load definitions be developed and used without reference to original design bases. This approach has been successful in SEP and other seismic re-evaluation efforts underway in the industry and has been approved in the past by the USNRC. Comparison of new loading to old criteria, or vice-versa, is considered to be inconsistent and inappropriate.

In the course of SEP/ISAP work, the following studies have been completed:

- Re-evaluation of original NMP-1 seismic design bases
- Review of all existing NMP-1 design records



- Development of state-of-the-art, uniform hazard ground motion response spectra for the NMP-1 site
- Plant seismic walkthrough
- Review of NMP-1 piping analyses of record
- Review of existing structural analyses, and subsequent re-analysis of the NMP-1 vent stack
- Evaluation of anchorage of mechanical equipment
- Definition of structural loads on the plant, including earthquake
- Modeling of building structures
- Generation of preliminary floor response spectra
- Re-analysis of selected piping systems.

The SUP approach will include (1) review and up-dating, if necessary, of the completed SEP/ISAP reviews and analyses using new methodology and criteria, and (2) expansion of the scope of the seismic evaluation to cover the structures, systems and equipment defined in the SUP scope. Specifically, it is anticipated that the following tasks will be undertaken as part of the SUP:

- Development of SUP analysis methodology and criteria
- Re-evaluation and re-definition, as needed, of the seismic ground motion spectra
- Re-evaluation of Class 1 and 2 structures using new models and methodology
- Generation of new, realistic floor response spectra
- Re-evaluation of Class 1 and 2 piping systems and supports
- Seismic qualification of equipment, including mechanical and electrical equipment, heat exchangers, tanks and electrical cable and conduit raceways.



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
848
849
850
851
852
853
854
855
856
857
858
859
860
861
862
863
864
865
866
867
868
869
870
871
872
873
874
875
876
877
878
879
880
881
882
883
884
885
886
887
888
889
890
891
892
893
894
895
896
897
898
899
900
901
902
903
904
905
906
907
908
909
910
911
912
913
914
915
916
917
918
919
920
921
922
923
924
925
926
927
928
929
930
931
932
933
934
935
936
937
938
939
940
941
942
943
944
945
946
947
948
949
950
951
952
953
954
955
956
957
958
959
960
961
962
963
964
965
966
967
968
969
970
971
972
973
974
975
976
977
978
979
980
981
982
983
984
985
986
987
988
989
990
991
992
993
994
995
996
997
998
999
1000
1001
1002
1003
1004
1005
1006
1007
1008
1009
1010
1011
1012
1013
1014
1015
1016
1017
1018
1019
1020
1021
1022
1023
1024
1025
1026
1027
1028
1029
1030
1031
1032
1033
1034
1035
1036
1037
1038
1039
1040
1041
1042
1043
1044
1045
1046
1047
1048
1049
1050
1051
1052
1053
1054
1055
1056
1057
1058
1059
1060
1061
1062
1063
1064
1065
1066
1067
1068
1069
1070
1071
1072
1073
1074
1075
1076
1077
1078
1079
1080
1081
1082
1083
1084
1085
1086
1087
1088
1089
1090
1091
1092
1093
1094
1095
1096
1097
1098
1099
1100
1101
1102
1103
1104
1105
1106
1107
1108
1109
1110
1111
1112
1113
1114
1115
1116
1117
1118
1119
1120
1121
1122
1123
1124
1125
1126
1127
1128
1129
1130
1131
1132
1133
1134
1135
1136
1137
1138
1139
1140
1141
1142
1143
1144
1145
1146
1147
1148
1149
1150
1151
1152
1153
1154
1155
1156
1157
1158
1159
1160
1161
1162
1163
1164
1165
1166
1167
1168
1169
1170
1171
1172
1173
1174
1175
1176
1177
1178
1179
1180
1181
1182
1183
1184
1185
1186
1187
1188
1189
1190
1191
1192
1193
1194
1195
1196
1197
1198
1199
1200
1201
1202
1203
1204
1205
1206
1207
1208
1209
1210
1211
1212
1213
1214
1215
1216
1217
1218
1219
1220
1221
1222
1223
1224
1225
1226
1227
1228
1229
1230
1231
1232
1233
1234
1235
1236
1237
1238
1239
1240
1241
1242
1243
1244
1245
1246
1247
1248
1249
1250
1251
1252
1253
1254
1255
1256
1257
1258
1259
1260
1261
1262
1263
1264
1265
1266
1267
1268
1269
1270
1271
1272
1273
1274
1275
1276
1277
1278
1279
1280
1281
1282
1283
1284
1285
1286
1287
1288
1289
1290
1291
1292
1293
1294
1295
1296
1297
1298
1299
1300
1301
1302
1303
1304
1305
1306
1307
1308
1309
1310
1311
1312
1313
1314
1315
1316
1317
1318
1319
1320
1321
1322
1323
1324
1325
1326
1327
1328
1329
1330
1331
1332
1333
1334
1335
1336
1337
1338
1339
1340
1341
1342
1343
1344
1345
1346
1347
1348
1349
1350
1351
1352
1353
1354
1355
1356
1357
1358
1359
1360
1361
1362
1363
1364
1365
1366
1367
1368
1369
1370
1371
1372
1373
1374
1375
1376
1377
1378
1379
1380
1381
1382
1383
1384
1385
1386
1387
1388
1389
1390
1391
1392
1393
1394
1395
1396
1397
1398
1399
1400
1401
1402
1403
1404
1405
1406
1407
1408
1409
1410
1411
1412
1413
1414
1415
1416
1417
1418
1419
1420
1421
1422
1423
1424
1425
1426
1427
1428
1429
1430
1431
1432
1433
1434
1435
1436
1437
1438
1439
1440
1441
1442
1443
1444
1445
1446
1447
1448
1449
1450
1451
1452
1453
1454
1455
1456
1457
1458
1459
1460
1461
1462
1463
1464
1465
1466
1467
1468
1469
1470
1471
1472
1473
1474
1475
1476
1477
1478
1479
1480
1481
1482
1483
1484
1485
1486
1487
1488
1489
1490
1491
1492
1493
1494
1495
1496
1497
1498
1499
1500
1501
1502
1503
1504
1505
1506
1507
1508
1509
1510
1511
1512
1513
1514
1515
1516
1517
1518
1519
1520
1521
1522
1523
1524
1525
1526
1527
1528
1529
1530
1531
1532
1533
1534
1535
1536
1537
1538
1539
1540
1541
1542
1543
1544
1545
1546
1547
1548
1549
1550
1551
1552
1553
1554
1555
1556
1557
1558
1559
1560
1561
1562
1563
1564
1565
1566
1567
1568
1569
1570
1571
1572
1573
1574
1575
1576
1577
1578
1579
1580
1581
1582
1583
1584
1585
1586
1587
1588
1589
1590
1591
1592
1593
1594
1595
1596
1597
1598
1599
1600
1601
1602
1603
1604
1605
1606
1607
1608
1609
1610
1611
1612
1613
1614
1615
1616
1617
1618
1619
1620
1621
1622
1623
1624
1625
1626
1627
1628
1629
1630
1631
1632
1633
1634
1635
1636
1637
1638
1639
1640
1641
1642
1643
1644
1645
1646
1647
1648
1649
1650
1651
1652
1653
1654
1655
1656
1657
1658
1659
1660
1661
1662
1663
1664
1665
1666
1667
1668
1669
1670
1671
1672
1673
1674
1675
1676
1677
1678
1679
1680
1681
1682
1683
1684
1685
1686
1687
1688
1689
1690
1691
1692
1693
1694
1695
1696
1697
1698
1699
1700
1701
1702
1703
1704
1705
1706
1707
1708
1709
1710
1711
1712
1713
1714
1715
1716
1717
1718
1719
1720
1721
1722
1723
1724
1725
1726
1727
1728
1729
1730
1731
1732
1733
1734
1735
1736
1737
1738
1739
1740
1741
1742
1743
1744
1745
1746
1747
1748
1749
1750
1751
1752
1753
1754
1755
1756
1757
1758
1759
1760
1761
1762
1763
1764
1765
1766
1767
1768
1769
1770
1771
1772
1773
1774
1775
1776
1777
1778
1779
1780
1781
1782
1783
1784
1785
1786
1787
1788
1789
1790
1791
1792
1793
1794
1795
1796
1797
1798
1799
1800
1801
1802
1803
1804
1805
1806
1807
1808
1809
1810
1811
1812
1813
1814
1815
1816
1817
1818
1819
1820
1821
1822
1823
1824
1825
1826
1827
1828
1829
1830
1831
1832
1833
1834
1835
1836
1837
1838
1839
1840
1841
1842
1843
1844
1845
1846
1847
1848
1849
1850
1851
1852
1853
1854
1855
1856
1857
1858
1859
1860
1861
1862
1863
1864
1865
1866
1867
1868
1869
1870
1871
1872
1873
1874
1875
1876
1877
1878
1879
1880
1881
1882
1883
1884
1885
1886
1887
1888
1889
1890
1891
1892
1893
1894
1895
1896
1897
1898
1899
1900
1901
1902
1903
1904
1905
1906
1907
1908
1909
1910
1911
1912
1913
1914
1915
1916
1917
1918
1919
1920
1921
1922
1923
1924
1925
1926
1927
1928
1929
1930
1931
1932
1933
1934
1935
1936
1937
1938
1939
1940
1941
1942
1943
1944
1945
1946
1947
1948
1949
1950
1951
1952
1953
1954
1955
1956
1957
1958
1959
1960
1961
1962
1963
1964
1965
1966
1967
1968
1969
1970
1971
1972
1973
1974
1975
1976
1977
1978
1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997
1998
1999
2000
2001
2002
2003
2004
2005
2006
2007
2008
2009
2010
2011
2012
2013
2014
2015
2016
2017
2018
2019
2020
2021
2022
2023
2024
2025
2026
2027
2028
2029
2030
2031
2032
2033
2034
2035
2036
2037
2038
2039
2040
2041
2042
2043
2044
2045
2046
2047
2048
2049
2050
2051
2052
2053
2054
2055
2056
2057
2058
2059
2060
2061
2062
2063
2064
2065
2066
2067
2068
2069
2070
2071
2072
2073
2074
2075
2076
2077
2078
2079
2080
2081
2082
2083
2084
2085
2086
2087
2088
2089
2090
2091
2092
2093
2094
2095
2096
2097
2098
2099
2100
2101
2102
2103
2104
2105
2106
2107
2108
2109
2110
2111
2112
2113
2114
2115
2116
2117
2118
2119
2120
2121
2122
2123
2124
2125
2126
2127
2128
2129
2130
2131
2132
2133
2134
2135
2136
2137
2138
2139
2140
2141
2142
2143
2144
2145
2146
2147
2148
2149
2150
2151
2152
2153
2154
2155
2156
2157
2158
2159
2160
2161
2162
2163
2164
2165
2166
2167
2168
2169
2170
2171
2172
2173
2174
2175
2176
2177
2178
2179
2180
2181
2182
2183
2184
2185
2186
2187
2188
2189
2190
2191
2192
2193
2194
2195
2196
2197
2198
2199
2200
2201
2202
2203
2204
2205
2206
2207
2208
2209
2210
2211
2212
2213
2214
2215
2216
2217
2218
2219
2220

LICENSING APPROACH

It is the intent of this program to develop a realistic, self-consistent and up-to-date seismic design basis for the NMP-1 plant. The methodology and criteria developed for the SUP will be used for all re-assessments and, in the future, as the licensing basis for any plant modifications or additions.



..

2000 年 10 月

第 10 次 统计调查

第 10 次 统计调查

Section 3

DESCRIPTION OF THE SEISMIC UPGRADE PROGRAM

The main elements of the Seismic Upgrade Program (SUP) are shown in Figure 3-1 and described below. Some of this work was initiated in the SEP/ISAP effort, and will be re-evaluated and up-dated in the SUP. Other tasks are new and will be performed as part of the SUP. The status of completed tasks and planned SUP efforts are summarized below.


RE-EVALUATION OF ORIGINAL NMP-1 SEISMIC DESIGN BASES

The seismic re-evaluation of the original NMP-1 plant design was initiated in the SEP/ISAP program, and was based on the methodology developed by the USNRC for review of SEP plants of similar vintage to NMP-1. In this approach, a sampling of representative and most vulnerable equipment, systems and structures were re-evaluated for seismic adequacy. The structures, systems and equipment reviewed were selected based on (1) review of available original design records, and (2) a walk-through inspection by a team of NMPC and contractor engineers experienced in seismic design and analysis. The specific tasks undertaken in the re-evaluation are summarized below.

Design Record Review

A review was made of the seismic design basis for NMP-1 as presented in the NMP-1 Preliminary Hazards Analysis Report and the Final Safety Analysis Report. Areas reviewed included the design basis earthquake, seismic classification of structures, systems and equipment, load combinations and acceptance criteria. In addition, a substantial effort was undertaken to assimilate and review all available seismic design





NMP-1
SEISMIC UPGRADE PROGRAM
FIGURE 3-1

卷之四

四

卷之四

四

四

records, including design calculations, analyses, procurement specifications, design specifications and pertinent letters and memoranda. Original design records were obtained from the NSSS (General Electric), the principal seismic consultant (J. A. Blume) and from Niagara Mohawk's design record data base system (Niagara Mohawk acted as its own A-E for NMP-1).

The results of this review are summarized in MPR Report No. 858, "NMP-1 Summary of Seismic Design Information". This report identified certain weaknesses in early records and also provided a basis for the seismic walk-through of the plant.

Seismic Walk-Through

A team of experienced seismic engineers, senior Niagara Mohawk design engineers and plant personnel was selected. This team included senior representatives from J. D. Stevenson and Associates, URS/J. A. Blume and Associates, and MPR Associates in addition to Niagara Mohawk personnel. The seismic walk-through was performed, after review of the compilation of original seismic design data, in November, 1982.

The scope of the walk-through included the following:

- Seismic Category 1 structures
- Safe-shutdown systems and equipment
- Safety systems and equipment
- Containment systems

The results of the walk-through inspections identified a number of areas for detailed evaluation. These areas include:

- Anchorage of cabinets, tanks, and heat exchangers
- Certain piping and support systems
- Support of selected pumps and valves

10

11

12

13

14

15

16

17

18

19

20

21

22

23

Diesel generator supports, inlet air and exhaust ducts
Certain block walls
Ventilation stack
Gap between reactor and turbine buildings
Cable trays and duct work
Control room ceiling

Completed evaluations of the above areas are discussed in subsequent sections of this report.

Review of Piping Analyses

Based on the preliminary record reviews and the seismic walk-through, a comprehensive evaluation of all available piping system analyses was performed. This evaluation included approximately 25 piping system analyses performed over the period from 1969 through 1981. The results of the evaluation identified the need for re-analysis of selected parts of fifteen piping systems, including those systems selected as needing review based on the seismic walk-through.

Review of Structural Analyses

Review of selected structural analyses was performed. In particular, it was noted that Niagara Mohawk's General Purpose Seismic Analysis Program (developed in the 1960s) was used in the design of a number of Class 1 structures, including the ventilation stack. Since the ventilation stack was also identified for detailed evaluation in the site walk-through, the ventilation stack was selected as a representative structure for re-analysis.

Re-analysis of the ventilation stack was performed using the computer program FESAP. In order to verify the results of the Niagara Mohawk General Purpose Seismic Analysis Program, identical inputs to those of the original NMPC analyses were used. The results of the re-analyses

[illegible]

confirm that the original Niagara Mohawk analysis method is conservative; the original method over-estimates seismic moments, but accurately calculates the natural frequencies of the structure.

Original structural analyses performed by other methods (most notably hand calculations) will be verified by re-evaluation of Class 1 and 2 structures as part of the SUP.

Anchorage of Mechanical Equipment

Anchorage and supports for mechanical equipment identified in the seismic walk-through as most vulnerable to seismic loads were re-evaluated. These re-analyses were based on the plant licensing basis Safe Shutdown Earthquake (SSE) and available preliminary floor response spectra for NMP-1. The floor response spectra used for this analysis were generated by URS/J. A. Blume for NMP-1 in 1982. Supports were re-evaluated for the following components:

- Emergency condenser makeup tank
- Emergency condenser
- Condensate storage and surge tanks
- 275 gallon fuel oil tank
- Reactor building closed loop cooling heat exchanger (HX)
- Containment spray HX
- Shutdown cooling HX
- Service water pump
- Emergency service water pump
- Containment spray (raw water) pump
- Core spray pump motor
- Containment spray pump motor
- Emergency diesel generator and inlet ducts

卷之四 雜著 四庫全書

The results of these analyses are presented in Table 1. All results were acceptable. These analyses will be re-validated or revised, as necessary, upon completion of the final seismic floor response spectra (FRS) for NMP-1 as described in this report. Evaluation of other potentially active mechanical and electrical equipment anchorages required for safe shutdown will also be performed as part of the resolution of Unresolved Safety Issue (USI) A-46.

RE-DEFINITION OF SEISMIC DESIGN INPUT

The review of the original NMP-1 design bases indicated that structural design loads due to external phenomena (including earthquake) were generally not established using criteria such as are specified for newer nuclear plants. Accordingly, projects were initiated as part of the ISAP to define appropriate design loads for re-evaluation of NMP-1 structures. The projects were directed toward development of site-specific seismic response spectra, and definition of other structural loads. The latter project is not a part of SUP, but is described here for completeness.

Site-Specific Seismic Uniform Hazard Study

The NMP-1 licensing basis SSE is a site-specific ground response spectra anchored at a peak ground acceleration (PGA) of 0.11g. A 1982 seismological study performed by Geoscience Services confirms the acceptability of this PGA for the very stable seismic zone in which NMP-1 is located. However, because of the acceptance of probabilistically-based site-specific design spectra in the SEP and the use of the uniform hazard methodology in the extensive Eastern U.S. Seismicity Study currently being undertaken by the USNRC (through Lawrence Livermore Lab) and the industry (through EPRI), a site-specific, uniform hazard study has been performed for the NMP-1 site. The principal investigators in the study were Dr. Robin McGuire (Dames and Moore) and Dr. C. Allin Cornell (Stanford University). Both are acknowledged experts in this field who also have primary responsibility for the development of the uniform hazard method in the on-going Eastern Seismicity Study being performed by EPRI. Analysis support was provided by Yankee Atomic Power Company.



611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
848
849
850
851
852
853
854
855
856
857
858
859
860
861
862
863
864
865
866
867
868
869
870
871
872
873
874
875
876
877
878
879
880
881
882
883
884
885
886
887
888
889
890
891
892
893
894
895
896
897
898
899
900
901
902
903
904
905
906
907
908
909
910
911
912
913
914
915
916
917
918
919
920
921
922
923
924
925
926
927
928
929
930
931
932
933
934
935
936
937
938
939
940
941
942
943
944
945
946
947
948
949
950
951
952
953
954
955
956
957
958
959
960
961
962
963
964
965
966
967
968
969
970
971
972
973
974
975
976
977
978
979
980
981
982
983
984
985
986
987
988
989
990
991
992
993
994
995
996
997
998
999
1000

TABLE 3-1

SUMMARY OF SUPPORT EVALUATIONS

Equipment	Evaluations	Results
1. Emergency Condenser Makeup Water Storage Tank	<ul style="list-style-type: none"> • Tension and shear in saddle bolts • Tension and shear in brace anchor bolts • Tension and compression in brace 	<p>Acceptable</p> <p>Acceptable</p> <p>Acceptable</p>
2. Condensate Storage and Surge Tank	<ul style="list-style-type: none"> • Tension, shear, and pullout of anchor bolts • Bending of anchor bolts 	<p>Acceptable</p> <p>Acceptable</p>
3. 275 Gallon Above Ground Fuel Oil Tank	<ul style="list-style-type: none"> • Tension and shear in tank to angle frame pipes • Tension, shear, and pullout of anchor bolts • Tension/compression in angle frame members 	<p>Acceptable</p> <p>Acceptable</p> <p>Acceptable</p>
4. Closed Loop Cooling Water Heat Exchanger	<ul style="list-style-type: none"> • Tension, shear, and pullout of anchor bolts 	Acceptable
5. Containment Spray Heat Exchanger	<ul style="list-style-type: none"> • Tension, shear, and pullout of anchor bolts 	Acceptable



TABLE 3-1 (Cont'd)

SUMMARY OF SUPPORT EVALUATIONS

Equipment	Evaluations	Results
6. Shutdown Cooling Heat Exchanger	<ul style="list-style-type: none"> ◦ Tension, shear, and pullout of anchor bolts 	Acceptable
7. Emergency Condenser	<ul style="list-style-type: none"> ◦ Tension, shear, and pullout of anchor bolts 	Acceptable
8. Service Water Pump	<ul style="list-style-type: none"> ◦ Tension and shear in motor to motor stand bolts ◦ Tension, shear, and pullout of pump anchor bolts ◦ Bending and shear in drive shaft 	Acceptable Acceptable Acceptable
9. Emergency Service Water Pump	<ul style="list-style-type: none"> ◦ Tension, shear, and pullout of anchor bolts ◦ Bending and shear in shaft ◦ Loads on shaft bearings 	Acceptable Acceptable Acceptable
10. Containment Spray Service Water Pump	<ul style="list-style-type: none"> ◦ Tension, shear, and pullout of anchor bolts ◦ Bending and shear in shaft ◦ Loads on shaft bearings 	Acceptable Acceptable Acceptable
11. Core Spray Pump	<ul style="list-style-type: none"> ◦ Bending in motor support stand 	Acceptable



TABLE 3-1 (Cont'd)

SUMMARY OF SUPPORT EVALUATIONS

Equipment	Evaluations	Results
12. Containment Spray Pump	° Bending in motor support stand	Acceptable
13. Emergency Diesel Generator	° Tension, shear, and pullout of anchor bolts	Acceptable
14. Diesel Generator Intake and Exhaust Ducts	° Bending in intake and exhaust ducts	Acceptable

卷之四

The uniform hazard study was based on a probabilistic assessment of the frequency of exceedance of various ground acceleration, velocity and response spectrum levels at the NMP-1 site. It utilized the procedures documented by Tera Corporation (1980) in the report of work for Lawrence Livermore National Laboratory and the USNRC Probabilistic Risk Assessment Guide (American Nuclear Society, 1981). It relied on the expertise of Dames and Moore, a wide range of expert opinion summarized by Bernreuter et al (1984), other studies of eastern seismicity including those by Hadley and Devine (1974), Tera Corp. (1980) and others. Earthquake catalogs of Chiburis (1981) and the USGS were used.

Dr. Lynn R. Sykes (Lamont-Doherty Geological Laboratory) and Mr. James McWhorter (Dames and Moore) delineated seismogenic zones and their credibility and estimated their parameters.

A total of 324 seismic hazard curves for acceleration were generated in this study for: four sets of zonations, times three attenuation functions, times three activity rates, times three b-values, times three values of M_b , max. The resulting fractile hazard curves are presented in Figure 3-2. These results show that the PGA of 0.11g for the NMP-1 SSE has a mean annual probability of exceedance of less than 4×10^{-4} . A PGA of 0.13g, in combination with the uniform hazard spectra shape given in Figure 3-3, is being used for SSE loading in the seismic/structural re-analyses undertaken as part of the SUP. This PGA has a mean annual probability of exceedance of about 2×10^{-4} and is considered to be an appropriate SSE level for future seismic assessments and plant modifications. The peak vertical ground acceleration is taken to be two-thirds of the peak horizontal ground acceleration.



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100





FIGURE 3-2

ACCELERATION HAZARD: 16, 50, and 84 PERCENTILES





ACCELERATION RESPONSE SPECTRA (5% DAMPING)

新 華 書 局

經 銷

各 埠 分 店

均 有 代 售

The NMP-1 uniform hazard spectra has been used as the basis for development of synthetic time-history ground motion for subsequent structural and floor response analyses. The free-field synthetic time histories for horizontal and vertical motion were developed by URS/J.A. Blume using representative earthquake records and accepted procedures (in URS/Blume program SMSPC3).

Definition of Other Loads on Structures

Although not directly related to SUP, definition of other loads on structures due to extreme external phenomena was completed as part of evaluation of several ISAP topics. The evaluations provide loads associated with ground water, snow, ice, maximum precipitation, straight wind and tornados.

RE-EVALUATION OF CLASS 1 AND CLASS 2 STRUCTURES

Scope

The re-evaluation of Class 1 and 2 structures includes development of dynamic and static structural models and criteria to re-analyze the NMP-1 reactor and turbine buildings; specifically the following structures:

- Reactor Building
- Turbine Building and Extension
- Off-Gas Building
- Screen and Pump House
- Waste Disposal Building
- Radwaste Solidification Building (Dynamic model only)
- Administration Building
- Administration Building Extension

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

The Class 1 and 2 building re-analysis will concentrate on the primary structural elements of the building. To the extent possible, Niagara Mohawk/EPRI research work on soil-structure interaction (explosive testing of scale models of the NMP-1 reactor building) will be factored into the structural analyses.

Dynamic Master and Detailed Static Building Models

For each Class 1 building listed above, two types of models were developed: dynamic master models and detailed static models.

The dynamic master models are three-dimensional finite element models comprised of vertical and horizontal beam elements and concentrated masses. Three-dimensional models were developed to account for the torsional response induced by the nonconcurrence of the centers of mass and rigidity in the buildings. They are intended for use in analysis and evaluation of dynamic loadings such as seismic excitation. The models are suitable for response spectrum analysis, time history analysis by model superposition, direct integration time history analysis, and free vibration analysis.

The static models are highly detailed, three dimensional finite element models which reproduce the static load paths in each building.^{1/} All structural members within each building have been explicitly included in the models. These members include steel columns, trusses, floor beams and girders and the various reinforced concrete walls, columns, floor slabs and floor beams. The static models are intended for analysis of static loads and/or equivalent static loads or displacements obtained

^{1/} Note that the Radwaste Solidification Building, recently constructed, has a well documented modern design basis. Therefore, a detailed static model was not developed for this building.

2020年12月20日 星期一 晴

from the dynamic model results. Examples of the dynamic models are shown in Figures 3-4 through 3-10. Examples of portions of the static models are shown in Figures 3-11 through 3-13. The model development effort is essentially complete.


Methodology and Acceptance Criteria

In parallel with model development, work has proceeded to define acceptable analysis approaches, load combinations and updated acceptance criteria. In recognition of the fact that NMP-1 is an older operating nuclear plant that was not designed to current structural codes and regulatory guidance, the approach and criteria developed for the structural re-analysis are realistic and not overly conservative. They are based on methods and criteria approved by the USNRC as part of the Systematic Evaluation Program (SEP) and include recommendations made in NUREG/CR 0098 and NUREG 1061. The applicable Codes, Standards and Specifications forming the basis for evaluation of Class 1 and 2 structures are listed in Appendix B. The structural analysis approach, load combinations and acceptance criteria are summarized below.

Loads and Load Combinations. The loads to be considered include the following: dead loads from the weight of the structure (D), weight of installed equipment and distribution systems (L), earth pressure and groundwater buoyancy loads (B), operating loads (R), and safe shutdown earthquake loads (E). Loads are combined as shown below:



FIGURE 3-4





1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36


37

38

39

40

FIGURE 3-5



PRELIMINARY



521

522

523

524

525

526

527

528

529

530

531

532

533

534

535

536

537

538

539

540

541

542

543

544

545

546

547

548

549

550

551

552

553

554

555

556

557

558

559

560

561

562

563

564

565

566

567

568

569

570

571

572

573

574

575

576

577

578

579

580


581

582

583

584

FIGURE 3-6




TURBINE BUILDING EXTENSION

PRELIMINARY



FIGURE 3-7



PRELIMINARY

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

FIGURE 3-8

PRELIMINARY











FIGURE 3-9

PRELIMINARY



LEGEND

PLAN TYPE

-  CONCRETE SLAB
-  CONCRETE FLOOR
-  CONCRETE WALL
-  STEEL BEAM

ADMINISTRATION BUILDING
AND
EXTENSION MODEL



1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21


22

23

24

25

FIGURE 3-10




RADWASTE SOLIDIFICATION
BUILDING MODEL

PRELIMINARY



REACTOR BLDG EXTERIOR WALLS AND FLOORS



PLOT LIMITS

110

X 280

Y 478.96

600

Z 225

400

DATE

SEPTEMBER

TIME

16:58:11

POST/MODEL

SAP USER GROU

UNIVERSITY OF

SOUTHERN CALI

VIEW DIR.:

1 1 1 -

VIEWING DIST

1E20

R090

S

X





FIGURE 3-11

PRELIMINARY



REACTOR BLDG SECONDARY SHIELD WALL



PLOT LIMITS

110
X 280
Y 478.96
600
Z 225
400

DATE
SEPTEMBER
TIME
15:57:13

POST/MODEL
SAP USER GROU
UNIVERSITY OF
SOUTHERN CALI

VIEW DIR.:
1 1 -1 -
VIEWING DIST
1E20
R090 S
X




FIGURE 3-12

PRELIMINARY



SCREEN PUMP HOUSE STATIC MODEL



PLOT LIMITS

250

X 397

Y 600

— 761.25

Z 213

289

DATE

SEPTEMBER

TIME

14:25:18

POST/SAP6.

SAP USER GROUP

UNIVERSITY OF

SOUTHERN CALI

VIEW DIR.:

1 1 -1 -

VIEWING DIST

1E20

R090

S

X Z



PRELIMINARY

FIGURE 3-13



$$1.6S = 1.0D + 1.0L + 1.0B + 1.0R + 1.0E' \quad (1)$$

$$U = \frac{1.0D}{1.40} + 1.0L + 1.0B + 1.0R + 1.0E' \quad (2)$$

where: S = Normal Allowable Stress as permitted by the AISC Building Specification - Part 1.

U = Strength capacity or allowable stress as defined by or the AISC Building Specification - Part 2.

Acceptance Criteria. Criteria have been developed for material properties, soils and foundations, and allowable stresses, as summarized below:

Material Properties. Specified design minimum material properties will be used unless mean values at a 95% confidence level of "as built" properties of materials can be established.

Soils and Foundations. Minimum safety margins for foundation bearing capacity shall be as suggested by the ASCE Manual 58.

Allowable Stresses and Strengths. The stresses resulting from simultaneous application of the above loads will be compared to the normal allowable stress (factored by 1.6) as permitted by AISC Building Specification, Part 1. Alternatively, strength capacity U may be used; as permitted by Part 2 of the specification. Where buckling is the limiting load condition, buckling loads shall be limited to 2/3 of the critical buckling load.

(Faint vertical bleed-through from reverse side)

Deformations shall be limited to prevent impact on, or interference with, adjacent structures or components. Beam deflections shall be limited to 1/180 of the span length when subjected to the loadings defined herein.

Analysis Guidelines. The system or subsystem analysis used to determine loads which act on structures shall assume linear elastic behavior, except in those instances when allowable behavior limits exceed yield. Use of other than linear elastic analytic procedures considering "system ductility", as defined in NUREG-0098, is permitted when yielding within allowable limits occurs.

Structure lateral load transfer due to friction and/or passive earth pressure is assumed. Damping values for Class 1 and 2 Structures and Equipment can be found in Appendix C.

GENERATION OF FLOOR RESPONSE SPECTRA

Scope

Using the building models discussed in the previous section, amplified floor response spectra are generated at all pertinent elevations of the reactor, turbine and pump and screen house buildings. Since vertical floor flexibility is considered in the models, up to several key locations per floor are chosen as response points for the generation of vertical amplified response spectra. As shown schematically in Figure 1, these spectra will be used as bases for all final equipment and system evaluations, including those for piping, supports, equipment anchorage, cable trays, equipment qualification, etc. Preliminary spectra have been developed at nine locations in the reactor building and at one location on the reactor vessel.

对 法 律 的 研 究 与 应 用 的 研 究 是 一 个 互 相 关 联 的 问 题

Seismic anchor motions (SAM's) for piping re-analysis have also been developed using a post-processor on the time-history model results to select the absolute greatest distance between structures with respect to time. Anchor motions have thus far been calculated between floors in the reactor building, between the reactor vessel and building, and between drywell concrete and drywell steel. SAM's will be addressed further in the piping re-evaluation section of this report.

Development Using Ground Motion and Building Models

The basis for the new response spectra is the probabilistic, site dependent study implemented by Cornell and McGuire, as discussed in this report. Floor acceleration response spectra are developed from time-history response records or power spectral densities at selected points within the structures. Floor response records are obtained from dynamic analyses in the time or frequency domain using mathematical lumped mass and spring models of the structures subjected to the SSE ground motion discussed above. Next, the acceleration response within the structures is used as input for the analysis of simple oscillators, each equivalent to a single-degree-of-freedom system with natural frequencies in the range of interest (0.5 to 33 Hz) for several damping ratios.

Methodology and Acceptance Criteria. As a minimum, the 75 frequencies of USNRC Reg. Guide 1.122 shall be used as the oscillator frequencies. Additional oscillator frequencies shall be included at resonances, and at their half-power points (damping x frequency points) and full-power points (2 x damping x frequency points) in the vicinity of 10 Hz and above.

Sufficient modal participation shall be achieved so that the function $[1 - (\text{participation factors})(\text{mode shapes})]$ does not exceed 0.2 at any node point associated with floor levels. If it does, the inverse of the above function shall be multiplied by the ground spectrum and combined with the floor response spectrum by SRSS.

中華民國二十六年四月一日 行政院秘書長 呈 總統 鈞鑒

From the structural response analysis, response spectra at selected nodal points are presented for each respective translational direction; north/south, east/west and vertical. If the seismic analysis is performed separately for each of the three directions, and in the case of asymmetric structures, the ordinates of the spectrum at the location of interest for a given direction shall be obtained by combining ordinates of the three co-directional spectra according to the square-root-sum-of-the-squares (SRSS) criterion.

To account for uncertainties in the structural frequencies, the computed response spectra shall be smoothed and peaks broadened in accordance with ASME Code Case N-397. Parametric studies have been performed and have removed most of the modeling and properties uncertainties. Therefore, peaks will be broadened $\pm 10\%$ in accordance with SEP precedents.

Response spectra shall be generated at damping ratios of 2, 3, 4, 5, 7, 10 and 20 percent for analysis of equipment, etc. PVRC damping will be used for piping analysis, as described in ASME Code Case N-411. Alternatively, the uniform 3% damping may be used for simplicity.

Significant effective damping of the structural system is achieved when the secondary system (equipment or component) is near or in resonance with the primary system, the building. The effective modal damping ratio is proportional to the square root of the ratio of the secondary system modal effective mass to the primary system modal effective mass. The resulting effective modal damping ratio will be utilized on a case-by-case basis for the generation of floor response spectra for this program.

RE-EVALUATION OF SELECTED CLASS 1 AND 2 PIPING SYSTEMS

Because of the significant changes in seismic analysis and acceptance criteria for piping and pipe support systems over the past 10 to 15 years, Niagara Mohawk has initiated an extensive program to re-assess

國民日報

中華民國二十九年

五月二十二日

星期五

the seismic adequacy of some plant piping systems believed to be sensitive to seismic loads. As in the case of the structural evaluations, analytical model preparation and development of analysis methodology and acceptance criteria have proceeded in parallel.

Scope

On the basis of the piping analysis reviews and the seismic walk-through inspections, the piping re-evaluation is focused initially on 15 piping systems believed to be representative and most sensitive to seismic loads. These target systems are as follows:

<u>System No.</u>	<u>Description</u>
81	Core Spray (suction side to topping pumps)
28, 44	CRD (pump to strainer and strainer to drywell penetration)
79	Diesel generator cooling water
301	CRD insert/withdrawal piping
05	Emergency condenser steam vent
93	Containment spray raw water cooling
80	Containment spray
39	Emergency condenser (outside drywell)
53	Condensate supply to CRD pumps
54	Spent fuel cooling
60	Emergency condenser makeup
82	Diesel fuel oil handling (buried)
72	Service water
34	Reactor head spray
36	Reactor instrument lines (typical run)



1
2
3
4

5
6
7
8
9
10
11
12

13
14
15
16
17
18

The scope of the initial piping re-analysis effort is a sample of piping comprised of one analytical model representing each of the above systems, plus any model (part of one of the above systems) considered a potential seismic concern either by engineering review of drawings or by seismic walkthrough.

Buried diesel fuel oil handling piping will be re-analyzed using appropriate methods, provided it is found to be essential for safe shutdown. In addition, any small bore piping found to be rigidly routed between tanks or large bore piping experiencing significant movement will be re-evaluated for relative anchor displacements, a concern identified in power plants which have experienced large earthquakes.

It is tentatively planned to extend piping re-analysis work to encompass all safety-related, Class 1 and 2 seismic systems (so defined in the FSAR and Appendix A) as a longer term effort. The schedule for this additional work will be dependent on the results of the analyses of the "worst-case" sample described above and availability of resources.

Piping Model Development

Niagara Mohawk has invested a large effort toward developing computer-generated isometric piping models for all NMP-1 piping systems. As-built models are being developed and verified by plant walk-through to represent piping geometry, material properties, support characteristics, and other information necessary for stress analysis of piping systems. This effort is nearly complete; piping models reside in Niagara Mohawk's data base system, allowing efficient access to computer-plotted drawings and stress analysis input decks compatible with the computer code SUPERPIPE.

一、
 二、
 三、
 四、

2

$$\begin{array}{c} \mathfrak{g} \\ \mathfrak{g} \\ \vdots \\ \mathfrak{g}_i \end{array}$$

40

3.

— 24 —

Methodology and Acceptance Criteria

Seismic re-analysis of piping is being performed using the methodology and acceptance criteria summarized below:

Loads and Load Combinations. The loads to be considered include internal pressure, moment due to dead weight, and moment due to occasional loads. This re-analysis will consider Safe Shutdown Earthquake (SSE) as the only occasional load in accordance with SEP plant re-analyses. Operating Basis Earthquake (OBE) will not be evaluated. The SSE loading has two components, seismic inertia and seismic anchor motions (SAM's).

Piping systems requiring Class 1 seismic analyses will be handled on a case basis. (None are included in the present scope of piping analysis.) For Class 2 and Class 3 piping, ASME Equation (9) (NC/ND - 3652.2) will be evaluated:

$$S_{OL} = \frac{P_{\max} D_o}{4 t_n} + .75 i \left(\frac{M_A + M_B}{Z} \right) \leq 2.4 S_H$$

where S_{OL} = stress due to occasional loading, psi.

i = stress intensification factor (NC/ND - 3673.2(b)).
The product of 0.75 i shall never be taken as less than 1.0.

P_{\max} = peak pressure, psig.

D_o = pipe outside diameter, in.

t_n = nominal wall thickness, in.

一

二

三

四

M_A = resultant moment loading (including torsion) due to weight, in-lb.

M_B = resultant moment loading (including torsion) due to SSE, using one-half the range, in-lb. Effects of anchor displacement due to earthquake may be evaluated in ASME Eq. (10) or (11) if not included in Eq. (9) above. If included in Eq. (9), they will be combined with inertial stresses using SRSS summation.

Z = elastic modulus of pipe, in³.

S_h = basic material allowable stress at Design Temperature, psi.

Acceptance Criteria. The Class 2 and 3 rules of the 1980 version of the ASME Code, Section III, Division 1, Subsections NC and ND will be used, except as indicated in this report. The load combination described above will be compared to S_h , the basic material allowable stress at design temperature, multiplied by a factor of 2.4 for Service Level D. If Level D cannot be met, then an alternative pseudo-plastic method (an augmented Class 2/3 analysis method accounting for the cyclic nature of seismic loading) or time-history method may be used.

Analysis Guidelines. SUPERPIPE, a computer code for structural analysis and Code compliance checking of piping systems, is employed to apply the loads and criteria above to the as-built computer models of essential piping. SUPERPIPE will automatically combine loads using Eq. (9), and evaluate stresses in comparison to specified criteria. Some specific analysis guidelines are discussed below.

本館新編

卷之四

新編

The response due to seismic inertial loads is determined using the appropriate floor response spectra for vertical and two horizontal directions, combined by SRSS. For piping supported on multiple elevations, either of the following methods will be used: (1) envelope applicable floor response spectra or (2) apply individual support (or group of supports) spectra independently, as recommended in NUREG/CR-3811. If independent support spectra are used, the responses for each support or group will be combined by absolute summation, or, if it can be shown the supports are uncoupled, by SRSS.

The modal responses shall be combined using SRSS for modes not closely spaced, and using either the grouping method or double sum method for closely spaced modes, as described in Reg. Guide 1.92.

Piping analysis will consider only modes below 33 Hz. In some cases, modes of vibration above 33 Hz may involve significant support reactions. For example, if a node is restrained by a "rigid" anchor, then there will be no excitation of the lumped mass at that node in any of the modes considered, because the frequency of vibration will be very high there. The resulting calculated anchor reactions may be substantially lessened by neglecting this mass contribution. Therefore, a procedure is employed whereby these "missing masses" are accounted for in an additional calculated mode incorporating these masses.

Stresses due to seismic anchor motion (SAM) will be determined using displacement from seismic building analysis, only if the piping analyzed has supports attached to independently responding structures, for example the reactor and turbine buildings. Unless it can be shown that independent supports move in phase, displacements will be assumed out of phase such that the maximum possible stress is obtained. Resulting SAM loads will be combined with inertial loads by SRSS.



許 慎 著
說 文 解 字 詁林
卷 之 一
一 說 文 解 字 詁林

RE-EVALUATION OF PIPING SUPPORTS

Scope

Piping supports will be evaluated for the piping systems analyzed. Adequacy of piping supports has been considered during the seismic walk-through in the identification of seismically sensitive piping systems.

Methodology and Acceptance Criteria

Piping supports will be analyzed in accordance with ASME Subsection NF-3300, and Service Level D limits. Loads will be determined from the output of piping analyses, which consider SSE loadings, as discussed above. Piping support anchorage, including base plates and anchor bolts, is analyzed in accordance with IE Bulletin No. 79-02.

SEISMIC QUALIFICATION OF EQUIPMENT

The seismic adequacy of equipment is being pursued by the Seismic Qualification Utilities Group (SQUG). As a member of SQUG, Niagara Mohawk is a participant in the cooperative SQUG/NRC program to resolve Unresolved Safety Issue USI A-46, "Seismic Qualification of Equipment in Operating Nuclear Plants." NMP-1 will be the pilot plant for the SQUG BWR walkdown program. This effort is directed toward qualifying equipment on the basis of seismic experience data, and is expected to provide (1) bases for demonstrating the seismic adequacy of mechanical and electrical safe shutdown equipment and (2) guidelines for the evaluation of equipment and cabinet anchorage, cable and conduit raceways and essential relays. These areas are being pursued separately from the SUP until such time that the results can be factored into the SUP.



1. 2. 3. 4. 5.

6. 7. 8.

9. 10.

11.

12. 13. 14. 15.

16.



17.
18.



PROGRAM ADMINISTRATION

Program Management and Participants

Mr. Francis Feng and Dr. Robert Oleck, of Niagara Mohawk, are overseeing the administration of SUP schedule, budget, and coordination of participants. They will also have final review responsibility for all SUP tasks.

The SUP team is composed of engineers from Niagara Mohawk and its contractors, including Stevenson & Associates and MPR Associates. These organizations have a large amount of collective experience in seismic qualification, dynamic modelling and analysis of structures, equipment and piping.

Schedule

The NMP-1 SUP was initiated in 1985 and is expected to be completed in three to four years from this writing dependent upon resources. A preliminary schedule illustrating short term and long term milestones is presented in Figure 3-14.

Quality Assurance

The SUP is being performed in accordance with Niagara Mohawk's quality assurance requirements. Drawings are created, updated and verified by walk-down to represent the as-built condition of piping, supports and structures. The computer codes used for seismic evaluation, principally COSMOS and SUPERPIPE, are or will be verified, accepted and controlled versions. All calculations, walk-throughs and other supporting data will be checked, reviewed, documented and logged in NMPC's controlled system.

Data Base Requirements

NMPC maintains two data bases for document control: a records data base and an analytical model data base. The records data base maintains control over the design records used as reference in this study. The analytical data base stores all models and analysis results of the Niagara Mohawk system for quick reference and revision control.



10
11
12
13
14

15
16

17
18

19
20

Milestone Schedule

Short Term:

- SUP Program Plan Development
- SUP Program Plan Review by NMPC
- Present Program Description to NRC
- Receive NRC comments on Program
- Finalization of Criteria:
 - Ground Motion (SSE)
 - Structural
 - Floor Spectra
 - Piping
 - Supports
- Obtain NRC Approval of Proposed Methodology and Governing Criteria

Long Term:

- Re-evaluation of Ground Motion Spectra
- Re-evaluation of Class 1 Structures
- Generation of New Floor Response Spectra
- Re-evaluation of Piping & Supports
- Seismic Qualification of Equipment
- Pilot Plant Review
- Prepare SER & Present to NRC
- Finalize SER after NRC comments

Figure 3-14



11/10/10

APPENDIX A

SEISMIC CLASSIFICATION OF NMP-1 STRUCTURES,
SYSTEMS AND EQUIPMENT



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

D. DESIGN OF STRUCTURES, COMPONENTS, EQUIPMENT, AND SYSTEMS

1.0 Classification and Seismic Criteria

Class I Structures and Components--Structures and components whose failure could cause significant release of radioactivity or which are vital to safe shutdown and isolation of the reactor.

Class II Structures and Components--Structures and components which are important to reactor operation but are not essential to safe shutdown or isolation, and whose failure could not result in substantial release of radioactive materials.

Class III Structures and Components--Structures and components that are not essential for safe shutdown and isolation of the reactor and whose failure will not result in significant release of radioactive materials.

No quantitative basis was used to determine the limit for significant release of radioactivity. The basis used was that if a system could fail such that the failure could result in a continuous, uncontrolled release of radioactivity that could not be readily terminated, the system was designated as Class I.

Thus, since release from a broken main steam line can be terminated by closing the automatic isolation valves, the parts of the system outside the isolation valves are not Class I. Similarly, rupture of a tank in the waste disposal building could result in a release not easily controlled or terminated. Therefore, these systems are Class I.

The decisions as to whether the balance of systems, components, and structures qualified for treatment as Class II or Class III were ultimately based on the best professional engineering judgment of those involved in specifying the design criteria. The prime consideration in deciding on Class II or Class III was whether or not the given system, component, or structure is necessary to continued Station operation. Where doubt existed as to which criterion should be applied, generally the resolution was made in the conservative direction, namely, to apply the Class II criterion.



1. The first part of the document is a list of names and dates, which appears to be a roster or a list of events. The names are written in a cursive script, and the dates are in a more formal, printed style. The list is organized into two columns, with names on the left and dates on the right. The names are: John Doe, Jane Smith, and Robert Brown. The dates are: 1890, 1891, and 1892.

2. The second part of the document is a list of names and dates, which appears to be a roster or a list of events. The names are written in a cursive script, and the dates are in a more formal, printed style. The list is organized into two columns, with names on the left and dates on the right. The names are: John Doe, Jane Smith, and Robert Brown. The dates are: 1890, 1891, and 1892.

1890

A list of Class I and Class II structures and systems is provided below:

Class I Structures

- Reactor building
- Waste disposal building
- Ventilation stack
- Drywell
- Reactor pressure vessel and its support structure
- Suppression chamber
- Diesel-generator support foundation

Class II Structures

- Turbine building
- Turbine-generator support foundation
- Intake and discharge tunnels

Combination Class I and Class II Structure

- Screen and pump house

Class I Equipment, Systems, or Areas in Class II Structures

- Diesel-generator support structure
- Control room
- Auxiliary control room
- Battery room
- Battery board room
- Supporting steel structure for emergency condenser, makeup, and demineralized water tanks

Class I Piping Systems

- Main steam inside drywell
- Core spray
- Containment atmospheric dilution
- Containment atmospheric monitoring
- Containment spray
- Containment spray cooling water
- Emergency cooling
- Liquid poison
- Drywell and suppression chamber vacuum relief
- Fuel pool cooling and filtering
- Reactor cleanup
- Reactor shutdown cooling
- Reactor head spray
- Condensate storage
- Condensate pump suction and discharge

10

22


 6 to



● ● ● ● ●

4

17

2

1

1

١٠٠
 ١٠١
 ١٠٢

Class I Piping Systems (Cont'd)

Feedwater booster discharge
 High pressure reactor feedwater
 Reactor building closed loop cooling
 Control rod drive piping
 Radioactive waste disposal system
 Emergency ventilation
 Breathing air
 Instrument air
 Service water
 Diesel-generator fuel oil, starting air, and
 cooling water

Class II Piping Systems

Main steam outside drywell
 Bypass steam to condenser
 Steam supply to air ejector
 Extraction steam piping
 Makeup demineralizer
 Turbine building closed loop cooling
 Reactor and turbine buildings, sump pump
 discharge
 Seal water
 Turbine oil storage
 City water
 Laboratory drains
 Off-gas

Class I Equipment Housed in and Supported by
Combination Class I and II Structures

Emergency service water pumps and piping
 Containment spray cooling pumps and piping
 Diesel-generator cooling water pumps and piping
 Service water pumps and piping

Class I Equipment Housed in and Supported by Class II
Structures

Condensate storage tanks and piping
 Condensate pumps, suction and discharge piping
 Feedwater booster pumps and discharge piping
 High pressure reactor feed pumps and discharge
 piping
 Diesel-generator fuel oil, starting air and
 cooling water piping
 Emergency condenser storage tanks
 Reactor building closed loop cooling piping
 (partial)
 Breathing air piping (partial)
 Instrument air compressors

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

Class I Equipment Housed in and Supported by Class II Structures (Cont'd)

Instrument air piping (partial)
Service water piping (partial)

1.1 Design Techniques

1.1.1 Structures

The design basis load combinations of dead load, live load (including piping, equipment, and temperature), moving loads, and incident loads are directly combined with horizontal and vertical earthquake loads for structures consisting in whole or in part of Class I elements. The resulting stress levels are within normal Code values with no increase allowed for the earthquake condition for Class I structures or components except for:


- a. Suppression chamber columns, and
- b. Ventilation stack,

for which a one-third increase was allowed. Although original criteria allowed a one-third increase in stress levels for Class II structures when earthquake loading was included, calculated stresses remained within the normal stress range with no increase for earthquake.

Tables XVI-20 through XVI-26 present the load combinations and allowable stresses for structures consisting in whole or in part of Class I elements.

Figures XVI-34 through XVI-41 present the computed deflections from the design earthquake excitation.

For concrete design criteria such as bar spacing, bar cover, minimum reinforcement, temperature steel, etc., ACI Code 318-63 was used. For proportioning of concrete members, Part IV-A, "Working Stress Design," of Code



2.

APPENDIX B

APPLICABLE CODES, STANDARDS AND SPECIFICATIONS



2

12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
84

一、
 二、
 三、
 四、
 五、
 六、



2008 -



APPENDIX B

Applicable Codes, Standards and Specifications

As a general practice the Codes, Standards and Specifications listed herein shall be periodically reviewed and updated as appropriate by NMPC Engineering Department.

The following codes, standards, specifications, and recommendations are the basis for the evaluation of Category I structures.

- o American Concrete Institute (ACI)
 - ACI-318-77 Building Code
 - Supplemented
by ACI 349-80 "Code Requirements for Nuclear Safety Related
Concrete Structures - Appendix B Steel Embedments"
- o American Institute of Steel Construction (AISC)
 - "Specifications for the Design, Fabrication, and Erection of
Structural Steel for Buildings," effective November 1, 1978.
 - Supplemented by ductility and thermal load behavior criteria
contained in ANSI/AISC N690 - "1984 Nuclear Facilities - Steel
Safety-Related Structures for Design Fabrication and Erection".
- o American Society for Testing Materials.
 - 1982 ASTM Standards.
- o American Welding Society (AWS)
 - "Structural Welding Code," AWS D1.1-82
- o U.S. Nuclear Regulatory Commission
 - 1. NUREG/CR-0098 "Development of Criteria for Seismic Review of
Selected Nuclear Power Plants," May 1978
 - 2. NUREG/CR 1161, "Recommended Revisions to Nuclear Regulatory
Commission Seismic Design Criteria," May 1980
 - 3. NUREG 1061, "Evaluation of Seismic Designs - A review of
Seismic Design Requirements for Nuclear Power Plant Piping,"
April 1985

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

4. NUREG 0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants, LWR Edition," July 1981.

0 International Atomic Energy Agency

DOE 2882n, "A Seismic Design of Nuclear Facilities with Limited Radioactive Inventory," October 1984

0 American Society of Civil Engineers

1. Manual of Professional Practice No. 58, "Structural Analysis and Design of Nuclear Plant Facilities" August 1980.
2. ANSI A58.1 "Building Code Requirements for Minimum Design Loads in Building and Other Structures," 1982.



22

APPENDIX C

DAMPING VALUES FOR STRUCTURES AND EQUIPMENT



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

APPENDIX C
DAMPING VALUES FOR STRUCTURES AND EQUIPMENT
(Percent of Critical Damping)

<u>Structure or Component</u>	<u>Safe Shutdown Earthquake</u>
Equipment	3
Welded steel structures	4
Bolted steel structures	7
Prestressed concrete structures	5
Reinforced concrete structures	7
Electrical Raceways - Empty	7
Electrical Raceways - Full	20
Sloshing Mode in Tanks	0.5
Impulse Mode in Tanks	4



11

Enclosure 3

NINE MILE POINT UNIT NO. 1 (NMP-1)
SEISMIC UPGRADE PROGRAM

JUNE, 1987

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

NMP-1 SEISMIC UPGRADE PROGRAM (SUP)
OUTLINE OF DISCUSSION

o INTRODUCTION

- PURPOSE
- BACKGROUND
- OBJECTIVES
- SCOPE
- TIMING

o APPROACH

o MAIN ELEMENTS OF SUP

- RE-EVALUATION OF ORIGINAL SEISMIC DESIGN BASES
- RE-DEFINITION OF SEISMIC DESIGN INPUT
- RE-EVALUATION OF CLASS 1 AND 2 STRUCTURES
- GENERATION OF FLOOR RESPONSE SPECTRA
- RE-EVALUATION OF PIPING SYSTEMS & SUPPORTS
- SEISMIC QUALIFICATION OF EQUIPMENT
- PROGRAM ADMINISTRATION



INTRODUCTION TO THE SUP

0 PURPOSE

- DEVELOP MODERN DEFINITION OF SEISMIC ADEQUACY OF NMP-1 AND PROVIDE NEW METHODS AND ACCEPTANCE CRITERIA FOR FUTURE ANALYSES/MODIFICATIONS

0 BACKGROUND

- FOLLOW-ON ACTIVITY FROM SEP/ISAP
- INCORPORATES EXTENSIVE CHANGES IN SEISMIC DESIGN METHODOLOGY AND CRITERIA, TO BECOME NEW LICENSING BASIS
- BUILDS ON SEP/ISAP WORK AND ADDRESSES:
 - DESIGN GROUND MOTION RESPONSE SPECTRA
 - CATEGORY 1 AND 2 STRUCTURES, PIPING AND SUPPORTS
 - SAFE SHUTDOWN EQUIPMENT



INTRODUCTION TO THE SUP (CONT'D)

o OBJECTIVES

- PROVIDE STATE-OF-THE-ART CRITERIA AND METHODOLOGY FOR FUTURE PLANT MODIFICATIONS
- RE-ASSESS ADEQUACY OF NMP-1 SEISMIC DESIGN BASED ON UP-TO-DATE METHODS AND CRITERIA
- DEMONSTRATE AND DOCUMENT SEISMIC ADEQUACY OF NMP-1 COMPARED TO MODERN PLANTS
- PROVIDE COMPREHENSIVE DATA BASE FOR STRUCTURES AND PIPING
- PREPARE FOR FUTURE USNRC SEISMIC PROGRAMS



INTRODUCTION TO THE SUP (CONT'D)

0 SCOPE

- 0 ALL SEISMIC CLASS 1 AND 2 STRUCTURES, PIPING AND SUPPORTS AS DEFINED IN NMP-1 FSAR
- 0 OTHER ACTIVE MECHANICAL/ELECTRICAL EQUIPMENT, HX, TANKS, CABLE TRAY/CONDUIT SYSTEMS IN ACCORDANCE WITH USI A-46

0 TIMING

- 0 NMPC WILL UNDERTAKE SUP AS A VOLUNTARY EFFORT OVER NEXT SEVERAL YEARS
- 0 SHORT-TERM OBJECTIVE TO OBTAIN NRC APPROVAL OF NEW SEISMIC CRITERIA FOR USE IN 1988 NMP-1 OUTAGE, USI A-46 AND SEISMIC EVALUATIONS



APPROACH

- o DEVELOP REALISTIC, SELF-CONSISTENT CRITERIA, METHODS AND LOAD DEFINITIONS TO BECOME PLANT LICENSING BASIS
- o RE-ASSESS SEISMIC DESIGN USING NEW METHODS AND CRITERIA
 - REVIEW AND UP-DATE, IF NECESSARY, COMPLETED SEP/ISAP WORK USING NEW METHODS AND CRITERIA
 - EXPAND SCOPE OF SEISMIC RE-EVALUATION TO COVER STRUCTURES, SYSTEMS AND EQUIPMENT IN SUP SCOPE

1

2

3

4

5

6

7

8

9

10

11

12



0 TASKS COMPLETED AS PART OF SEP AND ISAP:

- RE-EVALUATION OF ORIGINAL SEISMIC DESIGN BASES
- DESIGN RECORD REVIEW
- DEVELOPMENT OF UNIFORM HAZARD GROUND MOTION SPECTRA
- REVIEW OF PIPING ANALYSES OF RECORD
- REVIEW OF STRUCTURAL ANALYSES
- EVALUATION OF EQUIPMENT ANCHORAGE
- RE-DEFINITION OF LOADS ON PLANT STRUCTURES
- MODELING OF BUILDING STRUCTURES
- GENERATION OF PRELIMINARY FLOOR RESPONSE SPECTRA
- RE-ANALYSIS OF SELECTED PIPING SYSTEMS

234



三

0 SPECIFIC SUP TASKS:

- DEVELOPMENT OF UP-TO-DATE METHODOLOGY AND ACCEPTANCE CRITERIA
- RE-EVALUATION AND RE-DEFINITION, AS NEEDED, OF SEISMIC GROUND MOTION SPECTRA AND OTHER STRUCTURAL LOADS PREVIOUSLY DEFINED
- RE-EVALUATION OF CLASS 1 AND 2 STRUCTURES USING NEW METHODS
- GENERATION OF NEW FLOOR RESPONSE SPECTRA
- RE-EVALUATION OF SELECTED PIPING SYSTEMS AND SUPPORTS
- SEISMIC QUALIFICATION OF EQUIPMENT

7

三

[illegible]

2.

五

22

22

4
5
6
7

11


4

MAIN ELEMENTS OF SUP

- 0 RE-EVALUATION OF ORIGINAL SEISMIC DESIGN BASES, COMPLETED AS PART OF ISAP:
 - DESIGN RECORD REVIEW
 - PLANT SEISMIC WALK-THROUGH
 - REVIEW OF PIPING ANALYSES OF RECORD
 - REVIEW OF STRUCTURAL ANALYSES
 - EVALUATION OF EQUIPMENT ANCHORAGE

- 0 RE-DEFINITION OF SEISMIC DESIGN INPUT, COMPLETED AS PART OF ISAP
 - SITE-SPECIFIC SEISMIC UNIFORM HAZARD STUDY
 - BASED ON PROBABILISTIC ASSESSMENT OF FREQUENCY OF EXCEEDANCE
 - RELIED ON EXPERT OPINION SUMMARIZED BY BERNREUTER, AND EXPERTISE OF SYKES, McWHORTER, HADLEY & DEVINE, TERA CORP. AND OTHERS
 - PGA OF .13 COMBINED WITH UNIFORM HAZARD SPECTRA SHAPE
 - MEAN PROBABILITY OF EXCEEDANCE OF 2×10^{-4}
 - RE-DEFINITION OF OTHER STRUCTURAL LOADS DEFINED AS PART OF SEP






NMP-1
SEISMIC UPGRADE PROGRAM

1. The first part of the document is a list of names and addresses of the members of the committee.


2. The second part of the document is a list of names and addresses of the members of the committee.

3. The third part of the document is a list of names and addresses of the members of the committee.



ACCELERATION HAZARD: 16, 50, and 84 PERCENTILES





ACCELERATION RESPONSE SPECTRA (5% DAMPING)



1

2

3

4

5

6

7

8

MAIN ELEMENTS OF SUP (CONT'D)

0 RE-EVALUATION OF CLASS 1 AND CLASS 2 STRUCTURES

- SCOPE: PRIMARY STRUCTURAL ELEMENTS OF REACTOR, TURBINE AND SCREEN HOUSE BUILDINGS
- DYNAMIC MASTER AND DETAILED STATIC BUILDING MODELS DEVELOPED
- METHODOLOGY AND ACCEPTANCE CRITERIA
 - LOADS AND LOAD COMBINATIONS
 - ACCEPTANCE CRITERIA
 - ANALYSIS GUIDELINES

0 GENERATION OF FLOOR RESPONSE SPECTRA

- SCOPE: KEY LOCATIONS ON ALL PERTINENT ELEVATIONS OF REACTOR, TURBINE, AND SCREEN HOUSE BUILDINGS
- DEVELOPMENT USING GROUND MOTION AND BUILDING MODELS
- METHODOLOGY AND ACCEPTANCE CRITERIA



1944

20

21

22

23

24

25

26

27

28

29

30

31

32

33


34

35

36

37

38



- REACTOR PRESSURE VESSEL SYSTEM
(PEDESTAL, RPV, SHIELDED WALLS)
- DRYWELL
- INTERIOR WALLS
- EXTERIOR WALLS & COLUMNS
- - - - BEAMS



148





2

1

1

1

10/24/00 10:40 AM

1

1

1

1

1

2

1

1

1


LEGEND

..... CONCRETE COLUMN & WALLS

— STEEL BEAM

 CONCRETE SLAB

 ELEMENT NUMBER




TURBINE BUILDING EXTENSION

PRELIMINARY



SCREEN AND PUMP
HOUSE MODEL


-----	SCREEN, PUMP, GROUND
-----	SCREEN, PUMP, GROUND
	SCREEN, PUMP, GROUND
	SCREEN, PUMP, GROUND
	SCREEN, PUMP, GROUND



PRELIMINARY




PRELIMINARY



WASTE DISPOSAL BUILDING AND EXTENSION
AND
OFF GAS BUILDING MODELS







PRELIMINARY



LEGEND

PLAN VIEW

-  CONCRETE SLAB
-  CONCRETE FLOORING
-  CONCRETE BEAM
-  STEEL BEAM

ADMINISTRATION BUILDING
AND
EXTENSION MODEL

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46




47


48

LEGEND:

— LATEST WALL
+ COLLARS
--- LATERAL TIE BEAM
--- RAFTER WALL

FLOOR TYPES:

 GROUTED SLAB
 CONCRETE FLOORING
 CARPET



RADWASTE SOLIDIFICATION
BUILDING MODEL

PRELIMINARY

200


200

200

200

200

REACTOR BLDG EXTERIOR WALLS AND FLOORS



PLOT LIMITS

110

X 280

Y 478.96

600

Z 225

400

DATE

SEPTEMBER

TIME

16:58:11

POST/MODEL

SAP USER GROU

UNIVERSITY OF

SOUTHERN CALI

VIEW DIR.:

1 1 1 -


VIEWING DIST

1E20

R090

S

X



PRELIMINARY



100

100


100

100

100

100

REACTOR BLDG SECONDARY SHIELD WALL



PLOT LIMITS

110
X 280
Y 478.96
600
Z 225
400

DATE
SEPTEMBER
TIME
15:57:13

POST/MODEL
SAP USER GROU
UNIVERSITY OF
SOUTHERN CALI


VIEW DIR.:
1 1 -1 -
VIEWING DIST
1E20
R090 S
X



PRELIMINARY



SCREEN PUMP HOUSE STATIC MODEL



PLOT LIMITS

250

X 397

Y 600

761.25

Z 213

289

DATE

SEPTEMBER

TIME

14:25:18

POST/SAP6.

SAP USER GROU

UNIVERSITY OF

SOUTHERN CALI

VIEW DIR.:

1 1 -1 -

VIEWS DIST

1E20

R090

S

X Z

Y
X

PRELIMINARY



1

2

3

4

5

6

7

8

9

10

11

12

13

14

RE-EVALUATION OF CLASS 1 AND 2 STRUCTURES LOADS AND ACCEPTANCE CRITERIA

° LOADS CONSIDERED:

- DEAD LOADS (D) - OPERATING LOADS (R)
- LIVE LOADS & PRESSURE (L) - SSE LOADS (E')
- EARTH PRESSURE & BOUYANCY (B)

0 LOAD COMBINATIONS AND ALLOWABLES:

$$1.6S = D + L + B + R + E' \quad (1)$$

$$U = D + L + B + R + E \quad (2)$$

S. = NORMAL ALLOWABLE FROM AISC PART 1

U = STRENGTH CAPACITY FROM AISC PART 2 OR ACI 349

0 OTHER ACCEPTANCE CRITERIA:

- SPECIFIED DESIGN MIN MAT'L PROPERTIES
- MIN SAFETY MARGINS FOR BEARING CAPACITY - ASCE 58
- DEFORMATIONS LIMITED TO PREVENT IMPACT
- BEAM DEFLECTIONS $< 1/180$ SPAN LENGTH

10-1-73

10-1-73

10-1-73

10-1-73

10-1-73

FLOOR RESPONSE SPECTRA GENERATION
METHODS AND ACCEPTANCE CRITERIA

- o AS A MINIMUM, 75 OSCILLATOR FREQUENCIES FROM USNRC REG. GUIDE 1.122 SHALL BE USED
- o THREE DIRECTIONS OF SPECTRA COMBINED USING SRSS
- o PEAK BROADENING ACCORDING TO CODE CASE N-397, BUT ONLY $\pm 10\%$
- o PVRC DAMPING ACCORDING TO CODE CASE N-411 FOR PIPING ANALYSIS; DAMPING RATIOS OF 2, 3, 4, 5, 7, 10 AND 20 PERCENT FOR EQUIPMENT, ETC.
- o EFFECTIVE MODAL DAMPING RATIO TO BE USED ON CASE-BY-CASE BASIS

[illegible]

474

MAIN ELEMENTS OF SUP (CONT'D)

- o RE-EVALUATION OF SELECTED PIPING SYSTEMS
 - SCOPE: INITIALLY 15 TARGET SYSTEMS,
EVENTUALLY ALL FSAR SEISMIC CLASS 1
AND 2 SYSTEMS
 - PIPING MODEL DEVELOPMENT
 - METHODOLOGY AND ACCEPTANCE CRITERIA
 - LOADS AND LOAD COMBINATIONS
 - ACCEPTANCE CRITERIA
 - ANALYSIS GUIDELINES
- o RE-EVALUATION OF PIPING SUPPORTS
 - SCOPE: SUPPORTS FOR TARGET PIPING SYSTEMS
 - METHODOLOGY AND ACCEPTANCE CRITERIA
- o SEISMIC QUALIFICATION OF EQUIPMENT
 - BEING PURSUED BY SQUG, NMPC IS A MEMBER
 - NMP-1 IS BWR PILOT PLANT FOR SQUG PROGRAM
 - PROVIDES
 - BASIS FOR SEISMIC ADEQUACY OF MECHANICAL
AND ELECTRICAL SAFE SHUTDOWN EQUIPMENT



PIPING RE-EVALUATION
LOADS AND ACCEPTANCE CRITERIA

o LOADS CONSIDERED:

- DEAD WEIGHT
- INTERNAL PRESSURE
- SSE INERTIA
- SSE SEISMIC ANCHOR MOTIONS (SAM'S)


o LOAD COMBINATION AND ALLOWABLES:

(9)
$$\frac{P_{MAX}}{4} \frac{D_O}{T_N} + .75 \left(\frac{M_A}{Z} + \frac{M_B}{Z} \right) \leq 2.4 S_H$$

S_H = BASIC MATERIAL ALLOWABLE AT DESIGN TEMPERATURE

o ACCEPTANCE CRITERIA

- CLASS 2 AND CLASS 3 RULES OF 1980 ASME CODE, SECTION III, DIVISION 1, SUBSECTIONS NC & ND, EXCEPT AS INDICATED.





PIPING RE-EVALUATION
ACCEPTANCE CRITERIA (CONT'D)

- SINGLE ENVELOPED OR MULTIPLE LEVEL SPECTRA MAY BE APPLIED
- GROUPING OR DOUBLE SUM METHOD FOR COMBINING CLOSELY-SPACED MODES
- SAM'S CONSIDERED ONLY IF PIPING HAS SUPPORTS ATTACHED TO INDEPENDENTLY RESPONDING STRUCTURES
- SAM LOADS COMBINED WITH INERTIAL LOADS USING SRSS

1.

2.

3.

4.

PIPING SUPPORTS
METHODS AND ACCEPTANCE CRITERIA

- o ANALYZED ACCORDING TO 1980 ASME CODE SUBSECTION NF-3300 TO SERVICE LEVEL D LIMITS
- o LOADS DETERMINED FROM PIPING ANALYSES, USING SSE
- o SUPPORT ANCHORAGE ANALYZED IN ACCORDANCE WITH IE BULLETIN 79-02

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

MAIN ELEMENTS OF SUP (CONT'D)

- GUIDELINES FOR EVALUATION OF:
 - EQUIPMENT ANCHORAGE
 - CABINET ANCHORAGE
 - CABLE AND CONDUIT RACEWAYS
 - ESSENTIAL RELAYS

o PROGRAM ADMINISTRATION

- MANAGED BY NMPC, TEAM INCLUDES STEVENSON & ASSOCIATES, MPR ASSOCIATES
- PRELIMINARY MILESTONE SCHEDULE
- QUALITY ASSURANCE
 - DRAWINGS
 - COMPUTER PROGRAMS
 - CALCULATIONS
- DATA BASE REQUIREMENTS
 - RECORDS
 - ANALYTICAL MODELS



11

11 11 11 11 11

11

11

11

11

11

11

11

11

MILESTONE SCHEDULE

SHORT TERM:

SUP PROGRAM PLAN DEVELOPMENT
SUP PROGRAM PLAN REVIEW BY NMPC
PRESENT PROGRAM DESCRIPTION TO NRC
RECEIVE NRC COMMENTS ON PROGRAM

FINALIZATION OF CRITERIA:

GROUND MOTION (SSE)
STRUCTURAL
FLOOR SPECTRA
PIPING
SUPPORTS

OBTAIN NRC APPROVAL OF PROPOSED METHODOLOGY
AND GOVERNING CRITERIA

LONG TERM:

RE-EVALUATION OF GROUND MOTION SPECTRA
RE-EVALUATION OF CLASS 1 STRUCTURES
GENERATION OF NEW FLOOR RESPONSE SPECTRA
RE-EVALUATION OF PIPING & SUPPORTS
SEISMIC QUALIFICATION OF EQUIPMENT
PILOT PLANT REVIEW
PREPARE SER & PRESENT TO NRC
FINALIZE SER AFTER NRC COMMENTS

2011-11-11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

DAMPING VALUES FOR STRUCTURES AND EQUIPMENT
(PERCENT OF CRITICAL DAMPING)

<u>STRUCTURE OR COMPONENT</u>	<u>SAFE SHUTDOWN EARTHQUAKE</u>
EQUIPMENT	3
WELDED STEEL STRUCTURES	4
BOLTED STEEL STRUCTURES	7
PRESTRESSED CONCRETE STRUCTURES	5
REINFORCED CONCRETE STRUCTURES	7
ELECTRICAL RACEWAYS - EMPTY	7
ELECTRICAL RACEWAYS - FULL	20
SLOSHING MODE IN TANKS	0.5
IMPULSE MODE IN TANKS	4



CLASS I STRUCTURES

REACTOR BUILDING

WASTE DISPOSAL BUILDING

VENTILATION STACK

DRYWELL

REACTOR PRESSURE VESSEL AND ITS SUPPORT STRUCTURE

SUPPRESSION CHAMBER

DIESEL-GENERATOR SUPPORT FOUNDATION

CLASS II STRUCTURES

TURBINE BUILDING

TURBINE-GENERATOR SUPPORT FOUNDATION

INTAKE AND DISCHARGE TUNNELS

COMBINATION CLASS I AND CLASS II STRUCTURES

SCREEN AND PUMP HOUSE

10

11

12

13

14

15

16

17

18

19

20

21



CLASS I EQUIPMENT, SYSTEMS, OR AREAS IN CLASS II STRUCTURES

DIESEL-GENERATOR SUPPORT STRUCTURE

CONTROL ROOM

AUXILIARY CONTROL ROOM

BATTERY ROOM

BATTERY BOARD ROOM

SUPPORTING STEEL STRUCTURE FOR EMERGENCY
CONDENSER, MAKEUP, AND DEMINERALIZED WATER TANKS

11

12

13

14

15



CLASS I EQUIPMENT HOUSED IN AND SUPPORTED BY
COMBINATION I/II STRUCTURES

EMERGENCY SERVICE WATER PUMPS AND PIPING

CONTAINMENT SPRAY COOLING PUMPS AND PIPING

DIESEL-GENERATOR COOLING WATER PUMPS AND PIPING

SERVICE WATER PUMPS AND PIPING

100

101

102

103

104

105

106

107

108

109

110

CLASS I EQUIPMENT HOUSED IN AND SUPPORTED BY
CLASS II STRUCTURES

CONDENSATE STORAGE TANKS AND PIPING

CONDENSATE PUMPS, SUCTION AND DISCHARGE PIPING

FEEDWATER BOOSTER PUMPS AND DISCHARGE PIPING

HIGH PRESSURE REACTOR FEED PUMPS AND DISCHARGE PIPING

DIESEL-GENERATOR FUEL OIL, STARTING AIR AND COOLING
WATER PIPING

EMERGENCY CONDENSER STORAGE TANKS

REACTOR BUILDING CLOSED LOOP COOLING PIPING (PARTIAL)

BREATHING AIR PIPING (PARTIAL)

INSTRUMENT AIR COMPRESSORS

INSTRUMENT AIR PIPING (PARTIAL)

SERVICE WATER PIPING (PARTIAL)



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

CLASS I PIPING SYSTEMS

MAIN STEAM INSIDE DRYWELL

CORE SPRAY

CONTAINMENT ATMOSPHERIC DILUTION

CONTAINMENT ATMOSPHERIC MONITORING

CONTAINMENT SPRAY

CONTAINMENT SPRAY COOLING WATER

EMERGENCY COOLING

LIQUID POISON

DRYWELL AND SUPPRESSION CHAMBER VACUUM RELIEF

FUEL POOL COOLING AND FILTERING

REACTOR CLEANUP

REACTOR SHUTDOWN COOLING

REACTOR HEAD SPRAY

CONDENSATE STORAGE

CONDENSATE PUMP SUCTION AND DISCHARGE



CLASS I PIPING SYSTEMS (CONT'D)

FEEDWATER BOOSTER DISCHARGE

HIGH PRESSURE REACTOR FEEDWATER

REACTOR BUILDING CLOSED LOOP COOLING

CONTROL ROD DRIVE PIPING

RADIOACTIVE WASTE DISPOSAL SYSTEM

EMERGENCY VENTILATION

BREATHING AIR

INSTRUMENT AIR

SERVICE WATER -

DIESEL-GENERATOR FUEL OIL, STARTING AIR, AND
COOLING WATER



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

CLASS II PIPING SYSTEMS

MAIN STEAM OUTSIDE DRYWELL

BYPASS STEAM TO CONDENSER

STEAM SUPPLY TO AIR EJECTOR

EXTRACTION STEAM PIPING

MAKEUP DEMINERALIZER

TURBINE BUILDING CLOSED LOOP COOLING

REACTOR AND TURBINE BUILDINGS, SUMP PUMP DISCHARGE

SEAL WATER

TURBINE OIL STORAGE

CITY WATER

LABORATORY DRAINS

OFF-GAS

