UNITED STATES

## NUCLEAR REGULATORY COMMISSION

In the Matter of	)	
	)	
NIAGARA MOHAWK POWER CORPORATION	)	Docket No. 50-220
	)	
(Nine Mile Point Nuclear Station Unit	No. 1)	

## APPLICATION FOR AMENDMENT

TO

## **OPERATING LICENSE**

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. DPR-63, hereby requests that Specification 3.2.2 of the Technical Specifications set forth in Appendix A to that License be amended. These proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specification changes are set forth in Attachment A to this application. Figures 3.2.2.a, b and c, Tables 3.2.2.a, b and c, and the associated Bases have been proposed for amendment in order to reflect a change in the limits for minimum reactor vessel temperature for pressurization. These limits are based on measured nil-ductility temperature shifts of irradiated Nine Mile Point Unit 1 reactor vessel material specimens. Supporting information and analysis which demonstrate that the proposed changes involve no significant hazards considerations pursuant to 10CFR50.92 are included as Attachment B.

8707200404 870708 PDR ADBCK 05000220 PDR • u .

WHEREFORE, Applicant respectfully requests that Appendix Arito Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

Subscribed and sworn to before me on this day of July 1987.

MARY FRATESCHI

Notary Public In the State of New York
Qualified in Onendaga County No. 4797550
My Commission Expires (M.D. 30, 19....)

