

# CONTROLLED

## NIAGARA MOHAWK POWER CORPORATION

# NINE MILE POINT UNIT 2 TEN YEAR INSERVICE INSPECTION PROGRAM PLAN

### SECTION III PUMP AND VALVE INSERVICE TESTING (IWP, IWV)

PREPARED BY:



**Gilbert/Commonwealth**  
engineers and consultants - Reading, Pennsylvania

REVIEWED BY:

*Robert DeWall*

NMPC PROJECT ENGINEER

APPROVED BY:

*Robert DeWall for R.W. Hammelman*

NMPC LEAD MECHANICAL ENGINEER

REV.	DATE	DESCRIPTION OF CHANGE	REVIEWED BY: PROJECT ENGR.	APPROVED BY: LEAD MECH. ENGR.
0	5/29/87	Original Issue	<i>RKD</i>	<i>RKD for RWH</i>

8708050033 870730  
PDR ADDCK 05000410  
Q PDR

170  
171  
172

21

173  
174

175

176

177

178

179  
180

181  
182  
183

184	185
186	187
188	189
190	191
192	193
194	195
196	197
198	199
200	201
202	203
204	205
206	207
208	209
210	211
212	213
214	215
216	217
218	219
220	221
222	223
224	225
226	227
228	229
230	231
232	233
234	235
236	237
238	239
240	241
242	243
244	245
246	247
248	249
250	251
252	253
254	255
256	257
258	259
260	261
262	263
264	265
266	267
268	269
270	271
272	273
274	275
276	277
278	279
280	281
282	283
284	285
286	287
288	289
290	291
292	293
294	295
296	297
298	299
300	301
302	303
304	305
306	307
308	309
310	311
312	313
314	315
316	317
318	319
320	321
322	323
324	325
326	327
328	329
330	331
332	333
334	335
336	337
338	339
340	341
342	343
344	345
346	347
348	349
350	351
352	353
354	355
356	357
358	359
360	361
362	363
364	365
366	367
368	369
370	371
372	373
374	375
376	377
378	379
380	381
382	383
384	385
386	387
388	389
390	391
392	393
394	395
396	397
398	399
400	401
402	403
404	405
406	407
408	409
410	411
412	413
414	415
416	417
418	419
420	421
422	423
424	425
426	427
428	429
430	431
432	433
434	435
436	437
438	439
440	441
442	443
444	445
446	447
448	449
450	451
452	453
454	455
456	457
458	459
460	461
462	463
464	465
466	467
468	469
470	471
472	473
474	475
476	477
478	479
480	481
482	483
484	485
486	487
488	489
490	491
492	493
494	495
496	497
498	499
500	501
502	503
504	505
506	507
508	509
510	511
512	513
514	515
516	517
518	519
520	521
522	523
524	525
526	527
528	529
530	531
532	533
534	535
536	537
538	539
540	541
542	543
544	545
546	547
548	549
550	551
552	553
554	555
556	557
558	559
560	561
562	563
564	565
566	567
568	569
570	571
572	573
574	575
576	577
578	579
580	581
582	583
584	585
586	587
588	589
590	591
592	593
594	595
596	597
598	599
600	601
602	603
604	605
606	607
608	609
610	611
612	613
614	615
616	617
618	619
620	621
622	623
624	625
626	627
628	629
630	631
632	633
634	635
636	637
638	639
640	641
642	643
644	645
646	647
648	649
650	651
652	653
654	655
656	657
658	659
660	661
662	663
664	665
666	667
668	669
670	671
672	673
674	675
676	677
678	679
680	681
682	683
684	685
686	687
688	689
690	691
692	693
694	695
696	697
698	699
700	701
702	703
704	705
706	707
708	709
710	711
712	713
714	715
716	717
718	719
720	721
722	723
724	725
726	727
728	729
730	731
732	733
734	735
736	737
738	739
740	741
742	743
744	745
746	747
748	749
750	751
752	753
754	755
756	757
758	759
760	761
762	763
764	765
766	767
768	769
770	771
772	773
774	775
776	777
778	779
780	781
782	783
784	785
786	787
788	789
790	791
792	793
794	795
796	797
798	799
800	801
802	803
804	805
806	807
808	809
810	811
812	813
814	815
816	817
818	819
820	821
822	823
824	825
826	827
828	829
830	831
832	833
834	835
836	837
838	839
840	841
842	843
844	845
846	847
848	849
850	851
852	853
854	855
856	857
858	859
860	861
862	863
864	865
866	867
868	869
870	871
872	873
874	875
876	877
878	879
880	881
882	883
884	885
886	887
888	889
890	891
892	893
894	895
896	897
898	899
900	901
902	903
904	905
906	907
908	909
910	911
912	913
914	915
916	917
918	919
920	921
922	923
924	925
926	927
928	929
930	931
932	933
934	935
936	937
938	939
940	941
942	943
944	945
946	947
948	949
950	951
952	953
954	955
956	957
958	959
960	961
962	963
964	965
966	967
968	969
970	971
972	973
974	975
976	977
978	979
980	981
982	983
984	985
986	987
988	989
990	991
992	993
994	995
996	997
998	999
1000	1001

TABLE OF CONTENTS

		<u>PAGE</u>
1.0	INTRODUCTION	1
	1.1 REGULATORY REQUIREMENTS	1
	1.2 ADDITIONAL REFERENCE DOCUMENTS	2
2.0	INSERVICE TESTING BOUNDARIES	4
	2.1 SCOPE	4
	2.2 EXEMPTIONS	5
	2.3 P&ID'S	5
3.0	PUMP AND VALVE SELECTION	7
	3.1 CODE REQUIREMENT POSITIONS	7
	3.2 ALTERNATIONS TO CODE REQUIREMENTS	8
	3.3 COLD SHUTDOWN TEST JUSTIFICATION DISCUSSION	9
	3.4 RELIEF REQUESTS DISCUSSION	10
4.0	PUMP AND VALVE IST PROGRAM TABLE DESCRIPTIONS	11
	4.1 PUMP PROGRAM TABLE DESCRIPTION	11
	4.2 VALVE PROGRAM TABLE DESCRIPTION	12

APPENDICES

- APPENDIX A - VALVE INSERVICE TESTING PROGRAM COLD SHUTDOWN TEST JUSTIFICATIONS
- APPENDIX B - PUMP INSERVICE TESTING PROGRAM RELIEF REQUESTS
- APPENDIX C - VALVE INSERVICE TESTING PROGRAM RELIEF REQUESTS
- APPENDIX D - PUMP INSERVICE TESTING PROGRAM TABLES
- APPENDIX E - VALVE INSERVICE TESTING PROGRAM TABLES



1.0

INTRODUCTION

The Pump and Valve Inservice Testing Program for the Nine Mile Point Nuclear Station Unit #2 (NMP2) details the technical basis and provides the overall description of the activities planned to fulfill the Inservice Testing (IST) requirements for safety related pumps and valves as defined in the American Society of Mechanical Engineers, Boiler and Pressure Vessel Code, Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components". The IST program includes the Class 1, 2 and 3 pumps and valves required to be tested in accordance with Section XI Subsections IWP and IWV.

The IST program document is divided into the Program Text and the Appendices. The Program Text defines the basis for the program. It lists and explains the specific exemptions and selection criteria applied to Class 1, 2 and 3 pumps and valves, thus defining the scope and extent of the IST testing requirements. The Appendices include the Cold Shutdown Test Justifications, Pump Relief Requests, Valve Relief Requests, Pump Tables, and Valve Tables.

1.1

REGULATORY REQUIREMENTS

1.1.1

Code of Federal Regulations

Title 10, Part 50.55a of the Code of Federal Regulations, Paragraph (g)(4) requires that 10-year IST programs comply with the latest edition and addenda of Section XI incorporated by reference in Paragraph (b)(2) on the date 12 months prior to the date of issuance of the operating license. The operating license for NMP2 was issued on October 31, 1986. The use of any later edition and addenda of Section XI is allowed if it has been incorporated in Paragraph (b)(2).

1.1.2

Applicable Code

The first 10-year pump and valve IST Program complies with Section XI of the ASME Boiler and Pressure Vessel Code, 1983 Edition through Summer of 1983 addenda (1983S83) as required by 10CFR50.55a(b)(2). All references to subsections IWP and IWV of Section XI in this document correspond to the



aforementioned Code Edition with the exception of the portions addressed in the following paragraph.

**1.1.3 Adoption of Code CASE N-415**

The valve test program adopts Code Case N-415, which permits the use of ANSI/ASME OM-1, 1981 as alternative requirements for replacement, repair and maintenance, inservice tests and test frequency for safety valves, relief valves (including vacuum relief valves) and rupture disks.

**1.2 ADDITIONAL REFERENCE DOCUMENTS**

**1.2.1 FSAR**

The Final Safety Analysis Report for NMP2 is used to determine which safety related pumps and valves are within the scope of paragraph 2.1 and to incorporate any additional testing requirements that may be specified.

**1.2.2 Technical Specification**

The NMP2 Technical Specification is used in conjunction with the FSAR to assist in determining the pumps and valves which are in scope. This document is also reviewed and compared to the pump and valve test program to determine areas of conflict between the two.

**1.2.3 Operating Procedures**

The Unit 2 Operating Procedures were used to determine system operating modes and alignments under normal and emergency conditions.

**1.2.4 NRC Letters**

- o "NRC Staff Guidance for Preparing Pump and Valve Testing Program Descriptions and Associated Relief Requests Pursuant to 10CFR50.55a(g)", January 1978 is used to provide guidance for the



establishment of selection philosophy, the program submittal format, and the development of relief requests.

- o "NRC Staff Guidance for Complying with Certain Provisions of 10CFR50.55a(g) Inservice Inspection Requirements", November 1976, is used as a reference to provide NRC staff guidelines for excluding exercising tests of certain valves during plant operation.

#### **1.2.5 Draft Regulatory Guide**

Division I Draft Regulatory Guide and Value Impact Statement (Draft 2), "Identification of Valves for Inclusion in Inservice Testing Programs" is used to provide further insight to NRC positions on the contents of the valve program.

#### **1.2.6 NRC I.E. Bulletin**

I.E. Bulletin Number 83-03: "Check Valve Failures in Raw Water Cooling Systems of Diesel Generators" provides recommendations on test requirements for check valves.

#### **1.2.7 NRC I.E. Notice**

I.E. Notice Number 84-74: "Isolation of Reactor Coolant System from Low-Pressure Systems Outside Containment" is used for a reference for providing justification for relief from exercising certain reactor coolant pressure boundary valves.

#### **1.2.8 ASME/ANSI OM Documents**

- o OM-1 1981 is used for relief/safety valve and rupture disc testing per Code Case N-415.
- o Draft 8 of OM-6 for pump testing and OM-10 for valve testing are used for reference when determining testing requirements.



**2.0**      **INSERVICE TESTING BOUNDARIES**

**2.1**      **SCOPE**

**2.1.1**    **Pump IST Program**

The scope of the pump IST program includes all safety related centrifugal and positive displacement type pumps that are provided with an emergency power source, that are not exempt by paragraph 2.2.1, and which function to:

- o Mitigate the consequences of an accident or,
- o Shutdown the reactor to a cold shutdown condition.

These safety related pumps are found within the Class 1, 2, and 3 boundaries. The pumps within this scope are listed in Appendix D.

**2.1.2**    **Valve IST Program**

The scope of the valve IST program includes all safety related valves that are not exempt by paragraph 2.2.2 and which function to:

- o Mitigate the consequences of an accident or,
- o Shutdown the reactor to a cold shutdown condition.

These safety related valves are found within the Class 1, 2, and 3 boundaries. The valves within this scope are listed in Appendix E.



**2.2 EXEMPTIONS**

**2.2.1 Pump Exclusions Identified in IWP-1200**

Note: The term "Exclusions" is used in IWP-1200, but is considered synonymous with "Exemptions".

- a. Drivers of pumps with the exception when the driver and pump form an integral unit and the pump bearings are in the driver.
- b. Pumps supplied with emergency power solely for operating convenience.

**2.2.2 Valve Exemptions Identified in IWP-1200**

- a. Maintenance Valves - Valves which are used only to isolate components to perform maintenance, including relief valves which provide overpressure protection for a component that is isolated only for maintenance.
- b. Operating Convenience Valves - Valves used only for operating convenience, such as manual vent, drain, instrument, and test valves.
- c. System Control Valves - Valves such as pressure regulating, flow control, and manual throttle valves.
- d. Valves in External Control and Protection Systems - Systems responsible for sensing plant conditions and providing signals for valve operation.

**2.3 P&ID's**

A listing of all the P&ID's identifying safety related pumps and valves is included in Table 2.3-1.



TABLE 2.3-1

PUMP AND VALVE (IST) PROGRAM P&ID'S

<u>P&amp;ID NUMBER</u>	<u>SYSTEM</u>	<u>REV.</u>
2-A,B,C,D,E	Symbols	1
1-A,B,C,D,E,F,J	Main Steam (MSS)	3
	Mainsteam Safety Valves, Vents, and Drains (SVV)	
6-B	Feedwater (FWS)	3
11-A,B,C,D,E,F,G,H,J,L,P,Q	Service Water (SWP)	3
13-A,B,C,D,E	React. Bldg. Closed Loop Cooling Water (CCP)	3
19-D,E,F,G,J,L,M	Instrument Air (IAS)	3
	Service Air (SAS)	3
20-E	Breathing Air (AAS)	3
28-A,B,C	Reactor Vessel Instrument (ISC)	3
29-A,B,C	Reactor Recirc. System (RCS)	3
30-B,C	CRD Hydraulic System (RDS)	3
31-A,B,C,D,E,F,G	Residual Heat Removal System (RHS)	3
32-A	Low-Pressure Core Spray (CSL)	3
33-A,B	High-Pressure Core Spray (CSH)	3
35-A,B	Reactor Core Isolation Cooling (ICS)	3
	Reactor Core Isolation Cooling (ICS)	2
36-A	Standby Liquid Control (SLS)	3
37-A,B	Reactor Water Cleanup System (WCS)	3
EM-38A	Neutron Monitoring System (NMS)	5
38-A,B,C	Fuel Pool Cooling and Cleanup (SFC)	3
43-G	Fire Protection Water (FPW)	3
53-A,B	Control Bldg. Chilled Water (HVK)	3
61-A,B	Primary Containment Purge and Standby Gas Treatment (CPS)	3
62-A,B	DBA Hydrogen Recombiner (HCS)	3
63-E	Reactor Bldg. Floor Drains (DFR)	3
67-A	Drywell Equipment Drains (DER)	3
81-A	Cont. Leakage Monitoring (LMS)	3
82-A,B	Cont. Atmosphere Monitoring (CMS)	3
104-A,	Diesel Gen. Air Startup (EGA)	3
	Standby Diesel Gen. Fuel (EGF)	3
105-B	Nitrogen System (GSN)	3



### 3.0 PUMP AND VALVE SELECTION

Class 1, 2 and 3 pumps and valves which are within the scope of the Inservice Testing Program, as defined in Section 2.1, and are not exempt per Section 2.2, shall be tested in accordance with the Section XI Code Editions stated in paragraphs 1.1.2 and 1.1.3. Tables listing the pumps and valves, including all applicable testing requirements and frequencies, are contained in Appendices D and E, respectively. Pump and valve table descriptions are found in Section 4.0. When valve testing must be deferred to cold shutdown, Cold Shutdown Test Justifications are provided in Appendix A. When the pump or valve testing requirements of the applicable code cannot be met for any reason, relief requests are provided in Appendix B or C respectively.

#### 3.1 CODE REQUIREMENT POSITIONS

This section indicates the positions used to clarify Code requirements as they apply for the formulation and the implementation of this program.

##### 3.1.1 Passive Valves

Subsection IWV-2100(b) defines passive valves as "valves which are not required to change position to accomplish a specific function". For this program, passive valves are further defined as those valves where the normal and safety position are the same, and the valve is not required to change position during any normal plant operating condition, provided the valve does not receive an automatic actuation signal.

##### 3.1.2 Cold Shutdown Testing

For valves in which testing is deferred to cold shutdown, testing will commence within 48 hours after cold shutdown is achieved and will continue until all tests are complete or the plant is ready to return to power. Any testing not completed at one cold shutdown will be performed during any subsequent cold shutdowns. For planned cold shutdowns in which NMP2 will have sufficient time to complete the testing of all valves identified to be tested at cold shutdown, exception may be taken to the 48 hour start time. As



a minimum, all cold shutdown valves will be tested during each refueling outage, however, valve testing will not be performed at a frequency greater than quarterly for Categories A, B and C valves.

### **3.1.3 Check Valve Full/Partial Stroke**

In most cases, full design flow through a check valve requires less than full mechanical valve movement. As used in this program, with the exception of testable check valves, the term full stroke refers to the ability of the valve to pass design flow, and not the full mechanical stroking. Forward flow stroke operability testing will be by any method that verifies the valve is capable of passing design flow. Any test that verifies less than full design flow capability is considered as a partial stroke test.

## **3.2 ALTERATIONS TO CODE REQUIREMENTS**

### **3.2.1 Pump Vibration Testing**

NMP2 has adopted velocity instead of displacement for measuring pump vibration on all pumps. Justification is provided in Relief Request GPRR-1, based on the conclusion that vibration velocity provides a significant improvement in the predictive capability of vibration testing, which will result in earlier detection of potential problems.

### **3.2.2 Pump Bearing Temperature**

Pump bearing temperature monitoring will not be performed. Justification is provided in Relief Request GPRR-3, based on the conclusion that the ability of improved vibration testing to detect very small changes in bearing condition would preclude any bearing condition severe enough to cause an abnormal rise in the temperature on the bearing housing.

### **3.2.3 Increased Testing Frequencies**

The testing frequencies for certain Category C and D valves has been increased in compliance with Technical Specification or FSAR commitments.



The specific frequency designations and the associated references are contained in the test frequency section of Table 4.2-2.

### 3.3 COLD SHUTDOWN TEST JUSTIFICATION DISCUSSION

The Code permits the delay of valve testing that is impractical during operation to be performed during cold shutdown. Justification for this delay of testing is provided by the Cold Shutdown Test Justifications included in Appendix A. Each Cold Shutdown Test Justification is formatted to contain the following information:

- o Cold Shutdown Test Justification Number
- o System
- o Valve Identification Number
- o Category
- o Class
- o Function
- o Quarterly Test Requirements
- o Cold Shutdown Test Justification
- o Quarterly Partial Stroke Testing
- o Cold Shutdown Testing

The cold shutdown test justifications are formatted for numerical filing as follows:

XXX-VCS-Y where:

- XXX = System designation
- VCS = Valve cold shutdown test justification
- Y = Sequential number within any system



### **3.4 RELIEF REQUESTS DISCUSSION**

#### **3.4.1 General**

Written relief requests as allowed by 10CFR50.55a(g)(5)(iii) have been provided in Appendix B, for pumps, and Appendix C, for valves, to provide justification for:

- o Performance of testing requirements on pumps and valves that are impractical during both operation and cold shutdown.
- o The use of alternate testing methods when Code requirements are either impractical, or where the alternate methods provide equal to or greater assurance of pump and valve operability.

Each relief request is formatted to include the following information:

- o Relief Request Number
- o System (specific relief requests only)
- o Pump or Valve Identification Number
- o Category (valves only)
- o Class
- o Function (specific relief requests only)
- o Testing Requirement
- o Basis for Relief
- o Alternate Testing

#### **3.4.2 Generic Pump and Valve Relief Requests**

Generic relief requests are used when a relief request applies to pumps or valves in general, e.g.: all containment isolation valves that are Type C tested or all centrifugal pumps.



These relief requests are formatted for numerical filing as follows:

GVRR-Y or GPRR-Y where:

GVRR = Generic valve relief request  
GPRR = Generic pump relief request  
Y = Sequential number

### 3.4.3 Specific Pump and Valve Relief Requests

These reliefs are used to provide specific relief to specific pumps or valves and are formatted for numerical filing as follows:

XXX-VRR-Y or XXX-PRR-Y where:

XXX = System designation  
VRR = Valve relief request  
PRR = Pump relief request  
Y = Sequential relief request number in any system

## 4.0 PUMP AND VALVE IST PROGRAM TABLE DESCRIPTIONS

### 4.1 PUMP PROGRAM TABLE DESCRIPTION

#### 4.1.1 Pump Table Summary

The Pump IST Program Table (Appendix D) contains an alpha-numeric listing of all the pumps included in the NMP2 Section XI Pump IST Program. The data contained in these tables identifies the inservice test parameters to be measured, the applicable relief requests and any applicable remarks. NOTE: A column for testing frequency was not included since all testing for pumps will be performed QUARTERLY.



#### 4.1.2 Pump Program Table Format

The Pump IST Program Tables has been organized to provide the following information:

Note: The numbers in parenthesis correspond to those found on the sample pump (IST) Program Table found in Table 4.1-1.

- (1) PUMP MARK NUMBER: The pump identification number
- (2) CODE CLASS: ASME Code Class
- (3) P&ID: Piping and Instrumentation Drawing where pump is located
- (4) COORD: Location coordinates of the pump on the P&ID
- (5) PARAMETERS - This column lists the applicable testing parameters that will be measured. The parameters listed are those required by the code unless alternate testing is provided by relief request. The following is a description of applicable parameters:
  - o SPEED - Pump speed (only required for variable speed pumps)
  - o INLET PRESS - Pump suction pressure
  - o DIFF PRESS - Pump differential or discharge pressure
  - o VIB VEL - Pump vibration velocity.
  - o FLOW - Pump flowrate
- (6) RELIEF - Indicates whether or not there is a relief request applicable, where Y = Yes and N = No. The specific relief request number is found in the remarks column.
- (7) REMARKS - Any additional pertinent information such as the applicable Relief Requests Number, FSAR or Tech. Spec. reference, is provided in this space.

#### 4.2 VALVE PROGRAM TABLE DESCRIPTION

##### 4.2.1 Valve Program Table Summary

The Valve Program Tables (Appendix E) provide a tabulation of all safety-related valves included in the NMP2 Valve IST Program. The tables are arranged by system and the valves in each system are listed in alpha-numeric sequence.



SAMPLE TABLE

TABLE 4.1-1

PUMP INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION UNIT #2

<u>PUMP MARK NUMBER</u>	<u>CODE CLASS</u>	<u>P&amp;ID</u>	<u>COORD</u>	<u>PARAMETERS</u>	<u>RELIEF</u>	<u>REMARKS</u>
(1)	(2)	(3)	(4)	(5)	(6)	(7)

SECTION III  
PAGE 13  
REVISION 0



4.2.2 Valve Program Table Format

Each valve program table has been organized to provide the following information:

Note: The numbers in parenthesis correspond to those found on the sample valve IST Program Table found in Table 4.2-1.

- (1) SYSTEM: The system that the particular table applies to
- (2) VALVE NUMBER: The valve identification mark number
- (3) CLASS: ASME Code Class
- (4) P&ID: Piping and instrumentation drawing where the valve is located
- (5) COORD: Location coordinates of the valve on the P&ID
- (6) VCAT: Valve category as identified by IWV-2200
- (7) ACT/PAS: Classification according to IWV-2100  
Where: A = Active  
P = Passive
- (8) SIZE: Valve size in inches
- (9) VALVE TYPE: Valve design type
- (10) ACTUAT TYPE: Type of actuator used to change position of valve
- (11) VALVE POSITIONS:
  - (a) NRM - Position during normal plant operation
  - (b) SAF - Position to fulfill safety function
  - (c) FAL - Position valve fails to or loss of electrical power
- (12) TYPE C - Indicates whether valve requires Appendix J, Type C Leak Test, where: Y = Yes N = No



- (13) **TEST, FREQ, (DIR):** The testing requirement, frequency the test will be performed, and in parenthesis, either the direction(s) stroke time should be measured for power operated valves, or the direction(s) the valve should be exercised for check valves. This column identifies the Code requirements unless alternate testing is provided by relief request or cold shutdown test justification. Format for the field is as follows:

Test code - Frequency Code (stroke time or exercise direction)

e.g.: FE-Q (F+R) = Full stroke exercise quarterly in the forward and reverse flow direction

ST-CS(O) = Measure valve stroke time in the open direction during cold shutdowns.

FE-R(R) = Full stroke exercise during refueling outage in the reverse direction.

- (14) **RELIEF:** Indicates whether or not there is a relief request, or cold shutdown test justification applicable; where Y = Yes and N = No. The specific relief request or cold shutdown test justification number is found in the remarks column.
- (15) **REMARKS:** Any additional pertinent information such as the applicable Cold Shutdown Test Justifications numbers and/or Relief Request numbers are provided in this space.

#### 4.2.3 Valve Program Table Codes

A quick reference table providing definitions for the codes (abbreviations) used on the Valve Program Tables is provided in Table 4.2-2.



2

SAMPLE TABLE

TABLE 4.2-1

VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION UNIT #2

SYSTEM: (1)

<u>VALVE NUMBER</u>	<u>CLASS</u>	<u>P&amp;ID</u>	<u>COORD</u>	<u>VCAT</u>	<u>ACT PAS</u>	<u>SIZE</u>	<u>VALVE TYPE</u>	<u>ACTUAT TYPE</u>	<u>POSITIONS</u>			<u>TEST FREQ. (DIR.)</u>	<u>RELIEF</u>	<u>REMARKS</u>	
(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11a)	(11b)	(11c)	(12)	(13)	(14)	(15)



TABLE 4.2-2 VALVE TABLE CODES

VALVE TYPE				ACTUATOR TYPE	
CODE	DEFINITION	CODE	DEFINITION	CODE	DEFINITION
AGV	Angle Valve	NDV	Needle	AOA	Air Operator
BFV	Butterfly	PGV	Plug	EXA	Explosive-Operator
BLV	Ball	PRV	Regulating	HOA	Hydraulic-Operator
CHV	Check	RD	Rupture Disc	MAA	Manual Operator
DIV	Diaphragm	REV	Relief	MOA	Motor Operator
EXV	Explosive	SCV	Stop Check	NOA	Nitrogen Operator
FCV	Flow Control	SKV	Spring Check	SEA	Self-Actuated
GTV	Gate	TCV	Testable Check	SOA	Solenoid-Operator
GLV	Globe	VRV	Vacuum Breaker		

VALVE POSITIONS		TEST DIRECTION	
CODE	DESCRIPTION	CODE	DEFINITION
O	Open	O	Open
C	Closed	C	Closed
LO	Locked Open	F	Forward Flow
LC	Locked Closed	R	Reverse Flow
TH	Throttled		
--	Determined by system parameters i.e. check valve		
AI	As is		
OC	Open or Closed		

TEST REQUIREMENTS		TEST FREQUENCY	
CODE	DEFINITION	CODE	DEFINITION
EX	Explosive Valve per IWV-3610	Q	Quarterly
FE	Full Stroke Exercise per IWV-3412 or 3522	S	Every 6 months
FS	Fail Safe per IWV-3415	CS	Cold Shutdown
LJ	Leak Test per 10CFR50 Appendix J	R	Refueling
LK	Leak Test per Section XI (Pressure Isolation Only)	T	Every 2 years
PI	Remote Position Indication Test per IWV-3300	P1	50% each refueling outage per FSAR 5.2.2.10
RT	Relief Valve per OM-1, 1981	P2	Every 10 years per OM-1, 1981
RD	Rupture Disc per OM-1, 1981	P3	Every 5 years per OM-1, 1981
ST	Stroke Time per IWV-3413	P4	Every refueling outage per T.S.4.6.4.b.3
VT	Vacuum Test per OM-1, 1981	P5	50% each refueling outage per T.S.4.1.5.d.1
		P6	1 squib each refueling outage per T.S.4.6.3.5.b



APPENDIX A

VALVE INSERVICE TESTING PROGRAM  
COLD SHUTDOWN TEST JUSTIFICATIONS



### COLD SHUTDOWN TEST JUSTIFICATION CCP-VCS-1

**System:** Reactor Building Closed Loop  
Cooling Water

**Valve(s):** 2CCP\*MOV15A,B  
2CCP\*MOV16A,B  
2CCP\*MOV17A,B  
2CCP\*MOV94A,B

**Category:** A [2CCP\*MOV15A, 15B, 16A, 16B, 17A, 17B, 94A, 94B]

**Class:** 2 [2CCP\*MOV15A, 15B, 16A, 16B, 17A, 17B, 94A, 94B]

**Function:** Inlet and outlet primary containment isolation valves to recirculation pump coolers and CCP return line block valves.

**Quarterly Test Requirements:** Exercise and stroke time.

**Cold Shutdown Test Justification:** Testing during operation would cause a loss of CCP flow to the recirculation pump seal coolers, motor bearing coolers, and motor winding coolers. The failure of any one of these valves to reopen after stroking would result in a complete loss of cooling to the associated recirculation pump, which could cause extensive damage to the pump. Furthermore, loss of cooling requires a plant shutdown.

**Quarterly Partial Stroke Testing:** The operating circuitry of these valves only permits full stroke operation.

**Cold Shutdown Testing:** Exercise and stroke time.



**COLD SHUTDOWN TEST JUSTIFICATION CCP-VCS-2**

**System:** Reactor Building Closed Loop Cooling Water

**Valve(s):** 2CCP\*MOV122  
2CCP\*MOV124  
2CCP\*MOV265  
2CCP\*MOV273

**Category:** A

**Class:** 2

**Function:** CCP supply and return line primary containment isolation valves to drywell unit coolers.

**Quarterly Test Requirements:** Exercise and stroke time.

**Cold Shutdown Test Justification:** The drywell coolers are required during normal plant operation to maintain the average drywell temperature below 150°F. Cycling of these valves will interrupt cooling water flow to the drywell coolers. The failure of any one of these valves to reopen after testing would result in a complete loss of cooling water to the drywell coolers. This loss would lead to a high drywell temperature condition and required plant shutdown. Furthermore, the loss of drywell cooling could result in equipment damage and/or a high drywell pressure and subsequent reactor trip.

**Quarterly Partial Stroke Testing:** The operating circuitry of these valves only permits full stroke operation.

**Cold Shutdown Testing:** Exercise and stroke time.



**COLD SHUTDOWN TEST JUSTIFICATION CSH-VCS-1**

**System:** High-Pressure Core Spray

**Valve(s):** 2CSH\*A0V108

**Category:** AC

**Class:** 1

**Function:** HPCS discharge line inside containment isolation valve.

**Quarterly Test Requirements:** Verify forward flow operability and reverse flow closure.

**Cold Shutdown Test Justification:** This valve is a testable check valve equipped with an air operator for testing. During plant operation, full reactor coolant system pressure is imposed on the valve disk. The air operator is only capable of exercising the valve against zero differential pressure.

**Quarterly Partial Stroke Testing:** The valve operator is incapable of exercising the valve against the reactor coolant system pressure.

**Cold Shutdown Testing:** Forward flow operability and reverse flow closure will be verified using the air test operator when the differential pressure across the valve is reduced to zero.



**COLD SHUTDOWN TEST JUSTIFICATION CSH-VCS-2**

**System:** High-Pressure Core Spray

**Valve(s):** 2CSH\*MOV107

**Category:** A

**Class:** 1

**Function:** HPCS discharge line outside containment isolation valve.

**Quarterly Test Requirements:** Exercise and stroke time.

**Cold Shutdown Test Justification:** This valve and check valves 2CSH\*AOV108 and 2CHS\*V9 prevent overpressurization of the CSH pump suction piping. Since there are no provisions to detect leakage past the check valves during plant operation, opening of this valve could over pressurize the CSH pump suction piping, if simultaneous leakage occurred past the check valves.

**Quarterly Partial Stroke Testing:** The operating circuitry of this valve only permits full stroke operation.

**Cold Shutdown Testing:** Exercise and stroke time.



**COLD SHUTDOWN TEST JUSTIFICATION CSH-VCS-3**

**System:** High-Pressure Core Spray

**Valve(s):** 2CSH\*V16

**Category:** C

**Class:** 2

**Function:** HPCS pump suppression pool suction line check valve.

**Quarterly Test Requirements:** Verify forward flow operability.

**Cold Shutdown Test Justification:** The only way to verify forward flow operability is to pump suppression pool water through the system back to the suppression pool via the test return line. This leaves a significant amount of poor quality suppression pool water in the CSH piping. If an initiation of the CSH occurred before the system were flushed, the poor quality suppression pool water would be injected into the reactor, resulting in loss of reactor coolant system water chemistry and a forced reactor shutdown.

**Quarterly Partial Stroke Testing:** Partial stroke exercising would have the same effect as full stroke exercising during normal operation.

**Cold Shutdown Testing:** The valve will be tested for forward flow operability at cold shutdown when there is sufficient time to flush the system after testing.



### COLD SHUTDOWN TEST JUSTIFICATION CSL-VCS-1

**System:** Low-Pressure Core Spray

**Valve(s):** 2CSL\*AOV101  
2CSL\*MOV104

**Category:** A [2CSL\*MOV104]  
AC [2CSL\*AOV101]

**Class:** 1

**Function:** LPCS injection inside and outside containment isolation valves.

**Quarterly Test Requirements:** Exercise and stroke time [2CSLMOV104]. Verify forward and reverse flow operability [2CSL\*AOV101].

**Cold Shutdown Test Justification:** These valves are reactor pressure boundary valves, they also provide isolation between high and low pressure CSL piping. Testable check valve 2CSL\*AOV101 can only be operated using the air test operator when differential pressure across the valve is equal to zero. Valve 2CSL\*MOV104 can only be opened when differential pressure across the valve is 88 PSID or less. During normal plant operation, these conditions cannot be achieved and; furthermore, if leakage occurred past either valve while the other was opened, damage could occur to the low pressure CSL piping.

**Quarterly Partial Stroke Testing:** Partial stroke exercising results in the same situation as full stroke exercising.

**Cold Shutdown Testing:** All required quarterly testing listed above will be performed.



**COLD SHUTDOWN TEST JUSTIFICATION FWS-VCS-1**

**System;** Feedwater

**Valve(s);** 2FWS\*AOV23A, B

**Category:** AC

**Class:** 1

**Function:** Feedwater system outside primary containment isolation valve.

**Quarterly Test Requirements:** Verify reverse flow closure.

**Cold Shutdown Test Justification:** These valves are testable check valves with installed air operators for testing. The air operators are not capable of closing the valves with the feedwater system in operations. To exercise the valves closed during normal operation would require a significant reduction in power and stopping one loop of feedwater would introduce undesirable operational transients and could result in a reactor scram.

**Quarterly Partial Stroke Testing:** Partial stroking would require the same conditions as full stroke exerising.

**Cold Shutdown Test Justification:** Reverse flow closure will be verified using the installed air test operators.



**COLD SHUTDOWN TEST JUSTIFICATION FWS-VCS-2**

**System;** Feedwater

**Valve(s);** 2FWS\*MOV21A, B

**Category:** A

**Class:** 1

**Function:** Feedwater system flow block valves.

**Quarterly Test Requirements:** Exercise and stroke time.

**Cold Shutdown Test Justification:** Exercising these valves during normal operation would require a significant reduction in power and stopping one loop of feedwater flow. Isolation of one loop of feedwater would introduce undesirable operational transients and could result in a reactor scram.

**Quarterly Partial Stroke Testing:** The operating circuitry of this valve only permits full stroke operation.

**Cold Shutdown Testing:** Exercise and stroke time.



**COLD SHUTDOWN TEST JUSTIFICATION ICS-VCS-1**

**System;** Reactor Core Isolation Cooling

**Valve(s);** 2ICS\*MOV126

**Category:** B

**Class:** 1

**Function:** RCIC injection valve.

**Quarterly Test Requirements:** Exercise and stroke time.

**Cold Shutdown Test Justification:** System design did not provide a means to verify that there is no leakage across downstream testable check valves 2ICS\*AOV156 and 2ICS\*AOV157 during normal operation. If leakage does exist, opening 2ICS\*MOV126 during normal operation could result in an intersystem LOCA.

**Quarterly Partial Stroke Testing:** The operating circuitry of this valve only permits full stroke operation.

**Cold Shutdown Testing:** Exercise and stroke time.



**COLD SHUTDOWN TEST JUSTIFICATION ICS-VCS-2**

**System;** Reactor Core Isolation Cooling

**Valve(s);** 2ICS\*AOV156  
2ICS\*AOV157

**Category:** A

**Class:** 1

**Function:** RCIC injection line containment isolation valves.

**Quarterly Test Requirements:** Verify forward flow operability and reverse flow closure.

**Cold Shutdown Test Justification:** These valves are testable check valves with air test operators. During plant operation full reactor coolant system pressure is imposed on the valve disk. The air operator is only capable of exercising the valve against zero differential pressure. There are no system design provisions to verify leak tight closure of the valves after exercising. If the valves were to be exercised by using ICS system injection, the valves cannot be verified as fully closed after exercising. If upstream 2ICS\*MOV126 were opened inadvertently with leakage across these valves, the possibility of an intersystem LOCA exists. Forward flow injection of RCIC water during normal operation would cause a turbine trip and subsequent reactor scram.

**Quarterly Partial Stroke Testing:** Partial stroking requires the same conditions as full stroke testing.

**Cold Shutdown Testing:** Forward flow operability and reverse flow closure will be verified using the air test operators when the differential pressure across the valve is zero.



**COLD SHUTDOWN TEST JUSTIFICATION ICS-VCS-3**

**System;** Reactor Core Isolation Cooling

**Valve(s);** 2ICS\*MOV128

**Category:** A

**Class:** 1

**Function:** Inboard primary containment isolation valve.

**Quarterly Test Requirements:** Exercise and stroke time.

**Cold Shutdown Test Justification:** Failure of this valve in the closed position during normal operation would preclude the capability of operating the ICS system, if required. This valve is located inside the primary containment and could not be reopened manually without shutting down the reactor.

**Quarterly Partial Stroke Testing:** The operating circuitry for this valve only permits full stroke operation.

**Cold Shutdown Testing:** Exercise and stroke time.



**COLD SHUTDOWN TEST JUSTIFICATION ICS-VCS-4**

**System;** Reactor Core Isolation Cooling

**Valve(s);** 2ICS\*V28

**Category:** C

**Class:** 2

**Function:** ICS pump suppression pool suction line check valve.

**Quarterly Test Requirements:** Verify forward flow operability.

**Cold Shutdown Test Justification:** The only way to verify forward flow operability is to pump suppression pool water through the system and back to the suppression pool via the mini-flow return line. This leaves a significant amount of poor quality suppression pool water in the ICS. If an initiation of the ICS occurred before the system were flushed, the poor quality suppression pool water would be injected into the reactor, resulting in loss of reactor coolant system water chemistry and a forced reactor shutdown.

**Quarterly Partial Stroke Testing:** Partial stroke exercising would have the same effect as full stroke exercising during normal operation.

**Cold Shutdown Testing:** The valve will be tested for forward flow operability at cold shutdown when there is sufficient time to flush the system after testing.



**COLD SHUTDOWN TEST JUSTIFICATION MSS-VCS-1**

**System;** Main Steam

**Valve(s);** 2MSS\*AOV6A, B, C, D  
2MSS\*AOV7A, B, C, D

**Category:** A

**Class:** 1

**Function:** Main steam line inside and outside primary containment isolation valves.

**Quarterly Test Requirements:** Exercise, stroke time, and fail-safe test.

**Cold Shutdown Test Justification:** To exercise these valves during power operation would require a significant reduction in power and placing the plant in an abnormal operating condition with one main steam line isolated to the turbine. Also, recent industry information indicates that closing these valves with high steam flow in the line may be a large contributing factor in observed seat degradation.

**Quarterly Partial Stroke Testing:** Valves are partial stroke tested during normal plant operation.

**Cold Shutdown Testing:** Exercise, stroke time, and fail-safe test.



**COLD SHUTDOWN TEST JUSTIFICATION RCS-VCS-1**

**System;** Reactor Coolant (Recirculation)

**Valve(s);** 2RCS\*MOV18A, B

**Category:** B

**Class:** 1

**Function:** Reactor recirculation pumps P1A and P1B discharge isolation valves.

**Quarterly Test Requirements:** Exercise and stroke time.

**Cold Shutdown Test Justification:** Exercising these valves during normal operation would require a significant reduction in power and stopping flow in one recirculation loop. Isolation of one recirculation loop would introduce an undesirable operational transient that could result in a reactor scram.

**Quarterly Partial Stroke Testing:** The operating circuitry of these valves only permits full stroke operation.

**Cold Shutdown Testing:** Exercise and stroke time.



**COLD SHUTDOWN TEST JUSTIFICATION RCS-VCS-2**

**System;** Reactor Coolant (Recirculation)

**Valve(s);** 2RCS\*SOV65A, B  
2RCS\*SOV66A, B  
2RCS\*SOV67A, B  
2RCS\*SOV68A, B  
2RCS\*SOV79A, B  
2RCS\*SOV80A, B  
2RCS\*SOV81A, B  
2RCS\*SOV82A, B

**Category:** A

**Class:** 2

**Function:** Primary containment block valves in the reactor coolant recirculation flow control valve hydraulic lines.

**Quarterly Test Requirements:** Exercise, stroke time, and fail-safe test.

**Cold Shutdown Test Justification:** These valves control the flow of hydraulic fluid to the reactor coolant recirculation flow control valves, and their positions control the positions of the flow control valves. Exercising these valves during reactor coolant recirculation flow would cause disturbance of normal loop flow and could result in adverse plant operation, e.g., changes in reactivity, power transient, and a possible reactor scram.

**Quarterly Partial Stroke Testing:** The operating circuitry of these valves only permits full stroke operation.

**Cold Shutdown Testing:** Exercise, stroke time, and fail-safe test.



**COLD SHUTDOWN TEST JUSTIFICATION RHS-VCS-1**

**System;** Residual Heat Removal

**Valve(s);** 2RHS\*AOV16A, B, C  
2RHS\*AOV39A, B  
2RHS\*MOV23A, B  
2RHS\*MOV24A, B, C  
2RHS\*MOV40A, B  
2RHS\*MOV67A, B  
2RHS\*MOV104  
2RHS\*MOV112  
2RHS\*MOV113

**Category:** A (MOV's)  
AC (AOV's)

**Class:** 1

**Function:** Reactor coolant system pressure isolation valves and RHS system high to low pressure isolations.

**Quarterly Test Requirements:** Exercise and stroke time (All MOV's). Verify forward and reverse flow operability (All AOV's).

**Cold Shutdown Test Justification:** The AOV's are testable check valves that can only be operated when differential pressure across the valve is zero. The MOV's are interlocked to prevent them from opening when the reactor is at a higher pressure than the design of the low pressure RHS piping. These conditions for operation of these valves cannot be achieved during normal plant operation.

**Quarterly Partial Stroke Testing:** Partial stroke exercising results in the same situation as full stroke exercising.

**Cold Shutdown Testing:** All required quarterly testing listed above will be performed.



**COLD SHUTDOWN TEST JUSTIFICATION RHS-VCS-2**

**System;** Residual Heat Removal

**Valve(s);** 2RHS\*V143

**Category:** C

**Class:** 1

**Function:** RHR system reactor vessel head spray line check valve.

**Quarterly Test Requirements:** Verify forward flow operability.

**Cold Shutdown Test Justification:** To verify forward flow operability of this valve would require the flow of water from the RHS to ICS through valve 2RHS\*MOV104. Due to an interlock on 2RHS\*MOV104, which is not permitted to be defeated by Technical Specifications, testing can be accomplished only at cold shutdown.

**Quarterly Partial Stroke Testing:** Partial stroking would require the same operation conditions as full stroke exercising.

**Cold Shutdown Testing:** Verify forward flow operability.



**COLD SHUTDOWN TEST JUSTIFICATION RHS-VCS-3**

**System;** Residual Heat Removal

**Valve(s);** 2RHS\*MOV22A, B  
2RHS\*MOV80A, B  
2RHS\*PV21A, B

**Category:** A

**Class:** 2

**Function:** ICS to RHS Cross tie for Steam Condensing Mode.

**Quarterly Test Requirements:** Exercise and Stroke time (MOV's). Exercise, stroke time, fail-safe test (PV's).

**Cold Shutdown Test Justification:** These valves provide isolation between the ICS piping which is at reactor pressure and the low pressure RHS piping. Opening of these valves during power operation could overpressurize the low pressure RHS piping and result in an intersystem LOCA.

**Quarterly Partial Stroke Testing:** Partial stroke exercising results in the same situation as full stroke exercising.

**Cold Shutdown Testing:** All required quarterly testing listed above will be performed.



**COLD SHUTDOWN TEST JUSTIFICATION SWP-VCS-1**

**System;** Service Water

**Valve(s);** 2SWP\*MOV3A, B  
2SWP\*MOV19A, B  
2SWP\*MOV50A, B

**Category:** B

**Class:** 3

**Function:** Safety-related to non safety-related isolation valves [2SWP\*MOV3A, 3B, 19A, 19B]. SWS header cross connect valves [2SWP\*MOV50A, B].

**Quarterly Test Requirements:** Exercise and stroke time.

**Cold Shutdown Test Justification:** The closing of 2SWP\*MOV19A, B with the subsequent failure of either valve to reopen would result in a complete loss of cooling to CCP heat exchangers. This loss of cooling would result in loss of cooling to the reactor recirculation pumps and to the drywell cooling system. The closing of 2SWP\*MOV3A, B with subsequent failure of either valve to reopen would result an incomplete loss of cooling to the turbine generator. This loss of cooling water would require tripping the turbine generator and a subsequent power transient that could result in a reactor trip. Since SWP is normally cross connected and the above loads are supplied from the A header prior to closing either 2SWP\*MOV50A or 50B a major shifting of SWP loads must be performed. Since this shifting of loads would effect both safety related SWP trains the potential negative effect to overall plant safety exceeds any benefit resulting from stroking these valves.

**Quarterly Partial Stroke Testing:** The operation circuitry of these valves only permits full stroke operation.

**Cold Shutdown Testing:** Exercise and stroke time.



**COLD SHUTDOWN TEST JUSTIFICATION WCS-VCS-1**

**System:** Reactor Water Cleanup

**Valve(s):** 2WCS\*MOV102  
2WCS\*MOV112  
2WCS\*MOV200

**Category:** A

**Class:** 1

**Function:** Reactor Water Cleanup system primary containment isolation valves.

**Quarterly Test Requirements:** Exercise and stroke time.

**Cold Shutdown Test Justification:** Failure of these valves in the closed position during normal operation would result in the loss of reactor coolant chemistry control. Reactor coolant water chemistry control is required during all normal operating modes. Failure to maintain water chemistry control would result in a forced shutdown of the reactor. The inadvertent opening of these valves prior to system warm-up would result in thermal shock to the reactor water cleanup system.

**Quarterly Partial Stroke Testing:** The operating circuitry of these valves only permits full stroke operation.

**Cold Shutdown Testing:** Exercise and stroke time.



APPENDIX B

PUMP INSERVICE TESTING PROGRAM  
RELIEF REQUESTS



RELIEF REQUEST NO. GPRR-1

**Pump(s):** All safety-related pumps

**Class:** 2 and 3

**Testing Requirements:** Measure vibration amplitude displacement quarterly

**Basis for Relief:** NMP2 proposes an alternate program which, based on survey conducted of existing plants vibration programs and a review of pump vibration testing literature, provides a significant increase in the predictive capability. The proposed program is based on vibration readings measured in velocity units rather than vibration amplitude in mils displacement. This technique is an industry accepted method which is more sensitive to small changes that are indicative of developing mechanical problems and hence more meaningful. Velocity measurements, in addition to detecting high amplitude vibrations that indicate a major mechanical problem, provide an improved ability to detect equally harmful low-amplitude, high-frequency vibrations resulting from misalignment, imbalance, or bearing wear that usually go undetected by simple displacement measurements.

**Alternate Testing:** Pump vibration measurements will be in vibration velocity (in/sec). Acceptance criteria is provided in Tables 1 and 2 of this relief request.

Table 1: Vibration, Velocity (in/sec), Acceptance Criteria for Centrifugal Pumps\*

	<u>Acceptable Range</u>	<u>Alert Range</u>	<u>Required Action</u>
ECCS Systems	0-2.5V <sub>r</sub> or 0-.3 in/sec	>2.5V <sub>r</sub> -5V <sub>r</sub> or >.3 in/sec	>5V <sub>r</sub> or >.3 in/sec
Non-ECCS Systems	0-2.5V <sub>r</sub> or 0-.325 in/sec	>2.5V <sub>r</sub> -6V <sub>r</sub> or >.325-.7 in/sec	>6V <sub>r</sub> or >.7 in/sec

\*Note: The most limiting of the two ranges given is applicable.

Table 2: Vibration Velocity (in/sec), Acceptance Criteria for Positive Displacement Pumps

<u>Acceptable Range</u>	<u>Alert Range</u>	<u>Required Action</u>
0-2.5V <sub>r</sub>	>2.5V <sub>r</sub>	>6V <sub>r</sub>



RELIEF REQUEST NO. GPRR-2

**Pump(s):** All safety related pumps

**Class:** 2 and 3

**Testing Requirements:** Table IWP-3100-2 Allowable Ranges of Test Quantities

**Basis for Relief:** NMP2 proposes alternate high limits to those contained in Table IWP-3100-2 for the differential pressure ( $\Delta P$ ) and flowrate (Q) parameters. The alternate limits shown in the table below increases the high required action range for these parameters to 1.10 times the reference value and eliminates the high alert range. Since the primary reason for pump testing is to insure pump operability by the detection of degradation in relation to an established reference value, a change in the high limit will not impair the ability to detect pump degradation. Furthermore, these alternate limits are consistent with the limits contained in Draft 9 of ANSI/ASME OM-6.

**Alternate Testing:** Acceptance criteria for  $\Delta P$  and Q is provided in the table below.

<u>Test Parameter</u>	<u>Acceptable Range</u>	<u>Alert Range</u>		<u>Required Action Range</u>	
		<u>Low</u>	<u>High</u>	<u>Low</u>	<u>High</u>
$\Delta P$ All Pumps	.93 to 1.10 $\Delta P_r$	.90 to <.93 $\Delta P_r$	N/A	<.90 $\Delta P_r$	>1.10 $\Delta P_r$
Q All Pumps	.94 to 1.10 $Q_r$	.90 to <.94 $Q_r$	N/A	<.90 $Q_r$	>1.10 $Q_r$



RELIEF REQUEST NO. GPRR-3

**Pump(s):** All safety related pumps

**Class:** 2 and 3

**Testing Requirements:** Measure bearing temperature yearly

**Basis for Relief:** The measuring of bearing temperatures along with vibration monitoring are both means of determining the mechanical condition of a pump. However, the condition of a pump bearing would have to seriously degrade to cause a detectable rise of temperature on the bearing housing. With the improved vibration monitoring program employed at NMP2, the ability to detect very small changes in the mechanical condition of a pump exists. Therefore, any degradation of a bearing would be detected before an increase of temperature on the bearing housing occurred.

**Alternate Testing:** Pump mechanical condition will be determined by quarterly vibration monitoring. Bearing temperatures will not be measured.



**RELIEF REQUEST NO. EGF-PRR-1**

**System:** Standby Diesel Generator (Fuel oil)

**Pump(s):** 2EGF\*P1A, B, C, D  
2EGF\*P2A, B

**Class:** 3

**Function:** Transfer diesel fuel oil from the storage tank to the day tank.

**Testing Requirements:** Measure pump inlet and differential pressures.

**Basis for Relief:** This pump is located above the storage tank fluid level and is designed to be a self priming negative NPSH pump. A pressure tap has not been provided to measure pump inlet or differential pressure.

**Alternate Testing:** Pump outlet pressure is measured in accordance with the Code and flow rate is determined by measuring the day tank level versus time during pump testing. Outlet pressure and flow rate will be used to evaluate pump performance.



RELIEF REQUEST NO. 2SLS-PRR-1

**System:** Standby Liquid Control

**Pump(s):** 2SLS\*PIA, PIB

**Class** 2

**Function:** Inject borated solution into the reactor for emergency shutdown.

**Testing Requirements:** In accordance with IWP-4600, flow rate shall be measured using a rate or quantity gravity meter installed in the pump test circuit. The meter may be in any class that provides an overall readout repeatability of  $\pm 2$  percent of full scale.

**Basis for Relief:** These pumps test circuits are not provided with in-place flow meters. Flow measurement for these pumps will be accomplished by use of a clamp on ultrasonic flow meter with a full scale repeatable accuracy of  $\pm 3$  percent. The  $\pm 3$  percent accuracy exceeds the allowable instrument accuracy, however, this small reduction in accuracy will not provide a significant reduction in the ability to determine pump operability.

**Alternate Testing:** Flow rate will be measured using a clamp on ultrasonic flow meter with a repeatable full scale accuracy of  $\pm 3$  percent.



RELIEF REQUEST NO. 2SWP-PRR-1

**System:** Service Water

**Pump(s):** 2SWP\*P2A, B

**Class:** 3

**Function:** To operate in conjunction with temperature control valves [2SWS\*TV35A, B] to provide the recirculation of service water through chillers [2HVK\*CHL1A, B] to maintain inlet temperature and flow through the chillers above the minimum values necessary for proper operation of the Control Building Chilled Water System (HVK).

**Testing Requirements:** Measure pump inlet pressure, differential pressure, flow rate and vibration.

**Basis for Relief:** Since these pumps perform a control function, the operating parameters are constantly changing due to varying temperatures and pressures in the SWP supply and varying load conditions in the HVK system. Due to these varying operational conditions it is very difficult to obtain meaningful data for the parameters required by IWP. Since these pumps are integral to the operation of the HVK system NMP2 has determined that the normal monitoring of the HVK system for proper operation, insuring that chillers [2HVK\*CHL1A, B] inlet temperatures and flow rates are maintained above the minimum required values, and continued quarterly monitoring of the pumps for vibration velocity to insure mechanical integrity will meet the intent of IWP.

**Alternate Testing:** Normal monitoring of HVK system operation and insuring that 2HVK\*CHL1A, B inlet temperature and flow rate are maintained above the minimum required valves. Continued monitoring of pump vibration velocity in accordance with the acceptance criteria contained in GPRR-1.



APPENDIX C  
VALVE INSERVICE TESTING  
PROGRAM RELIEF REQUESTS



RELIEF REQUEST NO. GVRR-1

**Valves:** Containment Isolation Valves

**Category:** A

**Class:** 1, 2

**Testing Requirements:** Leak rate test in accordance with Subsection IWV-3420.

**Basis for Relief:** IWV-2200(a) defines Category A valves as "valves for which seat leakage is limited to a specified maximum amount in the closed position of fulfillment of their function." The intent of the Code requirement is to verify that valve leakage is limited to an acceptable value. For containment isolation valves, an acceptable total allowed leakage rate has been established in compliance with the requirements of 10CFR50, Appendix J. Performance of Appendix J, leak rate testing fulfills the intent of Section XI, Category A valve seat leak testing for containment isolation valves.

**Alternate Testing:** Containment isolation valves will be leak rate testing in accordance with Technical Specification 3/4.6.3 "Primary Containment Isolation Valves".



RELIEF REQUEST NO. GVRR-2

**Valves:** Excess Flow Check Valves

**Category:** AC

**Class:** 2

**Testing Requirements:** Quarterly Operability Testing

**Basis for Relief:** Excess flow check valves are installed on instrument lines penetrating containment in accordance with Regulatory Guide 1.11. Functional testing of these valves to verify closure can be accomplished by the process of venting the instrument side of the valve while the process side is under pressure. Such testing is required by Technical Specification 4.6.3.4 at least once every 18 months. Testing on a more frequent basis is not practical since the associated instruments are in use during plant operation and cold shutdown conditions.

**Alternate Testing:** Functional testing will be performed at least once every 18 months per Technical Specification 4.6.3.4.



RELIEF REQUEST NO. GVRR-3

**Valves:** Rapid actuating power-operated valves with stroke times of 5 sec or less.

**Category:** A, B

**Testing Requirements:** IWV-3417 requires corrective action if the measured stroke time for a valve that normally strokes in 10 sec or less varies by 50 percent from the last measured stroke time. IWV-3413 allows measurement to the nearest sec for stroke times of 10 sec or less.

**Basis for Relief:** For rapid actuating power-operated valves, the application of the above criteria could result in requiring corrective action when the valves are functioning normally. These valves generally are small air- and solenoid- operated valves which, because of their size and actuator types, stroke very quickly. Operating history on this type of valve indicates that they generally either operate immediately or fail to operate in a reasonable length of time. The intent of the referenced Code sections is to track valve stroke time as a means of detecting valve degradation. This type of valve does not lend itself to this tracking technique.

**Alternate Testing:** A maximum stroke time of 5 sec will be specified for each rapid actuating valve. If the valve strokes in 5 sec or less, it will be considered acceptable and no corrective action will be required. If the valve exceeds 5 sec, it will be considered inoperable and the appropriate corrective action will be taken.



**RELIEF REQUEST NO. CSH-VRR-1**

**System:** High Pressure Core Spray

**Valve(s):** 2CSH\*V59

**Category:** C

**Class:** 2

**Function:** Condensate Storage Tank Supply Header Check Valve.

**Quarterly Test Requirement:** Verify Forward and Reverse Flow Closure

**Basis for Relief:** System design does not include provisions for verification of reverse flow closure.

**Alternate Testing:** Verify forward flow operability quarterly. Disassemble and inspect valve internals every refueling outage.



**RELIEF REQUEST NO. FWS-VRR-1**

**System:** Feedwater

**Valve(s):** 2FWS\*V12A, B

**Category:** AC

**Class:** 1

**Function:** Feedwater system inside primary containment isolation valves.

**Quarterly Test Requirement:** Verify reverse flow closure.

**Basis for Relief:** Verification of reverse flow closure of these valves during normal operation would require a significant reduction in power and stopping one loop of feedwater flow. Isolation of one feedwater loop during normal operation would introduce undesirable operational transients that could result in a reactor scram. It is not practical during cold shutdown to isolate and drain the feedwater lines for this valve test. The only method available to verify reverse flow closure is by valve leak testing during Appendix J, Type C testing at refueling.

**Alternate Testing:** Reverse flow closure will be verified during Appendix J, Type C testing during refueling outages.



RELIEF REQUEST NO. GSN-VRR-1

**System:** Nitrogen

**Valve(s):** 2GSN\*V170

**Category:** AC

**Class:** 2

**Function:** TIP mechanism nitrogen purge primary containment isolation valves.

**Quarterly Test Requirement:** Verify reverse flow closure.

**Basis for Relief:** The only method available to verify reverse flow closure is by valve leak rate testing during Appendix J, Type C testing at refueling.

**Alternate Testing:** Reverse flow closure will be verified during Appendix J, Type C testing during refueling outages.



**RELIEF REQUEST NO. HCS-VRR-1**

**System:** DBA Hydrogen Recombiner

**Valve(s):** 2HCS\*MOV26A, B

**Category:** B

**Class:** 2

**Function:** Skid cooling water block valves

**Quarterly Test Requirement:** Exercise and Stroke Time

**Basis for Relief:** The skid cooling water block valves are controlled by an interlock with the gas blower operation. They will automatically stroke open when the gas blower starts and will close when the blower shuts off, and cannot be manually controlled. This interlock is designed to prevent water from entering the recombiner when it is not operating. Flooding of the recombiner will result in wetting down the in-line blower motor and make the unit inoperable.

**Alternate Testing:** Exercise and stroke valves twice a year during the scheduled 6 month operability testing of the recombiner.



RELIEF REQUEST NO. IAS-VRR-1

**System:** Instrument Air

**Valve(s):** 2IAS\*V448  
2IAS\*V449

**Category:** AC

**Class:** 2

**Function:** Instrument air system primary containment isolation valves.

**Quarterly Test Requirement:** Verify reverse flow closure.

**Basis for Relief:** The only method available to verify reverse flow closure is by valve leak testing during Appendix J, Type C testing at refueling.

**Alternate Testing:** Reverse flow closure will be verified during Appendix J, Type C testing during refueling outages.



RELIEF REQUEST NO. IAS-VRR-2

**System:** Instrument Air

**Valve(s):**

2IAS*V421	2IAS*V1601
2IAS*V431	2IAS*V1602
2IAS*V471	2IAS*V1603
2IAS*V526	2IAS*V1604
2IAS*V546	2IAS*V1605
2IAS*V571	2IAS*V1606
2IAS*V581	2IAS*V1607
	2IAS*V1608

**Category:** AC

**Class:** 3

**Function:** Main steam safety relief, ADS valve accumulator and MSIV accumulator inlet air check valves.

**Quarterly Test Requirement:** Verify reverse flow closure.

**Basis for Relief:** To verify reverse flow closure requires isolating the instrument air system and entering the primary containment. The instrument air system is required for normal operation and cannot be isolated until refueling.

**Alternate Testing:** Reverse flow closure will be verified during refueling outages.



RELIEF REQUEST NO. ICS-VRR-1

**System:** Reactor Core Isolation Cooling

**Valve(s):** 2ICS\*V39  
2ICS\*V40

**Category:** C


**Class:** 2

**Function:** RCIC turbine exhaust to suppression pool vacuum breaker check valves.

**Quarterly Test Requirement:** Verify forward flow operability.

**Basis for Relief:** System design does not include provisions to allow for quarterly verification of forward flow operability. The only method available is to use a special air test used at refueling during Appendix J, Type C seat leak testing of valves 2ICS\*MOV148 and 2ICS\*MOV164.

**Alternate Testing:** Valves will be tested for forward flow operability at refueling by a special air test performed in conjunction with the Appendix J, Type C seat leak testing of valves 2ICS\*MOV148 and 2ICS\*MOV164.



RELIEF REQUEST NO. ICS-VRR-2

**System:** Reactor Core Isolation Cooling

**Valve(s):** 2ICS\*V28

**Category:** C

**Class:** 2

**Function:** ICS Pump Suction From Suppression Pool Check Valve.

**Quarterly Test Requirement:** Verify forward flow operability.

**Basis for Relief:** Full stroke forward flow exercising of this valve during any mode of operation would require injecting poor quantity suppression pool water into either the reactor vessel or the condensate storage tank which would result in an undesirable water chemistry condition. The valve can be exercised by returning flow to the suppression pool via the mini-flow line, however, due to the smaller line size of the mini-flow, the flow rate that could be obtained would result in only a partial opening of the valve.

**Alternate Testing:** Partial forward flow exercise by recirculating water to the suppression pool via the mini-flow line at cold shutdown per ICS-VCS-4.



RELIEF REQUEST NO. MSS-VRR-1

**System:** Main Steam

**Valve(s):** 2MSS\*PSV121  
2MSS\*PSV126  
2MSS\*PSV127  
2MSS\*PSV129  
2MSS\*PSV130  
2MSS\*PSV134  
2MSS\*PSV137

**Category:** BC

**Class:** 1

**Function:** ADS valves

**Quarterly Test Requirement:** Exercise and failsafe

**Basis for Relief:** If the valves fail to reclose after testing, the plant would be placed in a LOCA condition. Stroke time is a function of reactor pressure and, therefore, shall not be measured during exercise testing. In addition, a recent study (BWR Owner's Group Evaluation of NUREG-0737, Item II.K.3.16, Reduction of Challenges and Failures of Relief Valves) recommends that the number of ADS openings be reduced as much as possible. Based on this study and the potential for causing a possible LOCA condition, exercise testing of the ADS valves will be delayed to refueling.

**Alternate Testing:** Exercise and failsafe during restart after refueling.



RELIEF REQUEST NO. RCS-VRR-1

**System:** Reactor Coolant (recirculation)

**Valve(s):** 2RCS\*V59A, B  
2RCS\*V60A, B  
2RCS\*V90A, B

**Category:** AC

**Class:** 2

**Function:** Reactor coolant recirculation pump seal water, primary containment isolation valves.

**Quarterly Test Requirement:** Verification of reverse flow closure.

**Basis for Relief:** To verify reverse flow closure would require stopping seal water flow to the pumps. The interruption of seal water flow, even for a short time, can result in extensive damage to the pump seals. Due to system design, the only method available to verify reverse flow closure is by valve leak testing during Appendix J, Type C testing at refueling.

**Alternate Testing:** Reverse flow closure will be verified during Appendix J, Type C testing during refueling outages.



RELIEF REQUEST NO. RDS-VRR-1

**System:** Control Rod Drive Hydraulic

**Valve(s):** 2RDS\*AOV126 (all 185 HCU's)  
2RDS\*AOV127 (all 185 HCU's)  
2RDS\*V114 (all 185 HCU's)

**Category:** B [2RDS\*AOV126, 127]  
C [2RDS\*V114]

**Class:** 2

**Function:** CRD scram valves

**Quarterly Test Requirement:** Exercise, stroke time, and fail-safe test [2RDS\*AOV126, 127]  
Verify forward flow operability [2RDS\*V114]

**Basis for Relief:** Individual valve testing is not possible without causing a control rod scram with a resulting change in core reactivity. Quarterly testing of these valves would violate plant technical specifications which govern the methods and frequency of reactivity changes. The technical specification for control rod scram insertion time testing meets the intent of Section XI testing requirements.

**Alternate Testing:** The control rod scram insertion time testing required by Technical Specification 4.1.3.2 will be performed in lieu of the Section IX testing. Testing will be performed at the frequency specified by the Technical Specification.



**RELIEF REQUEST NO. RDS-VRR-2**

**System:** Control Rod Drive Hydraulic

**Valve(s):** 2RDS\*V115 (all 185 HCU's)

**Category:** C

**Class:** 2

**Function:** Scram accumulator charging and drive water line check valves.

**Quarterly Test Requirement:** Verify reverse flow closure.

**Basis for Relief:** Verification of reverse flow closure requires securing the CRD pumps, depressurizing the header, and monitoring the individual accumulator pressure and alarm to verify that the valves have closed on reverse flow. This would violate plant technical specifications and could result in a plant scram.

**Alternate Testing:** Verification of reverse flow closure will be performed during a refueling outage when the header can be depressurized without a possible plant scram. Testing will be done during the performance of Technical Specification 4.1.3.5, by depressurizing the header and monitoring the individual accumulator pressure and alarm to verify that the valves have closed on reverse flow.



**RELIEF REQUEST NO. RDS-VRR-3**

**System:** Control Rod Drive Hydraulic

**Valve(s):** 2RDS\*V138 (all 185 HCU's)

**Category:** C

**Class:** 2

**Function:** Cooling water line to HCU check valve

**Quarterly Test Requirement:** Verify reverse flow closure.

**Basis for Relief:** Individual valve testing is not possible without causing an individual control rod scram with a resulting change in core reactivity. Quarterly testing of these valves would violate plant technical specifications which govern the methods and frequency of reactivity changes. Operability is demonstrated by proper CRD temperature, insertion, and withdrawal times.

**Alternate Testing:** Proper CRD insertion and withdrawal times during every refueling outage prior to startup along with the constant monitoring of proper CRD temperature demonstrates proper operation of these valves. In addition, the CRD's are jogged up and down one notch on a weekly basis.



RELIEF REQUEST NO. SLS-VRR-1

**System:** Standby Liquid Control

**Valve(s):** 2SLS\*MOV5A, B  
2SLS\*V10

**Category:** AC

**Class:** 1

**Function:** SLS injection inside and outside containment isolation valves.

**Quarterly Test Requirement:** Verify forward and reverse flow operability

**Basis for Relief:** Verifying forward flow operability during normal operation would require firing a squib valve and injecting water into the reactor coolant system using the SLS pumps. Injecting water during normal operation could result in adverse plant conditions such as changes in reactivity, power transients, thermal shock-induced cracking, and a possible plant trip. The only method available to verify reverse closure of valve 2SLS\*V10 is by Appendix J, Type C seat leak testing at refueling.

**Alternate Testing:** Verify forward flow operability at refueling during the SLS injection test. Reverse flow closure of valve 2SLS\*V10 will be verified during Appendix J, Type C testing during refueling outages. Reverse flow closure of valves 2SLS\*MOV5A, B will be verified quarterly using the motor operators.



RELIEF REQUEST NO. SLS-VRR-2

**System:** Standby Liquid Control

**Valve(s):** 2SLS\*V12  
2SLS\*V14

**Category:** C

**Class:** 2

**Function:** SLS Pump Discharge Check Valves.

**Quarterly Test Requirement:** Verify reverse flow operability quarterly.

**Basis for Relief:** Verifying reverse flow operability during normal operation would require both SLS loops to be cross connected. This would render the SLS inoperable since both pumps would be lined up to discharge to test tank, not the reactor vessel.

**Alternate Testing:** Verify reverse flow operability at refueling during the SLS injection test.



**RELIEF REQUEST NO. SWP-VRR-1**

**System:** Service Water

**Valve(s):** 2SWP\*MOV77A, B

**Category:** B

**Class:** 3

**Function:** Traveling water screen bypass for SWP.

**Quarterly Testing Requirement:** Exercise and stroke time.

**Basis for Relief:** These valves open automatically when the traveling screens fail and cause the screenwall level to decrease. When open, the valves permit water to bypass the traveling water screens. During this time, debris from Lake Ontario, i.e., twigs, leaves, or marine life, may enter the service water system. To prevent fouling of safety-related service water components, these valves will be exercised during refueling when the reduced demand on SWP would allow stopping flow thru the associated screenwell.

**Alternate Testing:** Exercise and stroke time during refueling outage.



RELIEF REQUEST NO. SWP-VRR-2

**System:** Service Water

**Valve(s):** 2SWP\*V202A  
2SWP\*V1024  
2SWP\*V1025  
2SWP\*V1027

**Category:** C

**Class:** 3

**Function:** Flow isolation to prevent water hammer on pump restart after trip.

**Quarterly Test Requirement:** Forward and reverse flow exercise.

**Basis for Relief:** Reverse flow closure of the valves during normal plant operation is accomplished by isolation of either SWP safety-related division and by tripping all pumps on the isolated division. Isolation of any division would result in an undesirable transient which could cause a trip of the turbine generator or cause a high drywell pressure condition which would lead to a reactor scram. Therefore, reverse flow closure will be performed during refueling when demand for SWP is at a minimum.

**Alternate Testing:** Reverse flow exercise during refueling outages; forward flow exercise quarterly.



RELIEF REQUEST NO. SWP-VRR-3

**System:** Service Water

**Valve(s):** 2SWP\*V1002A, B

**Category:** C

**Class:** 3

**Function:** Service water make-up to spent fuel pool check valves.

**Quarterly Test Requirement:** Verify forward flow operability.

**Basis for Relief:** Full stroke forward flow exercising of these valves during any modes of operation would require injecting service water into the spent fuel pool which would have an undesirable effect on spent fuel pool chemistry. However, partial stroking of these valves can be performed without injecting water into the spent fuel pool by using installed test connections.

**Alternate Testing:** Partial forward flow exercising of these valves will be performed quarterly using the installed test connections.



APPENDIX D  
PUMP INSERVICE TESTING  
PROGRAM TABLES



APPENDIX D  
FIRST TEN YEAR INTERVAL  
PUMP INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

PUMP MARK NUMBER	CODE CLASS	P & ID	COORD	PARAMETERS	RELIEF	REMARKS
2CSH*P1	2	33B	H-7	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, MOTOR VIB TO BE TAKEN EVERY 92 DAYS, PER FSAR QUESTION 271-10, GPRR-3
2CSL*P1	2	32A	B-8	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, MOTOR VIB TO BE TAKEN EVERY 92 DAYS, PER FSAR QUESTION 271-10, GPRR-3
2EGF*P1A	3	104C	E-6	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, EGF-PRR-1, GPRR-3
2EGF*P1B	3	104B	E-8	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, EGF-PRR-1, GPRR-3
2EGF*P1C	3	104C	C-6	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, EGF-PRR-1, GPRR-3
2EGF*P1D	3	104B	C-8	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, EGF-PRR-1, GPRR-3
2EGF*P2A	3	104B	E-4	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, EGF-PRR-1, GPRR-3
2EGF*P2B	3	104B	C-4	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, EGF-PRR-1, GPRR-3
2HVK*P1A	3	53A	C-6	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2HVK*P1B	3	53A	C-10	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2ICS*P1	2	35D	G-9	SPEED, INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2RHS*P1A	2	31F	D-7	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3, MOTOR VIB TO BE TAKEN EVERY 92 DAYS, PER FSAR QUESTION 271-10
2RHS*P1B	2	31E	E-2	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3, MOTOR VIB TO BE TAKEN EVERY 92 DAYS, PER FSAR QUESTION 271-10
2RHS*P1C	2	31G	D-6	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3, MOTOR VIB TO BE TAKEN EVERY 92 DAYS, PER FSAR QUESTION 271-10




APPENDIX D  
FIRST TEN YEAR INTERVAL  
PUMP INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

PUMP MARK NUMBER	CODE CLASS	P & ID	COORD	PARAMETERS	RELIEF	REMARKS
2SFC*P1A	3	38B	E-3	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2SFC*P1B	3	38A	E-10	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2SLS*P1A	2	36A	H-5	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, SLS-PRR-1, GPRR-3
2SLS*P1B	2	36A	H-9	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, SLS-PRR-1, GPRR-3
2SWP*P1A	3	11B	C-9	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2SWP*P1B	3	11A	H-5	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2SWP*P1C	3	11A	H-10	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2SWP*P1D	3	11A	D-5	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2SWP*P1E	3	11B	H-9	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2SWP*P1F	3	11A	D-10	INLET PRESS, DIFF PRESS, FLOW, VIB VEL	Y	GPRR-1, GPRR-2, GPRR-3
2SWP*P2A	3	11J	J-6	VIB VEL	Y	GPRR-1, GPRR-3, SWP-PRR-1
2SWP*P2B	3	11J	E-6	VIB VEL	Y	GPRR-1, GPRR-3, SWP-PRR-1



APPENDIX E  
VALVE INSERVICE  
TESTING PROGRAM  
TABLES



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : AAS, BREATHING AIR

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
								HRM	SAF	FAL				
2AAS*HCV134	2 20E	D-3	A	P	02.0	GLV	HAA	LC	LC	-	Y	LJ-R, PI-T	Y	GVRR-1
2AAS*HCV135	2 20E	C-7	A	P	02.0	GLV	HAA	LC	LC	-	Y	LJ-R, PI-T	Y	GVRR-1
2AAS*HCV136	2 20E	D-3	A	P	02.0	GLV	HAA	LC	LC	-	Y	LJ-R, PI-T	Y	GVRR-1
2AAS*HCV137	2 20E	E-7	A	P	02.0	GLV	HAA	LC	LC	-	Y	LJ-R, PI-T	Y	GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2  
COOLING WATER

SYSTEM : CCP, REACTOR BUILDING CLOSED-LOOP

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2CCP*A0V37A	3 13E	J-2	B	A	1.50	GTV	AOA	0 C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N	
2CCP*A0V37B	3 13E	D-8	B	A	02.0	GTV	AOA	0 C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N	
2CCP*A0V38A	3 13E	J-4	B	A	1.50	GTV	AOA	0 C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N	
2CCP*A0V38B	3 13E	D-10	B	A	02.0	GTV	AOA	0 C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N	
2CCP*MOV122	2 13C	J-6	A	A	08.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV124	2 13C	I-6	A	A	08.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV14A	3 13E	G-7	B	A	12.0	GTV	MOA	0C C AI	N	FE-Q, ST-Q(C), PI-T	N	
2CCP*MOV14B	3 13E	H-10	B	A	12.0	GTV	MOA	0C C AI	N	FE-Q, ST-Q(C), PI-T	N	
2CCP*MOV15A	2 13D	K-6	A	A	04.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV15B	2 13A	I-7	A	A	04.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV16A	2 13D	K-7	A	A	04.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV16B	2 13A	G-7	A	A	04.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV17A	2 13D	C-7	A	A	04.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV17B	2 13B	E-7	A	A	04.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV18A	3 13E	G-5	B	A	12.0	GTV	MOA	0C C AI	N	FE-Q, ST-Q(C), PI-T	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : CCP, REACTOR BUILDING CLOSED-LOOP COOLING WATER

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
								NRM	SAF	FAL				
2CCP*MOV18B	3 13E	I-8	B	A	12.0	GTV	MOA	0	C	AI	N	FE-Q, ST-0(C), PI-T	N	
2CCP*MOV265	2 13C	B-6	A	A	08.0	GTV	MOA	0	C	AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV273	2 13C	C-6	A	A	08.0	GTV	MOA	0	C	AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV94A	2 13D	C-7	A	A	04.0	GTV	MOA	0	C	AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*MOV94B	2 13B	E-8	A	A	04.0	GTV	MOA	0	C	AI	Y	FE-CS, ST-CS(C), PI-T, LJ-R	Y	SEE GVRR-1, SEE CCP-VCS-2
2CCP*RV170	2 13B	F-7	A, C	A	0.75	REV	SEA	C	0	AI	Y	RT-P2, LJ-R	Y	GVRR-1
2CCP*RV171	2 13A	H-6	A, C	A	0.75	REV	SEA	C	0	AI	Y	RT-P2, LJ-R	Y	GVRR-1



APPENDIX E  
 FIRST TEN YEAR INTERVAL  
 VALVE INSERVICE TESTING PROGRAM TABLE  
 NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : CMS, CONTAINMENT ATMOSPHERE MONITORING

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
								NRH	SAF	FAL	TYPE C			
2CHS*EFV10	2 82A	I-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV1A	2 82A	I-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV1B	2 82A	E-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV3A	2 82A	J-9	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV3B	2 82A	D-9	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV5A	2 82B	I-3	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV5B	2 82B	C-3	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV6	2 82B	I-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV8A	2 82B	I-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV8B	2 82B	C-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV9A	2 82B	I-9	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*EFV9B	2 82B	C-9	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2CHS*S0V24A	2 82A	H-5	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V24B	2 82A	F-5	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V24C	2 82A	I-5	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : CHS, CONTAINMENT ATMOSPHERE MONITORING

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	NRH	SAF	FAL	POSITIONS TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2CHS*S0V24D	2	82A	D-5	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V26A	2	82B	H-5	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V26B	2	82B	D-5	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V26C	2	82B	J-5	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V26D	2	82B	B-5	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V32A	2	82A	J-8	A	A	0.75	GLV	SOA	0C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V32B	2	82A	E-8	A	A	0.75	GLV	SOA	0C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V33A	2	82A	H-8	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V33B	2	82A	F-8	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V34A	2	82B	H-8	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V34B	2	82B	E-8	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V35A	2	82B	J-8	A	A	0.75	GLV	SOA	0C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V35B	2	82B	C-8	A	A	0.75	GLV	SOA	0C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V60A	2	82A	I-3	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1
2CHS*S0V60B	2	82A	D-3	A	A	0.75	GLV	SOA	0	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-3, GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : CMS, CONTAINMENT ATMOSPHERE MONITORING

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL					
2CHS*S0V61A	2	82A	H-3	A	A	0.75	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-3, GVRR-1	
2CHS*S0V61B	2	82A	F-3	A	A	0.75	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-3, GVRR-1	
2CHS*S0V62A	2	82A	I-7	A	A	0.75	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-3, GVRR-1	
2CHS*S0V62B	2	82A	E-7	A	A	0.75	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-3, GVRR-1	
2CHS*S0V63A	2	82A	H-7	A	A	0.75	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-3, GVRR-1	
2CHS*S0V63B	2	82A	F-7	A	A	0.75	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-3, GVRR-1	
2CHS*S0V74A	2	82A	K-4	A	A	0.75	GLV	SOA	C	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2CHS*S0V74B	2	82A	C-4	A	A	0.75	GLV	SOA	C	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2CHS*S0V75A	2	82A	K-9	A	A	0.75	GLV	SOA	C	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2CHS*S0V75B	2	82A	C-9	A	A	0.75	GLV	SOA	C	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2CHS*S0V76A	2	82A	L-4	A	A	0.75	GLV	SOA	C	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2CHS*S0V76B	2	82A	B-4	A	A	0.75	GLV	SOA	C	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2CHS*S0V77A	2	82A	L-9	A	A	0.75	GLV	SOA	C	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2CHS*S0V77B	2	82A	B-9	A	A	0.75	GLV	SOA	C	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : CPS, PRIMARY CONTAINMENT PURGE

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2CPS*A0V104	2	61A	F-5	A	A	14.0	BFV	AOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*A0V105	2	61A	F-7	A	A	12.0	BFV	AOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*A0V106	2	61A	G-5	A	A	14.0	BFV	AOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*A0V107	2	61A	G-7	A	A	12.0	BFV	AOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*A0V108	2	61A	H-5	A	A	14.0	BFV	AOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*A0V109	2	61A	H-7	A	A	12.0	BFV	AOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1
2CPS*A0V110	2	61A	J-5	A	A	14.0	BFV	AOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1
2CPS*A0V111	2	61A	J-7	A	A	12.0	BFV	AOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1
2CPS*SOV119	2	61A	E-8	A	A	02.0	GLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*SOV120	2	61A	E-5	A	A	02.0	GLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*SOV121	2	61A	G-8	A	A	02.0	GLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*SOV122	2	61A	G-5	A	A	02.0	GLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*SOV132	2	61A	F-8	A	A	01.0	GLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2CPS*SOV133	2	61A	K-8	A	A	01.0	GLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, PI-T, LJ-R	Y	GVRR-1
2CPS*V50	2	61A	F-8	A, C	A	1.50	CHV	SEA	C	C	-	Y	FE-0(R), LJ-R	Y	GVRR-1



REVISION  
05-27-87

APPENDIX E

PAGE: 8

FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : CPS, PRIMARY CONTAINMENT PURGE

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
								NRM	SAF	FAL	TYPE C			
2CPS*V51	2 61A	J-8	A, C	A	1.50	CHV	SEA	C	C	-	Y	FE-0(R), LJ-R	Y	GVRR-1



3



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : CSH, HIGH-PRESSURE CORE SPRAY (HPCS)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2CSH*AOV108	1	33A	I-2	A, C	A	12.0	TCV	SEA	C	OC	-	Y	FE-CS(F&R), PI-T, LJ-R, LK-R	Y	GVRR-1, SEE CSH-VCS-1
2CSH*EFV1	2	33A	G-6	A, C	A	02.0	CHV	SEA	0	C	-	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2CSH*EFV2	2	33A	G-6	A, C	A	02.0	CHV	SEA	0	C	-	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2CSH*EFV3	2	33A	H-3	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2CSH*HOV101	2	33B	D-9	B	A	14.0	GTV	MOA	0	OC	AI	N	FE-0, ST-0(0&C), PI-T	N	
2CSH*HOV105	2	33B	G-5	A	A	04.0	GTV	MOA	C	OC	AI	Y	PI-T, LJ-R, FE-0, ST-0(0&C)	Y	GVRR-1, GVRR-3
2CSH*HOV107	1	33A	G-2	A	A	12.0	GTV	MOA	C	OC	AI	Y	FE-CS, ST-CS(0&C), PI-T, LJ-R, LK-R	Y	GVRR-1, SEE CSH-VCS-2
2CSH*HOV110	2	33B	G-3	B	A	20.0	GLV	MOA	C	C	AI	N	FE-0, ST-0(C), PI-T	N	
2CSH*HOV111	2	33A	F-4	A	A	12.0	GLV	MOA	C	C	AI	Y	FE-0, ST-0(C), PI-T, LJ-R	Y	GVRR-1
2CSH*HOV112	2	33B	F-3	B	A	20.0	GLV	MOA	C	C	AI	N	PI-T, FE-0, ST-0(C)	N	
2CSH*HOV118	2	33A	J-9	A	A	18.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2CSH*RV113	2	33B	F-8	C	A	0.75	REV	SEA	C	0	AI	N	RT-P2	N	
2CSH*RV114	2	33B	J-5	C	A	0.75	REV	SEA	C	0	AI	N	RT-P2	N	
2CSH*V16	2	33A	I-10	C	A	30.0	CHV	SEA	OC	OC	-	N	FE-CS(F&R)	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : CSH, HIGH-PRESSURE CORE SPRAY (HPCS)

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ. (DIR)	RELIEF	REMARKS
								NRH	SAF	FAL	TYPE C			
2CSH*V17	2 33B	J-8	C	A	03.0	CHV	SEA	0C	C	-	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE.
2CSH*V55	2 33B	J-8	C	A	03.0	CHV	SEA	0C	C	-	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE.
2CSH*V59	2 33B	D-9	C	A	14.0	CHV	SEA	0	0C	-	N	FE-Q(F), FE-R(R)	Y	SEE CSH-VRR-1
2CSH*V7	2 33B	E-5	C	A	04.0	CHV	SEA	C	0	-	N	FE-Q(F)	N	
2CSH*V9	2 33B	I-5	C	A	16.0	CHV	SEA	C	0	-	N	FE-Q(F&R)	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : CSL, LOW-PRESSURE CORE SPRAY (LPCS)

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2CSL*A0V101	1 32A	I-3	A, C	A	12.0	TCV	SEA	C OC AI	Y	FE-CS(F&R), LK-R, LJ-R, PI-T	Y	GVRR-1, SEE CSL-VCS-1
2CSL*EFV1	2 32A	H-5	A, C	A	0.75	CHV	SEA	0 C -	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1
2CSL*FV114	2 32A	E-4	B	A	12.0	GTV	HOA	0 0 AI	N	FE-Q, ST-Q(C), PI-T	N	
2CSL*MOV104	1 32A	H-3	A	A	12.0	GTV	HOA	C OC AI	Y	FE-CS, ST-CS(O&C), LK-R, LJ-R, PI-T	Y	GVRR-1, CSL-VCS-1
2CSL*MOV107	2 32A	C-5	B	A	04.0	GTV	HOA	0 OC AI	N	FE-Q, ST-Q(C), PI-T	N	
2CSL*MOV112	2 32A	G-9	A	A	30.0	BFV	HOA	0 OC AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2CSL*V14	2 32A	D-6	C	A	02.0	CHV	SEA	0C 0 -	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE.
2CSL*V21	2 32A	D-6	C	A	02.0	CHV	SEA	0C 0 -	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE.
2CSL*V4	2 32A	B-3	C	A	16.0	CHV	SEA	C 0 -	N	FE-Q(F)	N	
2CSL*V9	2 32A	E-5	C	A	12.0	CHV	SEA	0 C -	N	FE-Q(F&R)	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : DER, REACTOR BUILDING EQUIPMENT DRAINS

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS	NRM	SAF	FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2DER*EFV31	2 67A	B-6	A, C	A	0.75	CHV	SEA	0 C -	N				PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1
2DER*MOV119	2 67A	C-3	A	A	04.0	GTV	HOA	0 C AI	Y				FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2DER*MOV120	2 67A	C-3	A	A	04.0	GTV	HOA	0 C AI	Y				FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2DER*MOV130	2 67A	C-2	A	A	02.0	GLV	HOA	0 C AI	Y				FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2DER*MOV131	2 67A	C-2	A	A	02.0	GLV	HOA	0 C AI	Y				FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : DFR, REACTOR BUILDING FLOOR DRAINS

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ. (DIR)	RELIEF	REMARKS
	CLASS	P & ID							NRH	SAF	FAL	TYPE C			
2DFR*MOV120	2	63E	E-7	A	A	06.0	GTV	MOA	0	C	AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2DFR*MOV121	2	63E	F-7	A	A	06.0	GTV	MOA	0	C	AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2DFR*MOV139	2	63E	E-6	A	A	03.0	GTV	MOA	0	C	AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2DFR*MOV140	2	63E	F-6	A	A	03.0	GTV	MOA	0	C	AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : EGA, AIR STARTUP - STANDBY DIESEL GENERATOR

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ.(DIR)	RELIEF	REMARKS
								NRM	SAF	FAL	TYPE C			
2EGA*RV125	3 104A	G-3	C	A	40.0	REV	SEA	C	0	-	N	RT-P2	N	
2EGA*RV126	3 104A	H-8	C	A	40.0	REV	SEA	C	0	-	N	RT-P2	N	
2EGA*RV127	3 104A	L-6	C	A	22.0	REV	SEA	C	0	-	N	RT-P2	N	
2EGA*SV111	3 104A	H-6	C	A	01.0	REV	SEA	C	0	-	N	RT-P2	N	
2EGA*SV112	3 104A	H-5	C	A	01.0	REV	SEA	C	0	-	N	RT-P2	N	
2EGA*SV3A	3 104A	C-2	C	A	01.0	REV	SEA	C	0	-	N	RT-P2	N	
2EGA*SV3B	3 104A	C-8	C	A	01.0	REV	SEA	C	0	-	N	RT-P2	N	
2EGA*SV4A	3 104A	C-4	C	A	01.0	REV	SEA	C	0	-	N	RT-P2	N	
2EGA*SV4B	3 104A	C-9	C	A	01.0	REV	SEA	C	0	-	N	RT-P2	N	
2EGA*V29A	3 104A	G-6	C	A	01.0	CHV	SEA	OC	C	-	N	FE-0(R)	N	
2EGA*V29B	3 104A	G-5	C	A	01.0	CHV	SEA	OC	C	-	N	FE-0(R)	N	
2EGA*V62A	3 104A	C-5	C	A	1.50	CHV	SEA	OC	C	-	N	FE-0(R)	N	
2EGA*V62B	3 104A	C-3	C	A	1.50	CHV	SEA	OC	C	-	N	FE-0(R)	N	
2EGA*V63A	3 104A	C-10	C	A	1.50	CHV	SEA	OC	C	-	N	FE-0(R)	N	
2EGA*V63B	3 104A	C-8	C	A	1.50	CHV	SEA	OC	C	-	N	FE-0(R)	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : EGF, STANDBY DIESEL GEN

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ.(DIR)	RELIEF	REMARKS
								NRH	SAF	FAL	TYPE C			
2EGF*V12	3 104C	D-4	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F&R)	N	
2EGF*V13	3 104C	F-5	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F&R)	N	
2EGF*V32	3 104B	D-6	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F&R)	N	
2EGF*V33	3 104B	F-7	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F&R)	N	
2EGF*V52	3 104B	D-2	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F&R)	N	
2EGF*V53	3 104B	F-2	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F&R)	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : FPW, FIRE PROTECTION - WATER

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE ACTUAT		POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
	CLASS	P & ID					TYPE	TYPE	NRH	SAF	FAL				TYPE C
2FPW*S0V218	2	43G	E-8	A	P	02.0	GTV	SEA	C	C	C	Y	LJ-R, PI-T	Y	GVRR-1
2FPW*S0V219	2	43G	E-7	A	P	02.0	GTV	SEA	C	C	C	Y	LJ-R, PI-T	Y	GVRR-1
2FPW*S0V220	2	43G	D-8	A	P	02.0	GTV	SEA	C	C	C	Y	LJ-R, PI-T	Y	GVRR-1
2FPW*S0V221	2	43G	D-7	A	P	02.0	GTV	SEA	C	C	C	Y	LJ-R, PI-T	Y	GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : FWS, FEEDWATER SYSTEM

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2FWS*A0V23A	1 6B	G-2	A, C	A	24.0	TCV	SEA	0 C -	Y	FE-CS(R), PI-T, LJ-R	Y	SEE FWS-VCS-1, SEE GVRR-1
2FWS*A0V23B	1 6B	G-6	A, C	A	24.0	TCV	SEA	0 C -	Y	FE-CS(R), PI-T, LJ-R	Y	SEE FWS-VCS-1, SEE GVRR-1
2FWS*MOV21A	1 6B	E-2	A	A	24.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T	Y	SEE FWS-VCS-2, SEE GVRR-1
2FWS*MOV21B	1 6B	E-6	A	A	24.0	GTV	MOA	0 C AI	Y	FE-CS, ST-CS(C), PI-T	Y	SEE FWS-VCS-2, SEE GVRR-1
2FWS*V12A	1 6B	H-2	A, C	A	24.0	CHV	SEA	0 C -	Y	FE-R(R), LJ-R	Y	SEE FWS-VRR-1, SEE GVRR-1
2FWS*V12B	1 6B	H-2	A, C	A	24.0	CHV	SEA	0 C -	Y	FE-R(R), LJ-R	Y	SEE FWS-VRR-1, SEE GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : GSN, N2 INSERTING

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ. (DIR)	RELIEF	REMARKS
								NRM	SAF	FAL	TYPE C			
2GSN*SOV166	2 105B	J-7	A	A	01.0	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, LJ-R, PI-T	Y	GVRR-3, GVRR-1
2GSN*V170	2 105B	K-7	A, C	A	00.5	CHV	SEA	0	C	-	Y	FE-R(R), LJ-R	Y	GSN-VRR-1, GVRR-1
2GSN*V70A	3 105B	K-2	C	A	01.0	CHV	SEA	CO	C	N	N	FE-Q(R)	N	
2GSN*V70B	3 105B	K-4	C	A	01.0	CHV	SEA	CO	C	N	N	FE-Q(R)	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : GTS, STANDBY GAS TREATMENT

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.	(DIR)	RELIEF	REMARKS
2GTS*AOV101	2	61B	B-9	B	A	30.0	BFV	AOA	C	C	C	N	FE-0, ST-0(0&C), FS-0, PI-T		N	
2GTS*MOV1A	2	61B	C-4	B	A	30.0	BFV	HOA	C	O	AI	N	FE-0, ST-0(O), PI-T		N	
2GTS*MOV1B	2	61B	B-5	B	A	30.0	BFV	HOA	C	O	AI	N	FE-0, ST-0(O), PI-T		N	
2GTS*MOV28A	2	61B	C-8	B	A	08.0	BFV	HOA	O	C	C	N	FE-0, ST-0(0&C), FS-0, PI-T		N	
2GTS*MOV28B	2	61B	J-4	B	A	08.0	BFV	HOA	O	C	C	N	FE-0, ST-0(0&C), FS-0, PI-T		N	
2GTS*MOV2A	2	61B	D-8	B	A	30.0	BFV	HOA	C	OC	C	N	FE-0, ST-0(0&C), FS-0, PI-T		N	
2GTS*MOV2B	2	61B	D-4	B	A	30.0	BFV	HOA	C	OC	C	N	FE-0, ST-0(0&C), FS-0, PI-T		N	
2GTS*MOV3A	2	61B	K-8	B	A	30.0	BFV	HOA	C	OC	C	N	FE-0, ST-0(0&C), FS-0, PI-T		N	
2GTS*MOV3B	2	61B	K-3	B	A	30.0	BFV	HOA	C	OC	C	N	FE-0, ST-0(0&C), FS-0, PI-T		N	
2GTS*MOV4A	2	61B	D-8	B	A	08.0	GTV	HOA	OC	OC	AI	N	FE-0, ST-0(0&C), PI-T		N	
2GTS*MOV4B	2	61B	D-4	B	A	08.0	GTV	HOA	OC	OC	AI	N	FE-0, ST-0(0&C), PI-T		N	
2GTS*S0V102	2	61B	B-8	B	A	02.0	GLV	SOA	C	C	C	N	FE-0, ST-0(0&C), FS-0, PI-T	Y	SEE GVRR-3	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : HCS, DBA HYDROGEN RECOMBINER

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
									NRH	SAF	FAL	TYPE C			
2HCS*MOV1A	2	62A	D-8	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV1B	2	62A	I-8	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV25A	2	62B	J-5	B	A	03.0	GTV	MOA	C	0	AI	N	FE-0, ST-0(0), PI-T	N	
2HCS*MOV25B	2	62B	C-10	B	A	03.0	GTV	MOA	C	0	AI	N	FE-0, ST-0(0), PI-T	N	
2HCS*MOV26A	2	62B	I-3	B	A	01.0	GTV	MOA	C	0	AI	N	FE-S, ST-S(0), PI-T	N	HCS-VRR-1
2HCS*MOV26B	2	62B	C-7	B	A	01.0	GTV	MOA	C	0	AI	N	FE-S, ST-S(0), PI-T	N	HCS-VRR-1
2HCS*MOV2A	2	62A	D-6	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV2B	2	62A	I-6	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV3A	2	62A	D-4	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV3B	2	62A	I-4	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV4A	2	62A	F-8	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV4B	2	62A	H-8	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV5A	2	62A	F-6	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV5B	2	62A	H-6	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1
2HCS*MOV6A	2	62A	F-4	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(0&C), PI-T, LJ-R	Y	GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : HCS, DBA HYDROGEN RECOMBINER

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ. (DIR)	RELIEF	REMARKS
								NRH	SAF	FAL	TYPE C			
2HCS*MOV6B	2 62A	G-4	A	A	03.0	GLV	MOA	C	OC	AI	Y	FE-0, ST-0(O&C), PI-T, LJ-R	Y	GVRR-1
2HCS*SOV10A	2 62A	A-3	B	A	01.0	GLV	SOA	C	0	0	N	FE-0, ST-0(O), FS-0(O), PI-T	Y	GVRR-3
2HCS*SOV10B	2 62A	L-3	B	A	01.0	GLV	SOA	C	0	0	N	FE-0, ST-0(O), FS-0(O), PI-T	Y	GVRR-3
2HCS*SOV11A	2 62A	A-8	B	A	01.0	GLV	SOA	0	C	C	N	FE-0, ST-0(C), FS-0(C), PI-T	Y	GVRR-3
2HCS*SOV11B	2 62A	L-8	B	A	01.0	GLV	SOA	0	C	C	N	FE-0, ST-0(C), FS-0(C), PI-T	Y	GVRR-3



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : HVC, CONTROL BUILDING AIR-CONDITIONING

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRH	SAF	FAL				
2HVC*MOV1A	3 53B	I-7	B	A	18.0	BFV	MOA	0	C	AI	N	FE-0, ST-0(C), PI-T	N	
2HVC*MOV1B	3 53B	I-6	B	A	18.0	BFV	MOA	0	C	AI	N	FE-0, ST-0(C), PI-T	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : HVK, CONTROL BUILDING CHILLED WATER

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL			
2HVK*SOV36A	3	53A	F-3	B	A	03.0	GLV	SOA	0	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N
2HVK*SOV36B	3	53A	F-8	B	A	03.0	GLV	SOA	0	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N
2HVK*V105	3	53A	B-10	C	A	06.0	CHV	SEA	OC	0	-	N	FE-Q(F&R)	N
2HVK*V106	3	53A	B-5	C	A	06.0	CHV	SEA	OC	0	-	N	FE-Q(F&R)	N
2HVK*V12	3	53A	I-10	C	A	0.75	CHV	SEA	OC	C	-	N	FE-Q(R)	N
2HVK*V158	3	53A	F-2	C	A	03.0	CHV	SEA	OC	C	-	N	FE-Q(F&R)	N
2HVK*V163	3	53A	F-7	C	A	03.0	CHV	SEA	OC	C	-	N	FE-Q(F&R)	N
2HVK*V95	3	53A	I-5	C	A	0.75	CHV	SEA	OC	C	-	N	FE-Q(R)	N



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : IAS, INSTRUMENT AIR

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2IAS*EFV200	2	19E	H-10	A,C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1
2IAS*EFV201	2	19E	D-5	A,C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1
2IAS*EFV202	2	19E	G-5	A,C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1
2IAS*EFV203	2	19F	I-8	A,C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1
2IAS*EFV204	2	19F	K-4	A,C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1
2IAS*EFV205	2	19F	B-4	A,C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1
2IAS*EFV206	2	19F	K-9	A,C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1
2IAS*PSE141	3	19L	G-8	C	A	1.0	RD	SEA	C	0	0	N	RD-P3	N	REPLACE EVERY 5YRS - REF OH-1,1981
2IAS*PSE142	3	19L	G-10	C	A	1.0	RD	SEA	C	0	0	N	RD-P3	N	REPLACE EVERY 5YRS - REF OH-1,1981
2IAS*PSE143	3	19L	G-3	C	A	1.0	RD	SEA	C	0	0	N	RD-P3	N	REPLACE EVERY 5YRS - REF OH-1,1981
2IAS*PSE144	3	19L	G-6	C	A	1.0	RD	SEA	C	0	0	N	RD-P3	N	REPLACE EVERY 5YRS - REF OH-1,1981
2IAS*PSE145	3	19H	F-8	C	A	1.0	RD	SEA	C	0	0	N	RD-P3	N	REPLACE EVERY 5YRS - REF OH-1,1981
2IAS*PSE146	3	19H	F-10	C	A	1.0	RD	SEA	C	0	0	N	RD-P3	N	REPLACE EVERY 5YRS - REF OH-1,1981
2IAS*PSE147	3	19L	F-3	C	A	1.0	RD	SEA	C	0	0	N	RD-P3	N	REPLACE EVERY 5YRS - REF OH-1,1981
2IAS*PSE148	3	19L	F-5	C	A	1.0	RD	SEA	C	0	0	N	RD-P3	N	REPLACE EVERY 5YRS - REF OH-1,1981



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : IAS, INSTRUMENT AIR

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			C	TEST FREQ.	(DIR)	RELIEF	REMARKS
								NRM	SAF	FAL					
2IAS*SOV164	2 19D	C-10	A	A	1.50	GLV	SOA	0	OC	C	Y	FE-Q, ST-Q(O&C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2IAS*SOV165	2 19F	C-10	A	A	1.50	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(O&C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2IAS*SOV166	2 19D	C-8	A	A	1.50	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2IAS*SOV167	2 19G	C-7	A	A	1.50	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2IAS*SOV168	2 19G	C-5	A	A	1.50	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2IAS*SOV180	2 19G	D-5	A	A	1.50	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2IAS*SOV184	2 19D	E-8	A	A	1.50	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2IAS*SOV185	2 19G	D-7	A	A	1.50	GLV	SOA	0	C	C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3	
2IAS*SOVX181	3 19D	J-3	B	A	1.50	GLV	SOA	OC	0	C	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GVRR-3	
2IAS*SOVX186	3 19D	J-7	B	A	1.50	GLV	SOA	OC	0	C	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GVRR-3	
2IAS*SOVY181	3 19D	J-4	B	A	0.75	GLV	SOA	OC	0	C	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GVRR-3	
2IAS*SOVY186	3 19D	J-8	B	A	0.75	GLV	SOA	OC	0	C	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GVRR-3	
2IAS*SV19A	3 19D	I-3	C	A	0.75	REV	SEA	C	0	-	N	RT-P2	N		
2IAS*SV19B	3 19D	I-7	C	A	0.75	REV	SEA	C	0	-	N	RT-P2	N		
2IAS*V1601	3 19L	D-6	A,C	A	1.5	CHV	SEA	0	C	C	N	FE-R(F&R)	Y	SEE IAS-VRR-2	
2IAS*V1602	3 19L	D-9	A,C	A	1.5	CHV	SEA	0	C	C	N	FE-R(F&R), LK-R	Y	SEE IAS-VRR-2	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : IAS, INSTRUMENT AIR

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ. (DIR)	RELIEF	REMARKS
								NRH	SAF	FAL	TYPE C			
2IAS*V1603	3 19L	D-2	A,C	A	1.5	CHV	SEA	0	C	C	N	FE-R(F&R), LK-R	Y	SEE IAS-VRR-2
2IAS*V1604	3 19L	D-4	A,C	A	1.5	CHV	SEA	0	C	C	N	FE-R(F&R), LK-R	Y	SEE IAS-VRR-2
2IAS*V1605	3 19H	H-7	A,C	A	1.5	CHV	SEA	0	C	C	N	FE-R(F&R), LK-R	Y	SEE IAS-VRR-2
2IAS*V1606	3 19H	H-9	A,C	A	1.5	CHV	SEA	0	C	C	N	FE-R(F&R), LK-R	Y	SEE IAS-VRR-2
2IAS*V1607	3 19H	H-2	A,C	A	1.5	CHV	SEA	0	C	C	N	FE-R(F&R), LK-R	Y	SEE IAS-VRR-2
2IAS*V1608	3 19H	H-4	A,C	A	1.5	CHV	SEA	0	C	C	N	FE-R(F&R), LK-R	Y	SEE IAS-VRR-2
2IAS*V421	3 19E	C-4	A, C	A	01.2	CHV	SEA	0C	C	-	N	FE-R(F&R), LK-R	Y	IAS-VRR-2
2IAS*V431	3 19E	F-4	A, C	A	01.2	CHV	SEA	0C	C	-	N	FE-R(F&R), LK-R	Y	IAS-VRR-2
2IAS*V448	2 19D	E-10	A, C	A	1.50	CHV	SEA	0	C	-	Y	FE-R(F&R), LJ-R	Y	SEE GVRR-1, SEE IAS-VRR-1
2IAS*V449	2 19F	D-10	A, C	A	1.50	CHV	SEA	0	C	-	Y	FE-R(F&R), LJ-R	Y	SEE GVRR-1, SEE IAS-VRR-1
2IAS*V471	3 19E	G-10	A, C	A	01.2	CHV	SEA	0C	C	-	N	FE-R(F&R), LK-R	Y	IAS-VRR-2
2IAS*V526	3 19F	C-4	A, C	A	01.2	CHV	SEA	0C	C	-	N	FE-R(F&R), LK-R	Y	IAS-VRR-2
2IAS*V546	3 19F	J-4	A, C	A	01.2	CHV	SEA	0C	C	-	N	FE-R(F&R), LK-R	Y	IAS-VRR-2
2IAS*V571	3 19F	G-8	A, C	A	01.2	CHV	SEA	0C	C	-	N	FE-R(F&R), LK-R	Y	IAS-VRR-2
2IAS*V581	3 19F	J-8	A, C	A	01.2	CHV	SEA	0C	C	-	N	FE-R(F&R), LK-R	Y	IAS-VRR-2



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : ICS, REACTOR CORE ISOLATION COOLING (RCIC)

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2ICS*AOV109	2 35B	F-8	B	A	02.0	GLV	AOA	OC C C	N	FE-0, ST-0(C), FS-0, PI-T	Y	SEE GVRR-3
2ICS*AOV110	2 35B	E-8	B	A	02.0	GLV	AOA	OC C C	N	FE-0, ST-0(C), FS-0, PI-T	Y	SEE GVRR-3
2ICS*AOV130	2 35C	D-10	B	A	02.0	GLV	AOA	O C C	N	FE-0, ST-0(C), FS-0, PI-T	N	
2ICS*AOV131	2 35C	D-10	B	A	02.0	GLV	AOA	O C C	N	FE-0, ST-0(C), FS-0, PI-T	N	
2ICS*AOV156	1 35C	G-3	A, C	A	06.0	TCV	SEA	C OC N	Y	FE-CS(F&R), LJ-R, PI-T, LK-R	Y	SEE GVRR-1, SEE ICS-VCS-2
2ICS*AOV157	1 35C	J-3	A, C	A	06.0	TCV	SEA	C OC N	Y	FE-CS(F&R), LJ-R, PI-T, LK-R	Y	SEE GVRR-1, SEE ICS-VCS-2
2ICS*EFV1	2 35A	H-4	A, C	A	0.75	CHV	SEA	O C -	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ICS*EFV2	2 35A	H-4	A, C	A	0.75	CHV	SEA	O C -	N	LJ-R, PI-T, FE-0(F)	Y	GVRR-2, GVRR-1
2ICS*EFV3	2 35A	H-5	A, C	A	0.75	CHV	SEA	O C -	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ICS*EFV4	2 35A	H-5	A, C	A	0.75	CHV	SEA	O C -	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ICS*MOV116	2 35C	D-4	B	A	02.0	GLV	MOA	C O AI	N	FE-0, ST-0(O), PI-T	N	
2ICS*MOV120	2 35C	C-9	B	A	04.0	GLV	MOA	C O AI	N	FE-0, ST-0(O), PI-T	N	
2ICS*MOV121	1 35A	C-4	A	A	20.0	GTV	MOA	O OC AI	Y	FE-0, ST-0(C), LJ-R, PI-T	Y	GVRR-1
2ICS*MOV122	2 35A	G-7	A	A	12.0	GTV	MOA	O OC AI	Y	FE-0, ST-0(C), PI-T, LJ-R	Y	GVRR-1
2ICS*MOV124	2 35D	C-3	B	A	04.0	GTV	MOA	C C AI	N	PI-T, FE-0, ST-0(C)	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2  
SYSTEM : ICS, REACTOR CORE ISOLATION COOLING (RCIC)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2ICS*MOV126	1	35C	G-3	A	A	06.0	GTV	HOA	C	OC	AI	Y	FE-CS, ST-CS(C), LJ-R, PI-T	Y	SEE GVRR-1, SEE ICS-VCS-1
2ICS*MOV128	1	35A	G-5	A	A	20.0	GTV	HOA	0	OC	AI	Y	FE-CS, ST-CS(C), LJ-R, PI-T	Y	SEE ICS-VCS-3, GVRR-1
2ICS*MOV129	2	35D	I-5	B	A	06.0	GTV	HOA	OC	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2ICS*MOV136	2	35A	I-10	A	A	06.0	GTV	HOA	C	OC	AI	Y	FE-Q, ST-Q(O&C), PI-T, LJ-R	Y	GVRR-1
2ICS*MOV143	2	35A	F-7	A	A	02.0	GLV	HOA	C	OC	AI	Y	FE-Q, ST-Q(O&C), PI-T, LJ-R	Y	GVRR-1, GVRR-3
2ICS*MOV148	2	35A	I-7	A	A	1.50	GLV	HOA	0	OC	AI	Y	FE-Q, ST-Q(O&C), PI-T, LJ-R	Y	GVRR-1
2ICS*MOV159	2	35B	K-9	B	A	01.0	GLV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2ICS*MOV164	2	35A	H-6	A	A	1.50	GLV	HOA	0	OC	AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2ICS*MOV170	2	35A	D-5	A	A	01.0	GLV	HOA	OC	C	AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1, GVRR-3
2ICS*PSE117	2	35B	F-5	D	A	20.0	RD	SEA	C	0	0	N	RD-P3	N	
2ICS*PSE118	2	35B	F-5	D	A	20.0	RD	SEA	C	0	0	N	RD-P3	N	
2ICS*RV112	2	35C	C-3	C	A	0.75	REV	SEA	C	0	AI	N	RT-P2	N	
2ICS*RV114	2	35D	D-5	C	A	0.75	REV	SEA	C	0	AI	N	RT-P2	N	
2ICS*V249	2	35D	I-5	C	A	06.0	CHV	SEA	OC	0	-	N	FE-Q(F)	N	
2ICS*V27	2	35D	F-5	C	A	06.0	CHV	SEA	OC	0	-	N	FE-Q(F)	N	
2ICS*V28	2	35A	H-10	C	A	06.0	CHV	SEA	C	C	-	N	FE-CS(F)	Y	SEE ISC-VCS-4, ICS-VRR-2
2ICS*V29	2	35A	F-7	C	A	12.0	CHV	SEA	C	0	-	N	FE-Q(F)	N	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : ICS, REACTOR CORE ISOLATION COOLING (RCIC)

VALVE NUMBER	CODE		COORD	VCAT	ACT		VALVE TYPE	ACTUAT		POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS
	CLASS	P & ID			PAS	SIZE		TYPE	TYPE	NRM	SAF	FAL			
2ICS*V38	2	35A	G-9	C	A	02.0	CHV	SEA	C	0	-	N	FE-0(F)	N	
2ICS*V39	2	35A	H-6	C	A	1.50	CHV	SEA	C	0	-	N	FE-R(F)	Y	ICS-VRR-1
2ICS*V40	2	35A	I-6	C	A	1.50	CHV	SEA	C	0	-	N	FE-R(F)	Y	ICS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : ISC, REACTOR VESSEL INSTRUMENTATION

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL	TYPE C			
2ISC*EFV1	2	28A	I-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV10	2	28B	I-8	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV11	2	28C	I-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV12	2	28C	I-4	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV13	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV14	2	28C	I-8	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV15	2	28B	D-3	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV16	2	28B	D-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV17	2	28B	D-8	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV18	2	28C	D-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV19	2	28C	D-4	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV2	2	28A	I-4	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV20	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV21	2	28C	D-8	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1
2ISC*EFV22	2	28C	D-9	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-0(F), LJ-R	Y	GVRR-2, GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : ISC, REACTOR VESSEL INSTRUMENTATION

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS	NRH	SAF	FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2ISC*EFV23	2	28C	D-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV24	2	28C	I-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV25	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV26	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV27	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV28	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV29	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV3	2	28A	I-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV30	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV31	2	28C	D-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV32	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV33	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV34	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV35	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	
2ISC*EFV36	2	28C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, GVRR-1	











APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : LMS, CONTAINMENT LEAKAGE MONITORING

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
								NRH	SAF	FAL	TYPE C			
2LMS*SOV152	2 81A	D-4	A	A	0.75	DIV	SOA	C	C	C	Y	PI-T, LJ-R, FE-0, ST-0, FS-0	Y	GVRR-3, SEE GVRR-1
2LMS*SOV153	2 81A	F-4	A	A	0.75	DIV	SOA	C	C	C	Y	PI-T, LJ-R, FE-0, ST-0, FS-0	Y	GVRR-3, SEE GVRR-1
2LMS*SOV156	2 81A	D-9	A	A	0.75	DIV	SOA	C	C	C	Y	PI-T, LJ-R, FE-0, ST-0, FS-0	Y	GVRR-3, SEE GVRR-1
2LMS*SOV157	2 81A	F-9	A	A	0.75	DIV	SOA	C	C	C	Y	PI-T, LJ-R, FE-0, ST-0, FS-0	Y	GVRR-3, SEE GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : MSS, MAIN STEAM

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
	CLASS	P & ID							NRM	SAF	FAL				
2HSS*A0V6A	1	1E	C-7	A	A	26.0	GLV	AOA	0	C	C	Y	FE-CS, ST-CS(C), FS-CS, PI-T, LJ-R		
2HSS*A0V6B	1	1E	C-9	A	A	26.0	GLV	AOA	0	C	C	Y	FE-CS, ST-CS(C), FS-CS, PI-T, LJ-R		
2HSS*A0V6C	1	1E	C-3	A	A	26.0	GLV	AOA	0	C	C	Y	FE-CS, ST-CS(C), FS-CS, PI-T, LJ-R		
2HSS*A0V6D	1	1E	C-5	A	A	26.0	GLV	AOA	0	C	C	Y	FE-CS, FE-CS(C), FS-CS, PI-T, LJ-R		
2HSS*A0V7A	1	1F	B-5	A	A	26.0	GLV	AOA	0	C	C	Y	FE-CS, ST, CS(C), FS-CS, PI-T, LJ-R		
2HSS*A0V7B	1	1F	B-7	A	A	26.0	GLV	AOA	0	C	C	Y	FE-CS, ST-CS(C), FS-CS, PI-T, LJ-R		
2HSS*A0V7C	1	1F	B-2	A	A	26.0	GLV	AOA	0	C	C	Y	FE-CS, ST-CS(C), FS-CS, PI-T, LJ-R		
2HSS*A0V7D	1	1F	B-3	A	A	26.0	GLV	AOA	0	C	C	Y	FE-CS, ST-CS(C), FS-CS, PI-T, LJ-R		
2HSS*EFV1A	2	1J	H-7	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV1B	2	1J	H-9	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV1C	2	1J	H-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV1D	2	1J	H-4	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV2A	2	1J	H-7	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV2B	2	1J	H-10	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV2C	2	1J	H-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : MSS, MAIN STEAM

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2HSS*EFV2D	2	1J	H-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV3A	2	1J	H-7	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV3B	2	1J	H-10	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV3C	2	1J	H-3	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV3D	2	1J	H-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV4A	2	1J	H-8	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV4B	2	1J	H-10	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV4C	2	1J	H-3	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*EFV4D	2	1J	H-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2HSS*MOV111	1	1E	G-2	A	A	06.0	GLV	MOA	C	C	AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	SEE GVRR-1
2HSS*MOV112	1	1E	H-2	A	A	06.0	GLV	MOA	C	C	AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	SEE GVRR-1
2HSS*MOV118	1	1A	J-3	B	P	02.0	GLV	MOA	C	OC	AI	N	PI-T	N	
2HSS*MOV119	1	1A	J-4	B	P	02.0	GLV	MOA	C	OC	AI	N	PI-T	N	
2HSS*MOV208	2	1F	F-9	A	A	02.0	GLV	MOA	C	C	AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	SEE GVRR-1
2HSS*PSV120	1	1A	D-4	C	A	08.0	REV	SEA	C	0	-	N	RT-P1	N	
2HSS*PSV121	1	1A	E-4	B, C	A	08.0	REV	SEA	C	0	C	N	FE-R, FS-R, RT-P1, ST-R	Y	SEE HSS-VRR-1, ADS VLV.



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : MSS, MAIN STEAM

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			C.	TEST FREQ. (DIR)	RELIEF	REMARKS
								NRH	SAF	FAL				
2HSS*PSV122	1 1A	G-4	C	A	08.0	REV	SEA	C	0	-	N	RT-P1	N	
2HSS*PSV123	1 1A	H-4	C	A	08.0	REV	SEA	C	0	-	N	RT-P1	N	
2HSS*PSV124	1 1B	D-4	C	A	08.0	REV	SEA	C	0	-	N	RT-P1	N	
2HSS*PSV125	1 1B	E-4	C	A	08.0	REV	SEA	C	0	-	N	RT-P1	N	
2HSS*PSV126	1 1B	G-4	B, C	A	08.0	REV	SEA,	C	0	C	N	FE-R, FS-R, RT-P1, ST-R	Y	SEE MSS-VRR-1, ADS VLV.
2HSS*PSV127	1 1B	H-4	B, C	A	08.0	REV	SEA,	C	0	C	N	FE-R, FS-R, RT-P1, ST-R	Y	SEE MSS-VRR-1, ADS VLV.
2HSS*PSV128	1 1B	I-4	C	A	08.0	REV	SEA	C	0	C	N	RT-P1	N	
2HSS*PSV129	1 1C	D-4	B, C	A	08.0	REV	SEA,	C	0	C	N	FE-R, FS-R, RT-P1, ST-R	Y	SEE MSS-VRR-1, ADS VLV.
2HSS*PSV130	1 1C	E-4	B, C	A	08.0	REV	SEA,	C	0	C	N	FE-R, FS-R, RT-P1, ST-R	Y	SEE MSS-VRR-1, ADS VLV
2HSS*PSV131	1 1C	G-4	C	A	08.0	REV	SEA,	C	0	-	N	RT-P1	N	
2HSS*PSV132	1 1C	H-4	C	A	08.0	REV	SEA	C	0	-	N	RT-P1	N	
2HSS*PSV133	1 1C	J-4	C	A	08.0	REV	SEA	C	0	-	N	RT-P1	N	
2HSS*PSV134	1 1D	D-5	B, C	A	08.0	REV	SEA,	C	0	C	N	FE-R, FS-R, RT-P1, ST-R	Y	SEE MSS-VRR-1, ADS VLV.
2HSS*PSV135	1 1D	F-5	C	A	08.0	REV	SEA	C	0	-	N	RT-P1	N	
2HSS*PSV136	1 1D	H-5	C	A	08.0	REV	SEA	C	0	-	N	RT-P1	N	
2HSS*PSV137	1 1D	J-5	B, C	A	08.0	REV	SEA,	C	0	C	N	FE-R, FS-R, RT-P1, ST-R	Y	SEE MSS-VRR-1, ADS VLV
2HSS*SOV97A	2 1E	J-8	A	A	0.75	GLV	SOV	C	C	C	Y	LJ-R, FE-Q, ST-Q(C)	Y	SEE GVRR-1, GVRR-3
2HSS*SOV97B	2 1E	J-10	A	A	0.75	GLV	SOV	C	C	C	Y	LJ-R, FE-Q, ST-Q(C)	Y	SEE GVRR-1, GVRR-3



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : HSS, MAIN STEAM

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
								NRM	SAF	FAL	TYPE C			
2HSS*S0V97C	2 1E	J-4	A	A	0.75	GLV	SOV	C	C	C	Y	LJ-R, FE-0, ST-0(C)	Y	SEE GVRR-1, GVRR-3
2HSS*S0V97D	2 1E	J-6	A	A	0.75	GLV	SOV	C	C	C	Y	LJ-R, FE-0, ST-0(C)	Y	SEE GVRR-1, GVRR-3



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : NMS, NEUTRON MONITOR

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2NMS*SOV1A	2	EH38A	F-7	A	A	1.50	BLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, LJ-R, PI-T	Y	PART OF C51-J004A TIP SYSTEM, GVRR-1, GVRR-3
2NMS*SOV1B	2	EH38A	F-7	A	A	1.50	BLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, LJ-R, PI-T	Y	PART OF C51-J004B TIP SYSTEM, GVRR-1, GVRR-3
2NMS*SOV1C	2	EH38A	G-6	A	A	1.50	BLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, LJ-R, PI-T	Y	PART OF C51-J004C TIP SYSTEM, GVRR-1, GVRR-3
2NMS*SOV1D	2	EH38A	G-6	A	A	1.50	BLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, LJ-R, PI-T	Y	PART OF C51-J004D TIP SYSTEM, GVRR-1, GVRR-3
2NMS*SOV1E	2	EH38A	H-5	A	A	1.50	BLV	SOA	C	C	C	Y	FE-0, ST-0(C), FS-0, LJ-R, PI-T	Y	PART OF C51-J004E TIP SYSTEM, GVRR-1, GVRR-3
2NMS*VEX1A	2	EH38A	F-7	D	A	1.50	EXV	EXA	0	C	N	N	EX-P6	N	PART OF C51-J004A TIP SYSTEM
2NMS*VEX1B	2	EH38A	F-7	D	A	1.50	EXV	EXA	0	C	N	N	EX-P6	N	PART OF C51-J004B TIP SYSTEM
2NMS*VEX1C	2	EH38A	G-6	D	A	1.50	EXV	EXA	0	C	N	N	EX-P6	N	PART OF C51-J004C TIP SYSTEM
2NMS*VEX1D	2	EH38A	G-6	D	A	1.50	EXV	EXA	0	C	N	N	EX-P6	N	PART OF C51-J004D TIP SYSTEM
2NMS*VEX1E	2	EH38A	H-5	D	A	1.50	EXV	EXA	0	C	N	N	EX-P6	N	PART OF C51-J004E TIP SYSTEM



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RCS, REACTOR COOLANT (RECIRCULATION)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL				
2RCS*EFV44A	2	29B	D-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV44B	2	29C	D-2	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV45A	2	29B	D-3	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV45B	2	29C	D-3	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV46A	2	29B	D-4	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV46B	2	29C	D-4	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV47A	2	29B	D-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV47B	2	29C	D-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV48A	2	29B	D-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV48B	2	29C	D-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV52A	2	29B	I-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV52B	2	29C	I-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV53A	2	29B	H-5	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV53B	2	29C	H-6	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV62A	2	29B	J-9	A, C	A	0.75	CHV	SEA	0	C	-	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RCS, REACTOR COOLANT (RECIRCULATION)

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RCS*EFV62B	2 29C	J-9	A, C	A	0.75	CHV	SEA	0 C -	N	PI-T, LJ-R, FE-Q(F)	Y	GVRR-2, SEE GVRR-1
2RCS*EFV63A	2 29B	J-9	A, C	A	0.75	CHV	SEA	0 C -	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*EFV63B	2 29C	J-9	A, C	A	0.75	CHV	SEA	0 C -	N	PI-T, FE-Q(F), LJ-R	Y	GVRR-2, SEE GVRR-1
2RCS*MOV18A	1 29B	J-2	B	A	24.0	GTV	MOA	0 C AI	N	FE-CS, ST-CS(C), PI-T	Y	SEE RCS-VCS-1
2RCS*MOV18B	1 29C	J-2	B	A	24.0	GTV	MOA	0 C AI	N	FE-CS, ST-CS(C), PI-T	Y	SEE RCS-VCS-1
2RCS*SOV104	2 29B	H-3	A	A	0.75	GLV	SOA	0 C C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2RCS*SOV105	2 29B	H-3	A	A	0.75	GLV	SOA	0 C C	Y	FE-Q, ST-Q(C), FS-Q, PI-T, LJ-R	Y	GVRR-1, GVRR-3
2RCS*SOV65A	2 29A	A-6	A	A	02.0	GLV	SOA	0 C C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*SOV65B	2 29A	G-6	A	A	02.0	GLV	SOA	0 C C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*SOV66A	2 29A	C-6	A	A	01.0	GLV	SOA	0 C C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*SOV66B	2 29A	H-6	A	A	01.0	GLV	SOA	0 C C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*SOV67A	2 29A	D-6	A	A	02.0	GLV	SOA	0 C C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*SOV67B	2 29A	J-6	A	A	02.0	GLV	SOA	0 C C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*SOV68A	2 29A	E-6	A	A	0.75	GLV	SOA	0 C C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*SOV68B	2 29A	K-6	A	A	0.75	GLV	SOA	0 C C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RCS, REACTOR COOLANT (RECIRCULATION)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM	SAF	FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2RCS*S0V79A	2	29A	A-6	A	A	02.0	GLV	SOA	0	C	C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*S0V79B	2	29A	G-6	A	A	02.0	GLV	SOA	0	C	C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*S0V80A	2	29A	C-6	A	A	01.0	GLV	SOA	0	C	C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*S0V80B	2	29A	I-6	A	A	01.0	GLV	SOA	0	C	C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*S0V81A	2	29A	D-6	A	A	02.0	GLV	SOA	0	C	C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*S0V81B	2	29A	I-6	A	A	02.0	GLV	SOA	0	C	C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*S0V82A	2	29A	E-6	A	A	0.75	GLV	SOA	0	C	C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*S0V82B	2	29A	K-6	A	A	0.75	GLV	SOA	0	C	C	N	FE-CS, ST-CS(C), FS-CS, PI-T	Y	SEE RCS-VCS-2, GVRR-1, GVRR-3
2RCS*V59A	2	29B	H-10	A, C	A	0.75	CHV	SEA	0	C	-	Y	FE-R(R), LJ-R	Y	SEE RCS-VRR-1, GVRR-1.
2RCS*V59B	2	29C	G-10	A, C	A	0.75	CHV	SEA	0	C	-	Y	FE-R(R), LJ-R	Y	SEE RCS-VRR-1, GVRR-1.
2RCS*V60A	2	29B	F-10	A, C	A	0.75	CHV	SEA	0	C	-	Y	FE-R(R), LJ-R	Y	SEE RCS-VRR-1, GVRR-1.
2RCS*V60B	2	29C	F-10	A, C	A	0.75	CHV	SEA	0	C	-	Y	FE-R(R), LJ-R	Y	SEE RCS-VRR-1, GVRR-1.
2RCS*V90A	2	29B	G-10	A, C	A	0.75	CHV	SEA	0	C	-	Y	FE-R(R), LJ-R	Y	SEE RCS-VRR-1, GVRR-1.
2RCS*V90B	2	29C	G-10	A, C	A	0.75	CHV	SEA	0	C	-	Y	FE-R(R), LJ-R	Y	SEE RCS-VRR-1, GVRR-1.



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	NRH	SAF	FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*AOV123	2	30C	C-10	A	A	02.0	DIV	AOA	0	C	C	Y	FE-0, ST-0(O&C), FS-0, LJ-R, PI-T	Y	SEE GVRR-1, SEE RDS-VRR-1
2RDS*AOV124	2	30C	F-5	A	A	01.0	GLV	AOA	0	C	C	Y	FE-0, ST-0(O&C), FS-0, LJ-R, PI-T	Y	SEE GVRR-1, SEE RDS-VRR-1
2RDS*AOV126-0219	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(O), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-0223	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(O), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-0227	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(O), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS: 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-0231	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(O), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-0235	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(O), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-0239	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(O), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE ACTUAT		POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
	CLASS	P & ID					TYPE	TYPE	NRM	SAF	FAL				TYPE C
2RDS*A0V126-0243	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-0615	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-0619	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-0623	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-0627	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-0631	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-0635	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			C	TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL					
2RDS*A0V126-0639	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-0643	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-0647	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-1011	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-1015	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-1019	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-1023	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RDS*A0V126-1027	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1031	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1035	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1039	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1043	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1047	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1051	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL				
2RDS*A0V126-1407	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1411	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1415	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1419	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1423	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1427	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1431	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRH	SAF	FAL				
2RDS*A0V126-1435	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1439	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1443	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1447	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1451	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1455	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1803	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RDS*AOV126-1807	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-1811	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-1815	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-1819	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-1823	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-1827	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-1831	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
								NRH	SAF	FAL				
2RDS*A0V126-1835	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1839	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1843	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1847	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1851	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1855	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-1859	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
								NRH	SAF	FAL				
2RDS*AOV126-2203	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-2207	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-2211	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-2215	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-2219	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-2223	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-2227	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT, NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM	SAF	FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2RDS*A0V126-2231	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2235	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2239	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2243	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2247	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2251	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2255	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.	(DIR)	RELIEF	REMARKS	
								NRH	SAF	FAL	TYPE	C			
2RDS*A0V126-2259	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N		FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2603	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N		FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2607	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N		FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2611	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N		FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2615	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N		FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2619	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N		FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-2623	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N		FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.	(DIR)	RELIEF	REMARKS
								NRH	SAF	FAL					
2RDS*A0V126-2627	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-2631	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-2635	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-2639	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-2643	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-2647	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V126-2651	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL					
2RDS*AOV126-2655	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T		Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-2659	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T		Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3003	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T		Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3007	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T		Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3011	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T		Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3015	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T		Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3019	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T		Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2RDS*A0V126-3023	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3027	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3031	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3035	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3039	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3043	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3047	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C.	TEST FREQ. (DIR)	RELIEF	REMARKS
2RDS*AOV126-3051	2	30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3055	2	30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3059	2	30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3403	2	30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3407	2	30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3411	2	30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3415	2	30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL					
2RDS*AOV126-3419	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-3423	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-3427	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-3431	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-3435	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-3439	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-3443	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RDS*A0V126-3447	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3451	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3455	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3459	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3803	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3807	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3811	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*A0V126-3815	2 30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3819	2 30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3823	2 30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3827	2 30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3831	2 30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3835	2 30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-3839	2 30B	D-8	B	A	00.5	GTV	AOA	C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
								NRH	SAF	FAL				
2RDS*AOV126-3843	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3847	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3851	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3855	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-3859	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4203	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4207	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
								NRM	SAF	FAL	TYPE C			
2RDS*A0V126-4211	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-4215	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-4219	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-4223	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-4227	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-4231	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-4235	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RDS*AOV126-4239	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4243	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4247	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4251	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS: 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4255	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4259	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4607	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL				
2RDS*AOV126-4611	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4615	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4619	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4623	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4627	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4631	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-4635	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			C	TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL					
2RDS*AOV126-4639	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-4643	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-4647	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-4651	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-4655	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-5011	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-5015	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
									NRH	SAF	FAL				
2RDS*AOV126-5019	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-5023	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-5027	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-5031	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-5035	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-5039	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV126-5043	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			C.	TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL					
2RDS*AOV126-5047	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-5051	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-5415	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-5419	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-5423	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-5427	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*AOV126-5431	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRH	SAF	FAL				
2RDS*A0V126-5435	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-5439	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-5443	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-5447	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-5819	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-5823	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-5827	2 30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE ACTUAT		POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
	CLASS	P & ID					TYPE	TYPE	NRH	SAF	FAL				TYPE C
2RDS*A0V126-5831	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-5835	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-5839	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V126-5843	2	30B	D-8	B	A	00.5	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 126 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-0219	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-0223	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-0227	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			C	TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL					
2RDS*A0V127-0231	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-0235	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-0239	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-0243	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-0615	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-0619	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-0623	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRH	SAF	FAL				
2RDS*A0V127-0627	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-0631	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-0635	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-0639	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-0643	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-0647	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1011	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL				
2RDS*A0V127-1015	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1019	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1023	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1027	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1031	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1035	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1039	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
								NRH	SAF	FAL	TYPE C			
2RDS*A0V127-1043	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1047	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1051	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1407	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1411	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1415	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1419	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
									NRH	SAF	FAL	TYPE C			
2RDS*A0V127-1423	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1427	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1431	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1435	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1439	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1443	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-1447	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2RDS*AOV127-1451	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1455	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1803	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1807	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1811	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1815	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1819	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RDS*AOV127-1823	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1827	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1831	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1835	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1839	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1843	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1847	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT, NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RDS*AOV127-1851	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1855	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-1859	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2203	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2207	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2211	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2215	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH	SAF	FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*A0V127-2219	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2223	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2227	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2231	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS: 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2235	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2239	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2243	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM	SAF	FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*AOV127-2247	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2251	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2255	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2259	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2603	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2607	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2611	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT, NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RDS*A0V127-2615	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2619	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2623	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2627	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2631	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2635	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-2639	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT, NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH	SAF	FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2RDS*AOV127-2643	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2647	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2651	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2655	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-2659	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-3003	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-3007	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL				
2RDS*A0V127-3011	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3015	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3019	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3023	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3027	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3031	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3035	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRH	SAF	FAL				
2RDS*A0V127-3039	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3043	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3047	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3051	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS; 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3055	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3059	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3403	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE ACTUAT		POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
							TYPE	TYPE	NRM	SAF	FAL				TYPE
2RDS*A0V127-3407	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3411	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3415	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3419	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3423	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3427	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3431	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
								NRM	SAF	FAL	TYPE C			
2RDS*A0V127-3435	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3439	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3443	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3447	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3451	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3455	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3459	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2RDS*A0V127-3803	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3807	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3811	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3815	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3819	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3823	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3827	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2RDS*A0V127-3831	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3835	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3839	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3843	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3847	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3851	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-3855	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RDS*A0V127-3859	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4203	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4207	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4211	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS: 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4215	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4219	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4223	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL				
2RDS*A0V127-4227	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4231	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4235	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4239	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4243	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4247	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-4251	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			C	TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL					
2RDS*A0V127-4255	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-4259	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-4607	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-4611	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-4615	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-4619	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*A0V127-4623	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT, NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2RDS*AOV127-4627	2	30R	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-4631	2	30R	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-4635	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-4639	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-4643	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-4647	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-4651	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX E  
FIRST TEN YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL				
2RDS*A0V127-4655	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5011	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5015	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5019	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5023	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5027	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5031	2	30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUATOR TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
								NRH	SAF	FAL	TYPE C			
2RDS*AOV127-5035	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5039	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5043	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5047	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5051	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5415	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5419	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX C  
FIRST TO LAST TEST INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRH	SAF	FAL				
2RDS*AOV127-5423	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5427	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5431	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5435	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5439	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5443	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*AOV127-5447	2 30B	B-9	B	A	0.75	GTV	AOA	C	0	0	N	FE-0, ST-0(0), FS-0, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX 5  
FIRST TO LAST INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*A0V127-5819	2 30B	B-9	B	A	0.75	GTV	AOA	C 0 0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5823	2 30B	B-9	B	A	0.75	GTV	AOA	C 0 0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5827	2 30B	B-9	B	A	0.75	GTV	AOA	C 0 0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5831	2 30B	B-9	B	A	0.75	GTV	AOA	C 0 0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5835	2 30B	B-9	B	A	0.75	GTV	AOA	C 0 0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5839	2 30B	B-9	B	A	0.75	GTV	AOA	C 0 0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V127-5843	2 30B	B-9	B	A	0.75	GTV	AOA	C 0 0	N	FE-Q, ST-Q(O), FS-Q, PI-T	Y	GE VALVE 127 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*A0V130	2 30C	B-10	A	A	02.0	DIV	AOA	O C C	Y	FE-Q, ST-Q(O&C), FS-Q, LJ-R, PI-T	Y	GVRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
								HRM	SAF	FAL	TYPE C			
2RDS*AOV132	2 30C	F-4	A	A	01.0	GLV	AOA	0	C	C	Y	FE-0, ST-0(O&C), FS-0, LJ-RPI-T	Y	GVRR-1
2RDS*V114-0219	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0223	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0227	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0231	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0235	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0239	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0243	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-0615	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0619	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0623	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0627	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VLVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0631	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VLVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0635	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VLVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-0639	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX  
FIRST TEST PROGRAM TABLE  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS	NRM	SAF	FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-0643	2	308	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*V114-0647	2	308	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*V114-1011	2	308	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*V114-1015	2	308	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*V114-1019	2	308	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*V114-1023	2	308	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	
2RDS*V114-1027	2	308	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1	



APPENDIX 3  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRM	SAF	FAL				
2RDS*V114-1031	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1035	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1039	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1043	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1047	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1051	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1407	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX 7  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS	NRH	SAF	FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-1411	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N		FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1415	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N		FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1419	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N		FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1423	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N		FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1427	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N		FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1431	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N		FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1435	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N		FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-1439	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1443	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1447	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1451	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1455	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1803	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1807	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	VALVE SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-1811	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1815	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1819	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1823	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1827	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1831	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1835	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-1839	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1843	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1847	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1851	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1855	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-1859	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2203	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUATOR TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-2207	2 308	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2211	2 308	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2215	2 308	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2219	2 308	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2223	2 308	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2227	2 308	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2231	2 308	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
									NRH	SAF	FAL	TYPE C			
2RDS*V114-2235	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2239	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2243	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2247	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2251	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2255	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2259	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-2603	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2607	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2611	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2615	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2619	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2623	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2627	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL	TYPE C			
2RDS*V114-2631	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2635	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2639	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2643	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2647	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2651	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-2655	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT. PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-2659	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3003	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3007	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3011	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3015	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3019	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3023	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX C  
FIRST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-3027	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3031	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3035	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3039	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3043	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3047	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3051	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-3055	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3059	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3403	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3407	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3411	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3415	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3419	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-3423	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3427	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3431	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3435	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3439	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3443	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3447	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-3451	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3455	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3459	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3803	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3807	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3811	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3815	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUATOR TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2RDS*V114-3819	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3823	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3827	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3831	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3835	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3839	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3843	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAL TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-3847	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3851	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3855	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-3859	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4203	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4207	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4211	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2RDS*V114-4215	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4219	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4223	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4227	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4231	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4235	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4239	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-0(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



APPENDIX 5  
FIRST TO LAST INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-4243	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4247	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4251	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4255	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4259	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4607	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4611	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-4615	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4619	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4623	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4627	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4631	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4635	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4639	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-4643	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4647	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4651	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-4655	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5011	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5015	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5019	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-5023	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5027	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5031	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5035	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5039	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5043	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5047	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE ACTUAT		POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
	CLASS	P & ID					TYPE	TYPE	NRH	SAF	FAL				TYPE C
2RDS*V114-5051	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5415	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5419	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5423	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5427	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5431	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5435	2	30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V114-5439	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5443	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5447	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5819	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5823	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5827	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5831	2 30B	B-9	C	A	0.75	CHV	SEA	C 0 -	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRM	SAF	FAL				
2RDS*V114-5835	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5839	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V114-5843	2 30B	B-9	C	A	0.75	CHV	SEA	C	0	-	N	FE-Q(F)	Y	GE VALVE 114 ON P&ID, TESTING FREQUENCY IN ACCORDANCE WITH TS 4.1.3.2, SEE RDS-VRR-1
2RDS*V115-0219	2 30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0223	2 30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0227	2 30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0231	2 30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0235	2 30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0239	2 30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0243	2 30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0615	2 30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0619	2 30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE			COORD	VCAT	ACT PAS	SIZE	VALVE ACTUATOR		POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
	CLASS	P & ID	ID					TYPE	TYPE	NRH	SAF	FAL				TYPE
2RDS*V115-0623	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0627	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0631	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0635	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0639	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0643	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-0647	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1011	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1015	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1019	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1023	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1027	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1031	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1035	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1039	2	30B		D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE ACTUAT		POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
	CLASS	P & ID					TYPE	TYPE	NRM	SAF	FAL				TYPE
2RDS*V115-1043	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1047	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1051	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1407	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1411	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1415	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1419	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1423	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1427	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1431	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1435	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1439	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1443	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1447	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1451	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V115-1455	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1803	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1807	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1811	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1815	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1819	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1823	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1827	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1831	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1835	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1839	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1843	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1847	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1851	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-1855	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V115-1859	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2203	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2207	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2211	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2215	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2219	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2223	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2227	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2231	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2235	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2239	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2243	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2247	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2251	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2255	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE ACTUAT		POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
	CLASS	P & ID					TYPE	TYPE	NRH	SAF	FAL				TYPE C
2RDS*V115-2259	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2603	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2607	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2611	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2615	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2619	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2623	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2627	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2631	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2635	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2639	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2643	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2647	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2651	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-2655	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS	NRH	SAF	FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V115-2659	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3003	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3007	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3011	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3015	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3019	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3023	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3027	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3031	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3035	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3039	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3043	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3047	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3051	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3055	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N		FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V115-3059	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3403	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3407	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3411	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3415	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3419	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3423	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3427	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3431	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3435	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3439	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3443	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3447	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3451	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3455	2	30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



APPENDIX 5  
FIRST TEST PROGRAM TABLE  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2RDS*V115-3459	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3803	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3807	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3811	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3815	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3819	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3823	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3827	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3831	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3835	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3839	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3843	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3847	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3851	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-3855	2 30B	D-7	C	A	00.5	CHV	SEA	OC C -	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
									NRH	SAF	FAL	TYPE C			
2RDS*V115-3859	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4203	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V:15-4207	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4211	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4215	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4219	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4223	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4227	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4231	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4235	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4239	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4243	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4247	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4251	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4255	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2RDS*V115-4259	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4607	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4611	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4615	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4619	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4623	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4627	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4631	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4635	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4639	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4643	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4647	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4651	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-4655	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5011	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
									NRH	SAF	FAL	TYPE C			
2RDS*V115-5015	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5019	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5023	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5027	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5031	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5035	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5039	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5043	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5047	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5051	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5415	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5419	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5423	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5427	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5431	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-0(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL	TYPE C			
2RDS*V115-5435	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5439	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5443	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5447	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5819	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5823	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5827	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5831	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5835	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5839	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V115-5843	2	30B	D-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-Q(R)	Y	GE VALVE 115 ON P&ID, SEE RDS-VRR-2
2RDS*V138-0219	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0223	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0227	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0231	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



APPENDIX  
FIRST T... AR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRM	SAF	FAL				
2RDS*V138-0235	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0239	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0243	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0615	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0619	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0623	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0627	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0631	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0635	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0639	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0643	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-0647	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1011	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1015	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1019	2 30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



APPENDIX  
FIRST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE HILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE ACTUAT		POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
							TYPE	TYPE	NRM	SAF	FAL				TYPE C
2RDS*V138-1023	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1027	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1031	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1035	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1039	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1043	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1047	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1051	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1407	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1411	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1415	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1419	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1423	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1427	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1431	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS	NRM	SAF	FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V138-1435	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1439	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1443	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1447	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1451	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1455	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1803	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1807	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1811	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1815	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1819	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1823	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1827	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1831	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1835	2	30B	C-7	C	A	00.5	CHV	SEA	OC C	-	N			FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ. (DIR)	RELIEF	REMARKS
									NRH	SAF	FAL	TYPE C			
2RDS*V138-1839	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1843	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1847	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1851	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1855	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-1859	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2203	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2207	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2211	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2215	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2219	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2223	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2227	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2231	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2235	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ. (DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL	TYPE C			
2RDS*V138-2239	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2243	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2247	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2251	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2255	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2259	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2603	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2607	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2611	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2615	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2619	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2623	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2627	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2631	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2635	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2RDS*V138-2639	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2643	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2647	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2651	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2655	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-2659	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3003	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3007	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3011	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3015	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3019	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3023	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3027	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3031	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3035	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS	HRM	SAF	FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2RDS*V138-3039	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3043	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3047	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3051	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3055	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3059	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3403	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3407	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3411	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3415	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3419	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3423	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3427	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3431	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3435	2	30B	C-7	C	A	00.5	CHV	SEA	OC C -	N				FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	NRH	SAF	FAL	POSITIONS TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V138-3439	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3443	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3447	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3451	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3455	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3459	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3803	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3807	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3811	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3815	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3819	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3823	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3827	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3831	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3835	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
								NRH	SAF	FAL	TYPE C			
2RDS*V138-3839	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3843	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3847	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3851	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3855	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-3859	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4203	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4207	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4211	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4215	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4219	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4223	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4227	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4231	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4235	2 30B	C-7	C	A	00.5	CHV	SEA	0C	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RDS*V138-4239	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4243	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4247	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4251	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4255	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4259	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4607	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4611	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4615	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4619	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4623	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4627	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4631	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4635	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4639	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE ACTUAT		POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
	CLASS	P & ID					TYPE	TYPE	NRM	SAF	FAL				TYPE C
2RDS*V138-4643	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4647	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4651	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-4655	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5011	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5015	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5019	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5023	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5027	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5031	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5035	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5039	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5043	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5047	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5051	2	30B	C-7	C	A	00.5	CHV	SEA	OC	C	-	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RDS*V138-5415	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5419	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5423	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5427	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5431	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5435	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5439	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5443	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5447	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5819	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5823	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5827	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5831	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5835	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3
2RDS*V138-5839	2 30B	C-7	C	A	00.5	CHV	SEA	OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



SYSTEM : RDS, CONTROL ROD DRIVE HYDRAULIC

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	VALVE SIZE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2RDS*V138-5843	2 30B	C-7	C	A	00.5	CHV	SEA OC C -	N	FE-R(R)	Y	GE VALVE 138 ON P&ID, SEE RDS-VRR-3



APPENDIX C  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RHS, RESIDUAL HEAT REMOVAL (RHR)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2RHS*AOV150	2	31E	B-8	C	A	16.0	TCV	SEA	OC	C	-	N	FE-Q(F)	N	HOOK UP AIR FOR SECT XI TEST
2RHS*AOV16A	1	31A	F-5	A, C	A	12.0	TCV	SEA	C	OC	-	Y	FE-CS(F&R), LJ-R, PI-T, LK-R	Y	SEE RHS-VCS-1, GVRR-1
2RHS*AOV16B	1	31A	J-6	A, C	A	12.0	TCV	SEA	C	OC	-	Y	FE-CS(F&R), LJ-R, PI-T, LK-R	Y	SEE RHS-VCS-1, GVRR-1
2RHS*AOV16C	1	31A	J-4	A, C	A	12.0	TCV	SEA	C	OC	-	Y	FE-CS(F&R), LJ-R, PI-T, LK-R	Y	SEE RHS-VCS-1, GVRR-1
2RHS*AOV39A	1	31A	F-9	A, C	A	12.0	TCV	SEA	C	OC	-	Y	FE-CS(F&R), LJ-R, PI-T, LK-R	Y	SEE RHS-VCS-1, GVRR-1
2RHS*AOV39B	1	31A	K-9	A, C	A	12.0	TCV	SEA	C	OC	-	Y	FE-CS(F&R), LJ-R, PI-T, LK-R	Y	SEE RHS-VCS-1, GVRR-1
2RHS*EFV5	2	31B	B-8	A, C	A	0.75	CHV	SEA	O	C	-	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2RHS*EFV6	2	31B	B-7	A, C	A	0.75	CHV	SEA	O	C	-	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2RHS*EFV7	2	31A	C-6	A, C	A	0.75	CHV	SEA	O	C	-	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2RHS*FV38A	2	31C	B-6	B	A	18.0	GLV	HOA	C	CO	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*FV38B	2	31B	J-9	B	A	18.0	GLV	HOA	C	CO	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*FV38C	2	31B	H-7	B	A	18.0	GLV	HOA	C	CO	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*MOV104	1	31B	D-2	A	A	06.0	GLV	HOA	C	OC	AI	Y	FE-CS, ST-CS(C), LJ-R, PI-T, LK-R	Y	SEE RHS-VCS-1, GVRR-1
2RHS*MOV112	1	31A	H-10	A	A	30.0	GTV	HOA	C	OC	AI	Y	FE-CS, ST-CS(O&C), LJ-R, PI-T, LK-R	Y	SEE RHS-VCS-1, GVRR-1



APPENDIX E  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TEST PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RHS, RESIDUAL HEAT REMOVAL (RHR)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
									NRH	SAF	FAL	TYPE C			
2RHS*MOV113	1	31A	E-10	A	A	30.0	GTV	MOA	C	C	AI	Y	FE-CS, ST-CS(C), LJ-R, PI-T, LK-R	Y	SEE RHS-VCS-1, GVRR-1
2RHS*MOV115	2	31E	C-8	B	A	16.0	GTV	MOA	C	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*MOV116	3	31E	B-9	B	A	16.0	GTV	MOA	C	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*MOV12A	2	31D	I-6	B	A	18.0	BFV	MOA	O	OC	AI	N	FE-Q, ST-Q(C), PI-T	N	
2RHS*MOV12B	2	31E	D-7	B	A	18.0	BFV	MOA	O	OC	AI	N	FE-Q, ST-Q(C), PI-T	N	
2RHS*MOV142	2	31F	I-3	B	A	03.0	GLV	MOA	C	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*MOV149	2	31F	I-3	B	A	03.0	GTV	MOA	C	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*MOV15A	2	31A	B-2	A	A	16.0	GTV	MOA	C	OC	AI	Y	FE-Q, ST-Q(O&C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV15B	2	31B	F-4	A	A	16.0	GTV	MOA	C	OC	AI	Y	FE-Q, ST-Q(O&C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV1A	2	31C	F-9	A	A	24.0	BFV	MOA	O	OC	AI	Y	FE-Q, ST-Q(C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV1B	2	31F	F-2	A	A	24.0	BFV	MOA	O	OC	AI	Y	FE-Q, ST-Q(C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV1C	2	31G	D-10	A	A	24.0	BFV	MOA	O	OC	AI	Y	FE-Q, ST-Q(C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV22A	2	31D	G-9	A	A	08.0	GLV	MOA	C	C	AI	N	FE-CS, ST-CS(C), PI-T, LK-R	Y	SEE RHS-VCS-3
2RHS*MOV22B	2	31G	K-2	A	A	08.0	GLV	MOA	C	C	AI	N	FE-CS, ST-CS(C), PI-T, LK-R	Y	SEE RHS-VCS-3
2RHS*MOV23A	2	31D	D-9	A	A	08.0	GLV	MOA	C	C	AI	N	FE-CS, ST-CS(C), PI-T, LK-R	Y	SEE RHS-VCS-1



SYSTEM : RHS, RESIDUAL HEAT REMOVAL (RHR)

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RHS*MOV23B	2 31G	J-4	A	A	08.0	GLV	MOA	C C AI	N	FE-CS, ST-CS(C), PI-T, LK-R	Y	SEE RHS-VCS-1
2RHS*MOV24A	1 31A	D-5	A	A	12.0	GTV	MOA	C OC AI	Y	FE-CS, ST-CS(O&C), LJ-R, PI-T, LK-R	Y	GVRR-1, SEE RHS-VCS-1
2RHS*MOV24B	1 31B	D-7	A	A	12.0	GTV	MOA	C OC AI	Y	FE-CS, ST-CS(O&C), LJ-R, PI-T, LK-R	Y	GVRR-1, SEE RHS-VCS-1
2RHS*MOV24C	1 31B	C-5	A	A	12.0	GTV	MOA	C OC AI	Y	FE-CS, ST-CS(O&C), LJ-R, PI-T, LK-R	Y	GVRR-1, SEE RHS-VCS-1
2RHS*MOV25A	2 31A	E-2	A	A	16.0	GTV	MOA	C OC AI	Y	FE-Q, ST-Q(O&C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV25B	2 31B	B-3	A	A	16.0	GTV	MOA	C OC AI	Y	FE-Q, ST-Q(O&C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV26A	2 31D	D-3	A	A	01.0	GLV	MOA	C OC AI	Y	FE-Q, ST-Q(C), PI-T	Y	GVRR-1
2RHS*MOV26B	2 31E	H-5	A	A	01.0	GLV	MOA	C OC AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2RHS*MOV27A	2 31D	D-2	A	A	01.0	GLV	MOA	C OC AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2RHS*MOV27B	2 31E	H-4	A	A	01.0	GLV	MOA	C OC AI	Y	FE-Q, ST-Q(C), PI-T, LJ-R	Y	GVRR-1
2RHS*MOV2A	2 31F	H-9	B	A	18.0	BFV	MOA	C OC AI	N	FE-Q, ST-Q(O), PI-T	N	
2RHS*MOV2B	2 31F	G-3	B	A	18.0	BFV	MOA	C OC AI	N	FE-Q, ST-Q(O), PI-T	N	
2RHS*MOV30A	2 31C	D-6	A	A	18.0	BFV	MOA	O OC AI	Y	FE-Q, ST-Q(O&C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV30B	2 31C	J-7	A	A	18.0	BFV	MOA	O OC AI	Y	FE-Q, ST-Q(O&C), LJ-R, PI-T	Y	GVRR-1



APPENDIX  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RHS, RESIDUAL HEAT REMOVAL (RHR)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RHS*MOV32A	2	31D	J-4	B	A	04.0	GTV	MOA	C	C	AI	N	FE-Q, ST-Q(C), PI-T	N	
2RHS*MOV32B	2	31D	H-2	B	A	04.0	GTV	MOA	C	C	AI	N	FE-Q, ST-Q(C), PI-T	N	
2RHS*MOV33A	2	31C	C-2	A	A	04.0	GLV	MOA	C	OC	AI	Y	FE-Q, ST-Q(O&C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV33B	2	31C	I-3	A	A	04.0	GLV	MOA	C	OC	AI	Y	FE-Q, ST-Q(O&C), LJ-R, PI-T	Y	GVRR-1
2RHS*MOV37A	2	31D	H-5	B	A	04.0	GLV	MOA	C	C	AI	N	FE-Q, ST-Q(C), PI-T	N	
2RHS*MOV37B	2	31D	G-2	B	A	04.0	GLV	MOA	C	C	AI	N	FE-Q, ST-Q(C), PI-T	N	
2RHS*MOV40A	1	31A	D-9	A	A	12.0	GLV	MOA	C	OC	AI	Y	FE-CS, ST-CS(O), LJ-R, PI-T, LK-R	Y	GVRR-1, SEE RHS-VCS-1
2RHS*MOV40B	1	31B	C-10	A	A	12.0	GLV	MOA	C	OC	AI	Y	FE-CS, ST-CS(O&C), LJ-R, PI-T, LK-R	Y	GVRR-1, SEE RHS-VCS-1
2RHS*MOV4A	2	31F	E-5	B	A	06.0	GTV	MOA	O	OC	AI	N	FE-Q, ST-Q(C), PI-T	N	
2RHS*MOV4B	2	31E	D-4	B	A	06.0	GTV	MOA	O	OC	AI	N	FE-Q, ST-Q(C), PI-T	N	
2RHS*MOV4C	2	31B	I-9	B	A	06.0	GTV	MOA	O	OC	AI	N	FE-Q, ST-Q(C), PI-T	N	
2RHS*MOV67A	1	31A	F-10	A	A	02.0	GLV	MOA	C	C	AI	Y	LJ-R, PI-T, FE-CS, ST-CS(C), LK-R	Y	RHS-VCS-1, GVRR-1
2RHS*MOV67B	1	31A	K-10	A	A	02.0	GLV	MOA	C	C	AI	Y	LJ-R, PI-T, FE-CS, ST-CS(C), LK-R	Y	RHS-VCS-1, GVRR-1
2RHS*MOV80A	2	31D	H-9	A	A	01.0	GLV	MOA	C	C	AI	N	FE-Q, ST-Q(C), PI-T, LK-R	Y	SEE RHS-VCS-3



APPENDIX  
 FIRST YEAR INTERVAL  
 VALVE INSERVICE TESTING PROGRAM TABLE  
 NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RHS, RESIDUAL HEAT REMOVAL (RHR)

VALVE NUMBER	CODE CLASS	P & ID	COORD	V CAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	NRH	SAF	FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2RHS*MOV80B	2	31G	K-3	A	A	01.0	GLV	MOA	C	C	AI	N	FE-Q, ST-Q(C), PI-T, LK-R	Y	SEE RHS-VCS-3
2RHS*MOV8A	2	31F	B-3	B	A	18.0	BFV	MOA	0	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*MOV8B	2	31E	B-5	B	A	18.0	BFV	MOA	0	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*MOV9A	2	31F	H-2	B	A	18.0	BFV	MOA	0	OG	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*MOV9B	2	31E	C-5	B	A	18.0	BFV	MOA	0	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2RHS*PV21A	2	31D	D-9	A	A	08.0	GLV	AOA	C	C	C	N	FE-CS, ST-CS(C), FS-CS, LK-R, PI-T	Y	SEE RHS-VCS-3
2RHS*PV21B	2	31G	J-2	A	A	08.0	GLV	AOA	C	C	C	N	FE-CS, ST-CS(C), FS-CS, LK-R, PI-T	Y	SEE RHS-VCS-3
2RHS*RV108	2	31D	J-2	C	A	03.0	REV	SEA	C	0	-	N	RT-P2	N	
2RHS*RV110	2	31F	I-8	C	A	0.75	REV	SEA	C	0	-	N	RT-P2	N	
2RHS*RV152	2	31A	G-10	A, C	A	0.75	REV	SEA	C	0	-	Y	RT-P2, LJ-R	Y	GVRR-1
2RHS*RV20A	2	31C	A-5	C	A	0.75	REV	SEA	C	0	-	N	RT-P2	N	
2RHS*RV20B	2	31B	F-10	C	A	0.75	REV	SEA	C	0	-	N	RT-P2	N	
2RHS*RV20C	2	31B	H-6	C	A	0.75	REV	SEA	C	0	-	N	RT-P2	N	
2RHS*RVV35A	2	31C	D-4	A, C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	Y	GVRR-1, SET AT 0.2 PSID, SUBJECT TO APPENDIX J TYPE A TEST
2RHS*RVV35B	2	31C	I-5	A, C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	Y	GVRR-1, SET AT 0.2 PSID, SUBJECT TP APPENDIX J TYPE A TEST



APPENDIX  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RHS, RESIDUAL HEAT REMOVAL (RHR)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
									NRH	SAF	FAL	TYPE C			
2RHS*RVV36A	2	31C	D-4	A, C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	Y	GVRR-1, SET AT 0.2 PSID, SUBJECT TO APPENDIX J TYPE A TEST
2RHS*RVV36B	2	31C	J-5	A, C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	Y	GVRR-1, SET AT 0.2 PSID, SUBJECT TO APPENDIX J TYPE A TEST
2RHS*SOV120	2	31C	C-7	B	P	0.75	GLV	SOA	C	C	C	N	PI-T	N	
2RHS*SOV121	2	31C	C-7	B	P	0.75	GLV	SOA	C	C	C	N	PI-T	N	
2RHS*SOV35A	2	31D	G-7	B	A	0.75	GLV	SOA	C	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N	
2RHS*SOV35B	2	31E	D-8	B	A	0.75	GLV	SOA	C	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N	
2RHS*SOV36A	2	31D	G-6	B	A	0.75	GLV	SOA	C	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N	
2RHS*SOV36B	2	31E	D-7	B	A	0.75	GLV	SOA	C	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N	
2RHS*SOV70A	2	31D	E-10	B	A	01.0	GLV	SOA	OC	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	N	
2RHS*SOV70B	2	31E	J-5	B	A	01.0	GLV	SOA	OC	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2RHS*SOV71A	2	31D	E-10	B	A	01.0	GLV	SOA	OC	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2RHS*SOV71B	2	31E	J-6	B	A	01.0	GLV	SOA	OC	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2RHS*SOV72A	2	31D	G-9	B	A	01.0	GLV	SOA	OC	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2RHS*SOV72B	2	31G	J-5	B	A	01.0	GLV	SOA	OC	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3



APPENDIX F  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RHS, RESIDUAL HEAT REMOVAL (RHR)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRM	SAF	FAL				
2RHS*S0V73A	2	31D	G-9	B	A	01.0	GLV	SOA	OC	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2RHS*S0V73B	2	31G	J-5	B	A	01.0	GLV	SOA	OC	C	C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2RHS*SV34A	2	31D	B-2	C	A	04.0	REV	SEA	C	0	-	N	RT-P2	N	
2RHS*SV34B	2	31E	I-4	C	A	04.0	REV	SEA	C	0	-	N	RT-P2	N	
2RHS*SV62A	2	31D	A-2	C	A	06.0	REV	SEA	C	0	-	N	RT-P2	N	
2RHS*SV62B	2	31E	J-3	C	A	06.0	REV	SEA	C	0	-	N	RT-P2	N	
2RHS*V1	2	31F	C-5	C	A	18.0	CHV	SEA	C	0	N	N	FE-Q(F)	N	
2RHS*V143	1	31B	C-2	C	A	06.0	CHV	SEA	C	C	-	N	FE-CS(F)	N	SEE RHS-VCS-2
2RHS*V17	2	31G	D-3	B, C	A	02.0	SCV	SEA	0	0	-	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE
2RHS*V18	2	31G	D-3	C	A	02.0	CHV	SEA	0	0	-	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE
2RHS*V192	2	31E	J-2	A	P	0.75	GLV	HAA	LC	LC	AI	Y	LJ-R	Y	GVRR-1
2RHS*V2	2	31E	C-4	C	A	18.0	CHV	SEA	C	0	-	N	FE-Q(F)	N	
2RHS*V3	2	31G	B-3	C	A	18.0	CHV	SEA	C	0	-	N	FE-Q(F)	N	
2RHS*V47	2	31F	C-4	B, C	A	02.0	SCV	SEA	0	OC	-	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE



APPENDIX  
FIRST THERMAL INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : RHS, RESIDUAL HEAT REMOVAL (RHR)

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2RHS*V48	2 31F	D-4	C	A	02.0	CHV	SEA	0 OC -	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE
2RHS*V60	2 31G	E-2	C	A	02.0	CHV	SEA	0 OC -	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE
2RHS*V61	2 31G	E-1	B, C	A	02.0	SCV	SEA	0 OC -	N	FE-Q(R)	N	SATISFACTORY COMPLETION OF THE QUARTERLY PUMP TEST VERIFIES ACCEPTABLE OPERATION OF THIS VALVE
2RHS*V7	2 42A	C-6	C	A	06.0	CHV	SEA	C 0 -	N	FE-Q(F)	N	
2RHS*V8	2 31E	E-4	C	A	06.0	CHV	SEA	C 0 -	N	FE-Q(F)	N	
2RHS*V9	2 31B	H-9	C	A	06.0	CHV	SEA	C 0 -	N	FE-Q(F)	N	



APPENDIX  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : SAS, SERVICE AIR

VALVE NUMBER	CODE		COORD	VCAT	ACT PAS	SIZE	VALVE/ACTUAT		POSITIONS				TEST FREQ.(DIR)	RELIEF	REMARKS
	CLASS	P & ID					TYPE	TYPE	NRM	SAF	FAL	TYPE			
2SAS*HCV160	2	19J	H-6	A	P	02.0	GLV	MAA	C	C	-	Y	LJ-R, PI-T	Y	GVRR-1
2SAS*HCV161	2	19J	H-4	A	P	02.0	GLV	MAA	C	C	-	Y	LJ-R, PI-T	Y	GVRR-1
2SAS*HCV162	2	19J	I-6	A	P	02.0	GLV	MAA	C	C	-	Y	LJ-R, PI-T	Y	GVRR-1
2SAS*HCV163	2	19J	I-4	A	P	02.0	GLV	MAA	C	C	-	Y	LJ-R, PI-T	Y	GVRR-1



APPENDIX C  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : SFC, SPENT FUEL POOL COOLING AND CLEANUP (BWR)

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2SFC*A0V153	3 38A	I-10	B	A	08.0	BFV	AOA	0 C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2SFC*A0V154	3 38A	J-10	B	A	08.0	BFV	AOA	0 C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2SFC*A0V19A	3 38C	D-7	B	A	08.0	BFV	AOA	0C C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2SFC*A0V19B	3 38C	D-6	B	A	08.0	BFV	AOA	0C C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2SFC*HV17A	3 38B	J-3	B	A	08.0	BFV	AOA	0C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	SEE GVRR-3
2SFC*HV17B	3 38A	J-10	B	A	08.0	BFV	AOA	0C 0 0	N	FE-Q, ST-Q(0), FS-Q, PI-T	Y	SEE GVRR-3
2SFC*HV18A	3 38B	J-4	B	A	08.0	BFV	AOA	0C 0C C	N	FE-Q, ST-Q(0&C), FS-Q, PI-T	N	
2SFC*HV18B	3 38A	H-10	B	A	08.0	BFV	AOA	0C 0C C	N	FE-Q, ST-Q(0&C), FS-Q, PI-T	N	
2SFC*HV37A	3 38C	B-3	B	A	08.0	BFV	AOA	0 C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2SFC*HV37B	3 38C	C-3	B	A	08.0	BFV	AOA	0 C C	N	FE-Q, ST-Q(C), FS-Q, PI-T	Y	SEE GVRR-3
2SFC*V11	3 38B	C-10	C	A	08.0	CHV	SEA	0C 0 -	N	FE-Q(F)	N	
2SFC*V203	2 38C	F-7	A	P	1.50	GLV	HAA	C C -	Y	LJ-R	Y	GVRR-1
2SFC*V204	2 38C	F-8	A	P	1.50	GLV	HAA	C C -	Y	LJ-R	Y	GVRR-1
2SFC*V20A	3 38B	G-3	C	A	08.0	CHV	SEA	0C 0C -	N	FE-Q(F&R)	N	
2SFC*V20B	3 38A	F-10	C	A	08.0	CHV	SEA	0C 0C -	N	FE-Q(F&R)	N	
2SFC*V300A	3 38A	A-5	C	A	01.0	CHV	SEA	C 0 -	N	FE-Q(F)	N	
2SFC*V300B	3 38B	B-6	C	A	01.0	CHV	SEA	C 0 -	N	FE-Q(F)	N	




APPENDIX  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2  
SYSTEM : SFC, SPENT FUEL POOL COOLING AND CLEANUP (BWR)

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ.(DIR)	RELIEF	REMARKS
								NRM	SAF	FAL	TYPE C			
2SFC*V301A	3 38A	H-5	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F)	N	
2SFC*V301B	3 38B	I-9	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F)	N	
2SFC*V302	3 38A	E-2	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F)	N	
2SFC*V303	3 38A	K-7	C	A	01.0	CHV	SEA	C	0	-	N	FE-Q(F)	N	
2SFC*V9	3 38A	D-1	C	A	08.0	CHV	SEA	OC	C	-	N	FE-Q(F)	N	COMMENCE TESTING WHEN SYSTEM IS PLACED IN SERVICE



SYSTEM : SLS, STANDBY LIQUID CONTROL (SLC)

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TEST FREQ.(DIR)	RELIEF	REMARKS	
									NRM	SAF	FAL				
2SLS*HOV1A	2	36A	E-5	B	A	03.0	GLV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SLS*HOV1B	2	36A	E-9	B	A	03.0	GLV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SLS*HOV5A	1	36A	K-3	A, C	A	02.0	SCV	HOA	OC	OC	-	Y	FE-R(F&R), ST-R(C), PI-T, LJ-R	Y	SEE SLS-VRR-1, GVRR-1, TECH SPEC 3/4.1.5
2SLS*HOV5B	1	36A	J-3	A, C	A	02.0	SCV	HOA	OC	OC	-	Y	FE-R(F&R), ST-R(C), PI-T, LJ-R	Y	SEE SLS-VRR-1, GVRR-1, TECH SPEC 3/4.1.5
2SLS*RV2A	2	36A	H-4	C	A	0.75	REV	SEA	C	0	-	N	RT-P2	N	
2SLS*RV2B	2	36A	H-7	C	A	0.75	REV	SEA	C	0	-	N	RT-P2	N	
2SLS*V10	1	36A	J-1	A, C	A	02.0	CHV	SEA	C	OC	-	Y	FE-R(F&R), LJ-R	Y	SEE SLS-VRR-1, GVRR-1, TECH SPEC 3/4.1.5
2SLS*V12	2	36A	H-5	C	A	1.50	CHV	SEA	C	0	-	N	FE-Q(F), FE-R(R)	Y	SEE SLS-VRR-2
2SLS*V14	2	36A	H-8	C	A	1.50	CHV	SEA	C	0	-	N	FE-Q(F), FE-R(R)	Y	SEE SLS-VRR-2
2SLS*VEX3A	1	36A	J-5	D	A	1.50	EXV	EXA	C	0	-	N	EX-P5	N	
2SLS*VEX3B	1	36A	J-8	D	A	1.50	EXV	EXA	C	0	-	N	EX-P5	N	



APPENDIX C  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2  
SYSTEM : SVV, MAIN STEAM SAFETY VALVES, MAIN STEAM VENTS, MAIN STEAM DRAINS

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUATOR TYPE	POSITIONS NRM SAF FAL	TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
2SVV*RVV101	3 1A	D-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV102	3 1C	D-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV103	3 1D	D-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV104	3 1B	D-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV105	3 1C	F-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV106	3 1D	F-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV107	3 1A	F-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV108	3 1B	E-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV109	3 1C	G-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV110	3 1D	H-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV111	3 1A	G-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV112	3 1B	G-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV113	3 1C	I-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV114	3 1D	J-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV115	3 1A	I-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV116	3 1B	H-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV117	3 1C	J-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV118	3 1B	J-5	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV201	3 1A	D-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV202	3 1C	D-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV203	3 1D	D-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV204	3 1B	D-6	C	A	10.0	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID



APPENDIX E  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TEST PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : SVV, MAIN STEAM SAFETY VALVES}MAIN STEAM VENTS}MAIN STEAM DRAINS

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2SVV*RVV205	3	1C	F-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV206	3	1D	F-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV207	3	1A	F-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV208	3	1B	E-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV209	3	1C	G-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV210	3	1D	H-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV211	3	1A	G-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV212	3	1B	G-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV213	3	1C	I-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV214	3	1D	J-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV215	3	1A	I-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV216	3	1B	H-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV217	3	1C	J-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV218	3	1B	J-6	C	A	10.0	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV301	3	1A	C-6	C	A	02.5	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV302	3	1C	D-5	C	A	02.5	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV303	3	1D	E-6	C	A	02.5	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV304	3	1B	D-5	C	A	02.5	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV305	3	1C	F-5	C	A	02.5	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV306	3	1D	G-6	C	A	02.5	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV307	3	1A	F-6	C	A	02.5	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV308	3	1B	E-6	C	A	02.5	VRV	SEA	C	0	-	N	VT-P2	N	SETPOINT = 0.2 PSID



APPENDIX  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2  
SYSTEM : SVV, MAIN STEAM SAFETY VALVES)MAIN STEAM VENTS)MAIN STEAM DRAINS

VALVE NUMBER	CODE CLASS P & ID	COORD	V CAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2SVV*RVV309	3 1C	G-5	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV310	3 1D	I-6	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV311	3 1A	G-6	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV312	3 1B	G-5	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV313	3 1C	I-5	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV314	3 1D	K-6	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV315	3 1A	I-6	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV316	3 1B	I-5	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV317	3 1C	J-5	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID
2SVV*RVV318	3 1B	J-5	C	A	02.5	VRV	SEA	C 0 -	N	VT-P2	N	SETPOINT = 0.2 PSID



APPENDIX E  
FIRST TEST YEAR INTERVAL  
VALVE INSERVICE TESTING PROGRAM TABLE  
NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : SWP, SERVICE WATER

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.	(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL					
2SWP*AOV154A	3	11F	H-9	B	A	1.50	PGV	AOA	OC	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	PERIODIC TESTING WITH 2HVC*UC101A
2SWP*AOV154B	3	11F	D-8	B	A	1.50	PGV	AOA	OC	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	PERIODIC TESTING WITH 2HVC*UC101B
2SWP*AOV20A	3	11C	F-4	B	A	1.50	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	
2SWP*AOV20B	3	11P	G-7	B	A	02.0	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	
2SWP*AOV22A	3	11C	H-3	B	A	1.50	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	
2SWP*AOV22B	3	11P	J-10	B	A	02.0	GTV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	
2SWP*AOV571	3	11F	E-4	B	A	1.50	PGV	AOA	OC	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	PERIODIC TESTING WITH 2HVC*UC105
2SWP*AOV572	3	11P	A-5	B	A	02.0	PGV	AOA	OC	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	PERIODIC TESTING WITH 2HVC*UC104
2SWP*AOV573	3	11F	J-9	B	A	02.0	PGV	AOA	OC	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	PERIODIC TESTING WITH 2HVC*UC106
2SWP*AOV574	3	11F	F-9	B	A	02.0	PGV	AOA	OC	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	PERIODIC TESTING WITH 2HVC*UC107
2SWP*AOV581	3	11F	B-9	B	A	1.50	PGV	AOA	OC	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	PERIODIC TESTING WITH 2HVC*UC102
2SWP*AOV78A	3	11Q	E-9	B	A	02.0	PGV	AOA	OC	0	0	N	FE-Q, ST-Q(0), FS-Q		N	PERIODIC TESTING WITH 2HVC*UC108A
2SWP*AOV78B	3	11Q	J-9	B	A	02.0	PGV	AOA	OC	0	0	N	FE-Q, ST-Q(0), FS-Q		N	PERIODIC TESTING WITH 2HVC*UC108B
2SWP*AOV97A	3	11E	D-6	B	A	06.0	PGV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	PERIODIC TESTING WITH 2HVR*UC413A
2SWP*AOV97B	3	11F	I-5	B	A	06.0	PGV	AOA	C	0	0	N	FE-Q, ST-Q(0), FS-Q, PI-T		N	PERIODIC TESTING WITH 2HVR*UC413B



APPENDIX E  
 FIRST YEAR INTERVAL  
 VALVE INSERVICE TESTING PROGRAM TABLE  
 NINE MILE POINT NUCLEAR POWER STATION - UNIT 2

SYSTEM : SWP, SERVICE WATER

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ. (DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2SWP*HOV15A	3	11P	G-2	B	P	02.5	GTV	HOA	0	0	AI	N	PI-T	N	
2SWP*HOV15B	3	11G	B-7	B	P	02.5	GTV	HOA	0	0	AI	N	PI-T	N	
2SWP*HOV17A	3	11P	J-3	B	A	12.0	GTV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	VALVE IS PASSIVE UNTIL FIRST REFUELING
2SWP*HOV17B	3	11G	I-8	B	A	12.0	GTV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	VALVE IS PASSIVE UNTIL FIRST REFUELING
2SWP*HOV18A	3	11P	J-4	B	A	12.0	GTV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	VALVE IS PASSIVE UNTIL FIRST REFUELING
2SWP*HOV18B	3	11G	I-9	B	A	12.0	GTV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	VALVE IS PASSIVE UNTIL FIRST REFUELING
2SWP*HOV19A	3	11D	B-3	B	A	30.0	BFV	HOA	0	C	AI	N	FE-CS, ST-CS(C), PI-T	Y	SEE SWP-VCS-1
2SWP*HOV19B	3	11D	C-3	B	A	30.0	BFV	HOA	0	C	AI	N	FE-CS, ST-CS(C), PI-T	Y	SEE SWP-VCS-1
2SWP*HOV21A	3	11E	H-3	B	A	03.0	GTV	HOA	0	0	AI	N	FE-Q, ST-Q(O), PI-T	N	VALVE IS PASSIVE UNTIL FIRST REFUELING
2SWP*HOV21B	3	11F	H-2	B	A	03.0	GTV	HOA	0	0	AI	N	FE-Q, ST-Q(O), PI-T	N	VALVE IS PASSIVE UNTIL FIRST REFUELING
2SWP*HOV30A	3	11H	D-4	B	A	72.0	GTV	HOA	0	OC	AI	N	FE-Q, ST-Q(C), PI-T	N	
2SWP*HOV30B	3	11H	D-4	B	A	72.0	GTV	HOA	0	OC	AI	N	FE-Q, ST-Q(C), PI-T	N	
2SWP*HOV33A	3	11C	K-6	B	A	18.0	BFV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SWP*HOV33B	3	11P	E-10	B	A	18.0	BFV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SWP*HOV3A	3	11B	K-3	B	A	30.0	BFV	HOA	0	C	AI	N	FE-CS, ST-CS(C), PI-T	Y	SEE SWP-VCS-3



SYSTEM : SWP, SERVICE WATER

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
								NRM	SAF	FAL				
2SWP*MOV3B	3 11B	K-3	B	A	30.0	BFV	MOA	0	C	AI	N	FE-CS, ST-CS(C), PI-T	Y	SEE SWP-VCS-3
2SWP*MOV50A	3 11A	H-6	B	A	36.0	BFV	MOA	0	C	AI	N	FE-CS, ST-CS(C), PI-T	Y	SEE SWP-VCS-3
2SWP*MOV50B	3 11A	G-6	B	A	36.0	BFV	MOA	0	C	AI	N	FE-CS, ST-CS(C), PI-T	Y	SEE SWP-VCS-3
2SWP*MOV66A	3 11L	B-6	B	A	08.0	GTV	MOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SWP*MOV66B	3 11L	E-6	B	A	08.0	GTV	MOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SWP*MOV67A	3 11J	I-2	B	A	04.0	GTV	MOA	OC	0	AI	N	FE-Q, ST-Q(C), PI-T	N	
2SWP*MOV67B	3 11J	D-2	B	A	04.0	GTV	MOA	OC	0	AI	N	FE-Q, ST-Q(C), PI-T	N	
2SWP*MOV74A	3 11B	E-3	B	A	18.0	BFV	MOA	OC	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2SWP*MOV74B	3 11A	J-2	B	A	18.0	BFV	MOA	OC	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2SWP*MOV74C	3 11A	J-7	B	A	18.0	BFV	MOA	OC	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2SWP*MOV74D	3 11A	E-2	B	A	18.0	BFV	MOA	OC	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2SWP*MOV74E	3 11B	J-4	B	A	18.0	BFV	MOA	OC	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2SWP*MOV74F	3 11A	E-7	B	A	18.0	BFV	MOA	OC	OC	AI	N	FE-Q, ST-Q(O&C), PI-T	N	
2SWP*MOV77A	3 11H	D-3	B	A	48.0	GTV	MOA	C	0	AI	N	FE-R, ST-R(O), PI-T	Y	SEE SWP-VRR-1
2SWP*MOV77B	3 11H	D-3	B	A	48.0	GTV	MOA	C	0	AI	N	FE-R, ST-R(O), PI-T	Y	SEE SWP-VRR-1



SYSTEM : SWP, SERVICE WATER

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS			TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL				
2SWP*MOV90A	3	11C	K-4	B	A	18.0	BFV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SWP*MOV90B	3	11P	E-8	B	A	18.0	BFV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SWP*MOV94A	3	11L	I-8	B	A	08.0	GTV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SWP*MOV94B	3	11L	H-7	B	A	08.0	GTV	HOA	C	0	AI	N	FE-Q, ST-Q(O), PI-T	N	
2SWP*MOV95A	3	11L	C-2	B	A	08.0	GTV	HOA	0	OC	AI	N	FE-Q, ST-Q(C), PI-T	N	
2SWP*MOV95B	3	11L	F-3	B	A	08.0	GTV	HOA	0	OC	AI	N	FE-Q, ST-Q(C), PI-T	N	
2SWP*RV34A	3	11C	L-5	C	A	04.0	REV	SEA	C	0	AI	N	RT-P2	N	
2SWP*RV34B	3	11P	E-8	C	A	04.0	REV	SEA	C	0	AI	N	RT-P2	N	
2SWP*V1002A	3	11E	H-3	C	A	03.0	CHV	SEA	C	0	-	N	FE-Q(F)	Y	SEE SWP-VRR-3, VALVE IS PASSIVE UNTIL FIRST REFUELING
2SWP*V1002B	3	11F	H-2	C	A	03.0	CHV	SEA	C	0	-	N	FE-Q(F)	Y	SEE SWP-VRR-3, VALVE IS PASSIVE UNTIL FIRST REFUELING
2SWP*V1024	3	11E	I-2	C	A	06.0	CHV	SEA	0	OC	-	N	FE-R(R), FE-Q(F)	Y	TEST PER TECH SPEC 4.7.1.1.1.D, SEE SWP-VRR-2
2SWP*V1025	3	11F	F-1	C	A	06.0	CHV	SEA	0	OC	-	N	FE-R(R), FE-Q(F)	Y	TEST PER TECH SPEC 4.7.1.1.1.D, SEE SWP-VRR-2
2SWP*V1027	3	11A	B-7	C	A	30.0	CHV	SEA	OC	OC	-	N	FE-R(R), FE-Q(F)	Y	TEST PER TECH SPEC 4.7.1.1.1.D, SEE SWP-VRR-2
2SWP*V1A	3	11B	E-8	C	A	18.0	CHV	SEA	OC	OC	-	N	FE-Q(F&R)	N	



SYSTEM : SWP, SERVICE WATER

VALVE NUMBER	CODE CLASS	P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS				TEST FREQ.(DIR)	RELIEF	REMARKS
									NRH	SAF	FAL	TYPE C			
2SWP*V1B	3	11A	J-4	C	A	18.0	CHV	SEA	OC	OC	-	N	FE-0(F&R)	N	
2SWP*V1C	3	11A	J-9	C	A	18.0	CHV	SEA	OC	OC	-	N	FE-0(F&R)	N	
2SWP*V1D	3	11A	E-4	C	A	18.0	CHV	SEA	OC	OC	-	N	FE-0(F&R)	N	
2SWP*V1E	3	11B	J-8	C	A	18.0	CHV	SEA	OC	OC	-	N	FE-0(F&R)	N	
2SWP*V1F	3	11A	E-9	C	A	18.0	CHV	SEA	OC	OC	-	N	FE-0(F&R)	N	
2SWP*V201A	3	11F	B-6	C	A	01.2	CHV	SEA	OC	0	-	N	FE-0(F)	N	
2SWP*V201B	3	11F	B-6	C	A	01.2	CHV	SEA	OC	0	-	N	FE-0(F)	N	
2SWP*V202A	3	11B	C-2	C	A	30.0	CHV	SEA	OC	OC	-	N	FE-R(R), FE-0(F)	Y	TEST PER TECH SPEC 4.7.1.1.1.D, SEE SWP-VRR-2
2SWP*V219A	3	11J	I-3	C	A	04.0	CHV	SEA	OC	OC	-	N	FE-0(F)	N	
2SWP*V219B	3	11J	D-3	C	A	04.0	CHV	SEA	OC	OC	-	N	FE-0(F)	N	
2SWP*V240A	3	11J	J-5	C	A	04.0	CHV	SEA	OC	OC	-	N	FE-0(F&R)	N	
2SWP*V240B	3	11J	E-5	C	A	04.0	CHV	SEA	OC	OC	-	N	FE-0(F&R)	N	
2SWP*V259	3	11L	I-3	C	A	08.0	CHV	SEA	OC	OC	-	N	FE-0(F&R)	N	
2SWP*V260	3	11L	I-3	C	A	08.0	CHV	SEA	OC	OC	-	N	FE-0(F&R)	N	
2SWP*V75A	3	11L	D-7	C	A	08.0	CHV	SEA	C	0	-	N	FE-0(F&R)	N	
2SWP*V75B	3	11L	E-7	C	A	08.0	CHV	SEA	C	0	-	N	FE-0(F&R)	N	
2SWP*V800A	3	11F	B-9	C	A	01.2	CHV	SEA	OC	0	-	N	FE-0(F)	N	
2SWP*V800B	3	11F	C-9	C	A	01.2	CHV	SEA	OC	0	-	N	FE-0(F)	N	
2SWP*V802A	3	11F	B-10	C	A	03.0	CHV	SEA	OC	0	-	N	FE-0(F)	N	
2SWP*V802B	3	11F	C-10	C	A	03.0	CHV	SEA	OC	0	-	N	FE-0(F)	N	



SYSTEM : WCS, REACTOR WATER CLEANUP (RWCU)

VALVE NUMBER	CODE CLASS P & ID	COORD	VCAT	ACT PAS	SIZE	VALVE TYPE	ACTUAT TYPE	POSITIONS NRH SAF FAL	TYPE C	TEST FREQ.(DIR)	RELIEF	REMARKS
2WCS*EFV221	2 37A	G-7	A, C	A	0.75	CHV	SEA	0 C -	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2WCS*EFV222	2 37A	G-5	A, C	A	0.75	CHV	SEA	0 C -	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2WCS*EFV223	2 37A	H-4	A, C	A	0.75	CHV	SEA	0 C -	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2WCS*EFV224	2 37A	H-3	A, C	A	0.75	CHV	SEA	0 C -	N	PI-T, FE-R(F), LJ-R	Y	GVRR-2, GVRR-1
2WCS*EFV300	2 37A	G-6	A, C	A	0.75	CHV	SEA	0 C -	N	LJ-R, FE-R(F), PI-T	Y	GVRR-2, GVRR-1
2WCS*HOV102	1 37A	F-5	A	A	08.0	GLV	HOA	0 C AI	Y	FE-CS, ST-CS(Q), PI-T, LJ-R	Y	SEE GVRR-1
2WCS*HOV112	1 37A	G-5	A	A	08.0	GLV	HOA	0 C AI	Y	FE-CS, ST-CS(Q), PI-T, LJ-R	Y	WCS-VCS-1, GVRR-1
2WCS*HOV200	1 37B	D-9	A	A	08.0	GLV	HOA	0 C AI	Y	FE-CS, ST-CS(Q), PI-T, LJ-R	Y	GVRR-1, WCS-VCS-1



Lines read 9073, records: 361, pages: 0

User: MWO -at

Label: PRT002 -form 600LPM

ISI

