

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8709010132 DOC. DATE: 87/08/24 NOTARIZED: NO DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 LAZARUS, W. J. Region 1, Office of Director
 RECIP. NAME RECIPIENT AFFILIATION
 CHWALEK, T. Niagara Mohawk Power Corp.

SUBJECT: Forwards comments re 870706 scenario for 870826 partial scale emergency exercise. Remaining clarification may be discussed at briefing prior to drill.

DISTRIBUTION CODE: IE35D, COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Emergency Preparedness-Appraisal/Confirmatory Action Ltr/Exercise Rep

NOTES: 21 05000410

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-1 PD BENEDICT, B	1 1 1 1	HAUGHEY, M	1 1
INTERNAL:	ARM/DAF/LFMB NRR/PMAS/ILRB RGN1 FILE 01	1 0 1 1 1 1	NRR/DREP/EPB REG FILE 02 RGN2/DRSS/EPRPB	1 1 1 1 1 1
EXTERNAL:	LPDR NSIC	1 1 1 1	NRC PDR	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 11



AUG 24 1987

Docket Nos. 50-220
50-410

Niagara Mohawk Power Corporation
ATTN: T. Chwalek
Emergency Coordinator
301 Plainfield Road
Syracuse, New York 13212

Gentlemen:

Subject: Nine Mile Unit 2 Emergency Exercise Review Comments

This is in response to the letter of July 6, 1987 transmitting the scenario for the partial-scale exercise scheduled for August 26, 1987. We have reviewed the exercise package and provide the enclosed comments. These comments were discussed by telephone on July 27, 1987 with you and members of my staff. Any remaining clarification may be discussed at the briefing prior to the drill.

Should you have any questions in regard to our review, contact Mr. T. Tuccinardi (215) 337-5390 or Mr. E. Fox (215) 337-5044.

Sincerely,
Original Signed By:

William J. Lazarus, Chief
Emergency Preparedness Section
Division of Radiation Safety
and Safeguards

Enclosure:
As stated

OFFICIAL RECORD COPY

8709010132 870824
PDR ADOCK 05000410
F PDR

11 IE35



AUG 24 1987

cc w/encl:


T. E. Lempges, Vice President, Nuclear Generation
T. Perkins, General Superintendent, Nuclear Generation
W. Hansen, Manager of Quality Assurance
J. A. Perry, Vice President, Quality Assurance
T. Roman, Station Superintendent
J. Aldrich, Supervisor, Operations
W. Drews, Technical Superintendent
Troy B. Conner, Jr., Esquire
John W. Keib, Esquire
Director, Power Division
Conner & Wetterhahn
D. Quamme, NMP-2 Project Director
C. Beckham, NMPC QA Manager
R. B. Abbott, Station Superintendent
Department of Public Service, State of New York
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New York




AUG 24 1987

bcc w/encl:
Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
DRP Section Chief
Robert J. Bores, DRSS

RI:DRSS
Tuccinardi
8/17/87


RI:DRSS
Lazarus
8/18/87


RI:DRSS
Bellamy
8/18/87

OFFICIAL RECORD COPY



NINE MILE UNIT 2
EMERGENCY EXERCISE REVIEW COMMENTS
AUGUST 26, 1987

1. Release rate ($\mu\text{Ci}/\text{sec}$) values for the stack effluent monitors, particulate iodine and noble gas concentrations, and stack flow rates were omitted from the process rad monitor data in Section 8.1.
2. The status of emergency condensers (11/12) was omitted on the plant parameters and equipment status sheets (Section 8.3).
3. Onsite whole body dose rate values were omitted from Section 9.3.
4. There appears to be a discrepancy between reactor building vent monitors. The CAM is O.S.H. from 1100 to 1230 while channels 11 and 12 of the vent monitor remain constant throughout the exercise at 1.1 and 1.6 mR/hr.
5. -Supplemental scenario #1 implies that the controller will ensure the repair team is evacuated from the reactor building (elevation 237) before fuel damage occurs. Evacuation should be initiated by the players in anticipation of fuel failure.
6. Plant status, Message No. 28. The time is incorrect. It should be 1230 instead of 1215.

