

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8709010392 DOC. DATE: 87/08/25 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH. NAME AUTHOR AFFILIATION
 LEMPGES, T. E. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards application for amend to License DPR-63 & proposed change to Tech Specs. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+7
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD1-1 LA	1	0	PD1-1 PD	5	5
	BENEDICT, R	1	1	HAUGHEY, M	1	1
INTERNAL:	ARM/DAF/LFMB	1	0	NRR/DEST/ADS	1	1
	NRR/DEST/CEB	1	1	NRR/DEST/MTB	1	1
	NRR/DEST/RSB	1	1	NRR/DOEA/TSB	1	1
	NRR/BMAS/ILRB	1	1	OGC/HDS1	1	0
	<u>REC FILE</u> 01	1	1	RES/DE/EIB	1	1
EXTERNAL:	EG&G BRUSKE, S	1	1	LPDR	1	1
	NRC PDR	1	1	NSIC	1	1

REC'D w/check
 #162851

10-1

10-1
10-1

August 25, 1987
(NMP1L 0178)U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555Re: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an application for amendment to the Nine Mile Point Unit 1 Operating License DPR-63. Also enclosed is the proposed change to the Technical Specifications in Appendix A of the above mentioned license. Pursuant to 10CFR170.12, a one hundred fifty dollar (\$150.00) application fee is enclosed.

The proposed Technical Specifications contained herein represent a revision to Specification 3.2.7 Reactor Coolant System Isolation Valves. The proposed amendment will increase the maximum operating (closure) time of the emergency cooling high point vent and main steam warmup isolation valves to ten (10) seconds to be consistent with the closure time of the main steam isolation valves. In addition, the emergency cooling drain line vent isolation valves are being added to Table 3.2.7. A closure time of ten (10) seconds is specified for these valves to be consistent with the closure time of the valves identified above. This proposed amendment should be reviewed in conjunction with our amendment request dated November, 1985.

Pursuant to 10CFR59.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analysis regarding no significant hazard considerations to the appropriate state representative.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

T. E. Lempges
Vice President
Nuclear GenerationDPS/pns/0184S
Enclosuresxc: Regional Administrator, Region I
Mr. R. A. Capra, Director
Mr. R. A. Benedict, Project Manager
Mr. W. A. Cook, Resident InspectorMr. Jay Dunkleberger
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, NY 122238709010392 870825
PDR ADDCK 05000220
P PDRREC'D w/CHECK
#162851A001
1/1

