

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8709220366 DOC. DATE: 87/09/16 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 WENZINGER, E. C. Region 1, Office of Director
 RECIP. NAME RECIPIENT AFFILIATION
 MANGAN, C. V. Niagara Mohawk Power Corp.

SUBJECT: Forwards Combined Insp Repts 50-220/87-10 & 50-410/87-20 on
 870608-0719 & notice of violation.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+23
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: 21

05000410

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-1 PD	1 1	BENEDICT, R	2 2
	HAUGHEY, M	2 2	BENEDICT, B	2 2
INTERNAL:	ACRS	2 2	AEOD	1 1
	DEDRO	1 1	NRR MORISSEAU, D	1 1
	NRR/DOEA DIR	1 1	NRR/DREP/EPB	1 1
	NRR/DREP/RPB	2 2	NRR/DRIS DIR	1 1
	NRR/PMAS/ILRB	1 1	DE LIEBERMAN, J	1 1
	OGC/HDS1	1 1	REG. FILE	1 1
	RES DEPY GI	1 1	RGN1 FILE 01	1 1
INTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		



QCS

16 SEP 1987

Docket No. 50-220
Docket No. 50-410

Niagara Mohawk Power Corporation
ATTN: Mr. Charles V. Mangan
Senior Vice President - Nuclear
301 Plainfield Road
Syracuse, New York 13212

Gentlemen:

Subject: Combined Inspection 50-220/87-10 and 50-410/87-20

This refers to the routine inspection conducted by Messrs. W. Cook, C. Marschall and W. Schmidt of this office on June 8, 1987 to July 19, 1987 at Nine Mile Point Units 1 and 2, Scriba, New York. A summary of the findings was presented to Mr. R. Abbott, Mr. J. Aldrich and other members of your staff at the conclusion of the inspection.

Based on our review, the June 18, 1987 licensee identified Technical Specification Fire Protection Program violation, involving missed fire watch patrols, was the third such related violation in recent months. It appears that your corrective actions to preclude recurrence have been ineffective. As a result, a Notice of Violation (Appendix A) has been issued. This violation has been categorized by severity level according to 10 CFR Part 2, Appendix C (Enforcement Policy). You are required to respond to this violation and in preparing your response you should follow the instructions in Appendix A.

The response requested by this letter is not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL96-511.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:

Edward C. Wenzinger, Chief
Projects Branch No. 2
Division of Reactor Projects

Enclosures:

- 1. Appendix A, Notice of Violation
- 2. NRC Region I Combined Inspection Report Number 50-220/87-10 and 50-410/87-20

IE0111

8709220366 870916
PDR ADOCK 0500220
Q PDR

OFFICIAL RECORD COPY

CIR NMP 87-10/20 - 0001.0.0
09/09/87



cc w/encls:

Connor & Wetterhahn
John W. Keib, Esquire
T.E. Lempges, Vice President, Nuclear Generation
T.J. Perkins, General Superintendent
T.W. Roman, Station Superintendent, Unit 1
R.B. Abbott, Station Superintendent, Unit 2
J.A. Perry, Vice President, Quality Assurance
A.Z. Pinter, NMPC Site Licensing
C.G. Beckham, Manager, Quality Assurance
Troy B. Conner, Jr., Esquire
Director, Power Division
Department of Public Service, State of New York
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New York

bcc w/encls:

Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encls)
Chief, Engineering Programs Branch
J. Johnson, Section Chief, DRP
State Liaison Officer (SLO)

RI:DRP
Johnson/rhl

9/9/87

RI:DRP
Ventzinger

9/16/87

OFFICIAL RECORD COPY

CIR NMP 87-10/20 - 0002.0.0
09/09/87

