

UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
NIAGARA MOHAWK POWER CORPORATION)
(Nine Mile Point Nuclear Station Unit No. 1)

Docket No. 50-220

APPLICATION FOR AMENDMENT
TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. DPR-63, hereby requests that Sections 3.2.6 and 4.2.6 of the Technical Specifications set forth in Appendix A to that License be amended. These proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specification changes are set forth in Attachment A to this application. Technical Specifications 3.2.6 and 4.2.6 referencing the Inservice Inspection and Testing Programs currently in effect have been revised to delete references 1 and 2 located at the bottom of the page. The bases have been revised to include these references to the Inservice Inspection and Testing Programs which are currently in effect. In addition, the bases has also been revised to permit approved alternatives to the EPRI program to be used for the qualification of procedures and personnel performing augmented inspections.

3058G

BB02090500	BB0129
PDR	ADDOCK 05000220
P	PDR



Technical Specification 4.2.6.a.2 has been changed to delete the list of systems which contain non-conforming components. The systems containing non-conforming components are identified in the augmented Inservice Inspection Program. The augmented Inservice Inspection Program identifies all non-conforming components instead of only service sensitive components. This change is consistent with the terminology of NUREG 0313, Revision 1.

The proposed change would not authorize any change in the types of effluents or in the authorized power level of the facility in conjunction with this Application for License Amendment. Supporting information and analysis which demonstrate that the proposed changes involve no significant hazards considerations pursuant to 10CFR50.92, are included as Attachment B.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By C. V. Mangan
C. V. Mangan
Senior Vice President

Subscribed and sworn to before me
on this 29th day of January 1988.

BETH A. MENIKHEIM
Notary Public in the State of New York
Qualified in Onondaga County No. 4804074
My Commission Expires August 31, 1988.

