

UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
NIAGARA MOHAWK POWER CORPORATION )  
(Nine Mile Point Nuclear Station Unit No. 1)

Docket No. 50-220

APPLICATION FOR AMENDMENT  
TO  
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. DPR-63, hereby requests that Section 1.0 of the Technical Specifications set forth in Appendix A to that License be amended. The proposed change has been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specification change is set forth in Attachment A to this application. Section 1.1.b Shutdown Condition-Hot is being proposed for amendment to permit reactor vessel hydrotesting in conjunction with control rod scram time testing with the reactor mode switch in the refuel position and the reactor coolant temperature greater than 212°F. Supporting information and analysis which demonstrate that the proposed change involves no significant hazards consideration pursuant to 10CFR50.92, are included as Attachment B.

8802170217 880205  
PDR ADOCK 05000220  
P PDR

0192S



WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By C. W. Noman  
Senior Vice President

Subscribed and sworn to before me  
on this 5<sup>th</sup> day of February 1988.

BETH A. MENIKHEIM

Notary Public in the State of New York  
Qualified in Onondaga County No. 4804074  
My Commission Expires August 31, 1988

Beth A. Menikheim

