

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8802290326      DOC. DATE: 88/02/19      NOTARIZED: NO      DOCKET #  
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha      05000410  
 AUTH. NAME      AUTHOR AFFILIATION  
 MANGAN, C.V.      Niagara Mohawk Power Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC request for commitment to assure replacement of equipment located in zones specified to meet new temps.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution


NOTES: 21

05000410D

	RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL	
	PD1-1 LA		1	0	
	HAUGHEY, M		1	1	
INTERNAL:	ARM/DAF/LFMB		1	0	
	NRR/DEST/CEB8H7		1	1	
	NRR/DEST/RSB 8E		1	1	
	NRR/FMAS/ILRB12		1	1	
	REG FILE 01		1	1	
EXTERNAL:	LPDR		1	1	
	NSIC		1	1	
	PD1-1 PD		5	5	
	BENEDICT, B		1	1	
	NRR/DEST/ADS7E4		1	1	
	NRR/DEST/MTB 9H		1	1	
	NRR/DOEA/TSB11F		1	1	
	OGC 15-B-18		1	0	
	RES/DE/EIB		1	1	
	NRC PDR		1	1	

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 18

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



February 19, 1988  
NMP2L 1114U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555Re: Nine Mile Point Unit 2  
Docket No. 50-410  
NPF-69

Gentlemen:

Niagara Mohawk's letter dated August 3, 1987 (NMP2L 1066), transmitted a proposed Technical Specification change to increase the allowable service water supply header discharge temperature limit to 81°F. It was indicated in this submittal, under the discussion of equipment qualification, that the increased service water temperature affects the design normal maximum temperatures for three zones in the control building, and that all equipment in these zones is qualified to temperatures higher than the new calculated maximum temperatures. In a conversation with members of the Nuclear Regulatory Commission staff, a commitment was requested to assure that replacement of equipment located in these zones be specified to meet the new design maximum temperatures. This letter provides a response to the commitment requested by the Nuclear Regulatory Commission staff.

The three zones in the control building affected by the design normal maximum temperatures are the Division I and II cable areas and Division I riser area. The design normal maximum temperatures for these zones are specified in the Equipment Qualification Environmental Design Criteria (EQEDC) document. The previously specified temperature for these zones was 104°F. The EQEDC document was revised (Revision 4) on October 7, 1987, to incorporate the new calculated design normal maximum temperatures of 107°F, 106.4°F and 108°F, respectively, based on 82°F service water. The revision of the EQEDC documents assures that replacement of equipment in these zones will be procured in accordance with the new design normal maximum temperatures.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

*Cermanyan*  
C. V. Mangan  
Senior Vice PresidentLSL/pns/4458G  
cc: Regional Administrator, Region I  
Mr. R. A. Capra, Director  
Ms. M. F. Haughey, Project Manager  
Mr. W. A. Cook, Resident Inspector8802290326 880219  
PDR ADOCK 05000410  
P DCD*Acc  
1/10*

1000



Faint, illegible text at the bottom of the page, possibly bleed-through from the reverse side.