

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

#### NIAGARA MOHAWK POWER CORPORATION

#### DOCKET NO. 50-410

## NINE MILE POINT NUCLEAR STATION, UNIT 2

## AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 4 License No. NPF-69

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated February 3, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-69 is hereby amended to read as follows:

8804190076 880411 PDR ADDCK 05000410 PDR

~

,ïi \* \*

,

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. 4 are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance, and is to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert a. Copra

Robert A. Capra, Director Project Directorate I-1 Division of Reactor Projects, I/II

Attachment: Changes to the Technical Specifications

Date of Issuance: April 11, 1988

.

.

,

.

,

## ATTACHMENT TO LICENSE AMENDMENT

# AMENDMENT NO. 4 TO FACILITY OPERATING LICENSE NO. NPF-69

## DOCKET NO. 50-410

Revise Appendix A as follows:

<u>Remove Page</u>

Insert Page 3/3 3-19

3/4 3-19

- •

•

£

# TABLE 3.3.2-2 (Continued)

# ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

TRIP FUNCTION		TRIP SETPOINT	ALLOWABLE VALUE
2.	RCIC Isolation Signals (Continued)		
	d. RCIC Turbine Exhaust Diaphragm Pressure - High	<u>&lt;</u> 10 psig	<u>&lt;</u> 20 psig
	e. RCIC Equipment Area Temperature - High	<u>&lt;</u> 135°F	<u>&lt;</u> 140.5°F
	f. RCIC Steam Line Tunnel Temperature - High	<u>≺</u> 135°F	<u>&lt;</u> 140.5°F
•	g. Manual Isolation Push Button [RCIC]	NA	NA
	h. Drywell Pressure - High	<u>&lt;</u> 1.68 psig	<u>&lt;</u> 1.88 psig
	i. RHR/RCIC Steam Flow - High	<u>&lt;</u> 37.4 in.H <sub>2</sub> 0	<u>&lt;</u> 40.73 in. H <sub>2</sub> O
3.	Secondary Containment Isolation Signals	ŀ	•
	a. Reactor Building Above the Refuel Floor Exhaust Radiation - High	<u>&lt;</u> 2.36 x 10 <sup>-3</sup> μCi/cc	<u>&lt;</u> 2.46 x 10 <sup>-3</sup> µCi/cc
	b. Reactor Building Below the Refuel Floor Exhaust Radiation - High	<u>&lt;</u> 2.36 x 10 <sup>-3</sup> µCi/cc	≤ 2.46 x 10 <sup>-3</sup> µCi/cc

\* See Bases Figure B3/4 3-1.

Amendment No. 4

.

, , ,

•