

OPERATING DATA REPORT

DOCKET NO. 50-220
 DATE 7/8/88
 COMPLETED BY T. Roman
 TELEPHONE (315) 349-2422

OPERATING STATUS

1. Unit Name: Nine Mile Point Unit 1
2. Reporting Period: 6/1/88 through 6/30/88
3. Licensed Thermal Power (MWt): 1850
4. Nameplate Rating (Gross MWe): 640
5. Design Electrical Rating (Net MWe): 620
6. Maximum Dependable Capacity (Gross MWe): 630
7. Maximum Dependable Capacity (Net MWe): 610
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720.0	4,367.0	164,712.2
12. Number Of Hours Reactor Was Critical	0.0	0.0	115,234.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	1,204.2
14. Hours Generator On-Line	0.0	0.0	112,117.2
15. Unit Reserve Shutdown Hours	0.0	0.0	20.4
16. Gross Thermal Energy Generated (MWH)	0.0	0.0	188,473,132.0
17. Gross Electrical Energy Generated (MWH)	0.0	0.0	62,473,070.0
18. Net Electrical Energy Generated (MWH)	0.0	0.0	60,524,382.0
19. Unit Service Factor	0.0	0.0	68.1
20. Unit Availability Factor	0.0	0.0	68.1
21. Unit Capacity Factor (Using MDC Net)	0.0	0.0	60.2
22. Unit Capacity Factor (Using DER Net)	0.0	0.0	59.3
23. Unit Forced Outage Rate	0.0	100.0	14.9

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):


Refuel Outage started on January 22, 1988.

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 8/4/88

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

8807200095 880630
 PDR ADDCK 05000220
 R PNU

IE 24
 111
 (9/77)



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-220

UNIT NMP-1

DATE July 8, 1988

COMPLETED BY T. Roman *TR*


TELEPHONE (315) 349-2422

MONTH JUNE 1988

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>	31	<u>0</u>
16	<u>0</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.



..

.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JUNE 1988

DOCKET NO. 50-220
 UNIT NAME NMP-1
 DATE July 8, 1988
 COMPLETED BY T. Roman
 TELEPHONE (315)349-2422

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
	880122	S		C	4				The decision was made to start the Refuel Outage since the plant was already shutdown due to problems with the F.W. System.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

(9/77)



• •

•

•

•

•

•

• •

•

•


•

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT NUCLEAR STATION UNIT 1
NARRATIVE OF OPERATING EXPERIENCE

The station operated during the month of June 1988 with a Unit Availability Factor of 0.0% and a Net Design Electrical Capacity Factor of 0.0%. There were no challenges to Electromatic Relief Valves. Reductions in Capacity Factor were due to Refuel Outage.

CLASS I WORK - MECHANICAL MAINTENANCE - JUNE 1988

WR# 133976	System 32. #14 Reactor Recirc. Pump. Replaced parts.
WR# 141781	System 32. 11 Reactor Recirc. Pump Discharge Valve. Repacked.
WR# 141112	System 34. Head Spray Check Valve. Replaced valve.
WR# 140844	System 41. Liquid Poison. Replaced parts.
WR# 140845	System 41. Liquid Poison. Replaced parts.
WR# 141007	System 44. CRD Hydraulic Control Unit 30-27. Repair.
WR# 132262	System 54. Spent fuel pool inner and outer gates. Removed gates from water for RP and ALARA.
WR# 141830	System 44.2. CRD. Adjusted.
WR# 142177	System 44. 126 valve on CRD (26-03). Replaced parts.
WR# 142261	System 44. Disphragm for 127 valve (22-03). Replaced parts.
WR# 132023	System 72. Service Water Supply to Rx. Bldg. Check valve. Inspection.
WR# 132516	System 70. 11 RBCLC heat exchanger 70-13R drain/vent valve. Packed valves.
WR# 132945	System 201.2. Drywell O ₂ sampling. Installed "O" rings, clean and check valve.
WR# 133241	System DG. 103 Diesel Generator. Check discharge direction.
WR# 141229	System 39. EMC-39-HS-22. Replaced parts.
WR# 141230	System 39. EMC-39-HS-20. Replaced parts.
WR# 141231	System 39. EMC-39-HS-34. Replaced parts.
WR# 141403	System DG. 103 Diesel Generator. Replaced parts.
WR# 141543	System 202. RB Emergency Vent Fan 11. Replaced parts.
WR# 141592	System 81. Core Spray Spectacle flanges. Replaced parts.
WR# 141793	System 32. Recirc. decon. flanges Rx. Recirc. loop #12. Replaced parts.
WR# 141796	System 32. Recirc. decon. flanges Rx. Recirc. loop #14. Replaced parts.



WR# 141797	System 32. Recirc. decon flanges Rx. Recirc. loop #15. Replaced parts.
WR# 142015	System 93. Cont. Spray Raw Water. Repair support.
WR# 142018	System 1. Main Steam. Repair valve.
WR# 142019	System 1. Main Steam. Repair valve.
WR# 142020	System 80. Containment Spray. Repair support.
WR# 141794	System 32. Recirc. Decon. flange Rx. Recirc. loop #11. Replaced parts.
WR# 141795	System 32. Recirc. Decon. flange Rx. Recirc. loop #13. Replaced parts.
WR# 142012	System 39. Emergency Condenser. Readjusted.
WR# 142255	System 44. 127 Valve Diaphragm leaks. Replaced parts.
WR# 140358	System 44.2. CRD Scram Valve timing. Set timing.
WR# 142260	System 44.2. CRD Scram Valve 30-43. Replaced parts.
WR# 142258	System 44.2. CRD Scram Valve 18-35-127. Replaced parts.
WR# 108944	System 79. Emergency Diesel Gen. Cooling H ₂ O pump #103. Replaced parts.
WR# 141712	System PHS. Penetration #TC.282. Replaced cement with flamastic.
WR# 140839	System 38. Reactor Shutdown Cooling. Repair.
WR# 127111	System 72. Service Water Check Valve 72-22. Replaced parts.
WR# 142021	System 93. Cont. Spray Raw Water. Retighten nut.
WR# 140140	System 201.2. Tip N ₂ purge check valve 201.2-39. Rebuilt check valve.
WR# 140141	System 201.2. Tip N ₂ purge check valve 201.2-40. Rebuilt check valve.
WR# 141717	System PHS. Un-numbered penetration. Repair-add sealant.
WR# 141711	System PHS. Un-numbered penetration. Repair-add sealant.
WR# 141725	System PHS. Un-numbered penetration. Replaced parts.
WR# 141890	System 70. Heat exchanger 70-13R. Packed valve.
WR# 142016	System 93. Cont. Spray Raw Water. Readjusted.
WR# 141010	System RXBM. Spent fuel pool outer gate. Inspection.
WR# 100201	System 80. Cont. Spray 4T Exchanger Inlet. Replaced parts.
WR# 132732	System TBM. Cable tray rod hanger. Replaced parts.
WR# 141615	System DG. 102 Diesel Generator cooling water heat exchanger. Replaced parts.
WR# 100201	System 70. CTN Sp. Heat exchanger inlet. Replaced parts.
WR# 142033	System 93. Cont. Spray Cooling Raw Water. Adjusted.
WR# 142032	System 93. Cont. Spray Cooling Raw Water. Additional nut added.
WR# 139851	System 39. EMC supply and return 39-HS-10. Inspection
WR# 142232	System 44. CRD Accum. 127 valve. Replaced parts.
WR# 142244	System 44. CRD 38-07 Scram Valve Diaphragms. Replaced parts.
WR# 142245	System 44. HCU 38-11 126 valve. Replaced parts.
WR# 140425	System 60. Emerg. Condenser LCV 60-17. Replaced parts.
WR# 134088	System 70. RBCLC Hx 70-13R. Replaced parts.
WR# 141411	System 93. Drywell Equip. Drain IV. Replaced packing and parts.



WR# 113369 System 32. Snubber 32-13-SB-1A on Recirc. #13. Adjustment.
 WR# 142243 System 44. CRD 30-03. Scram Valve Diaphragm. Replaced parts.
 WR# 134586 System 70. #13.RBCLC pump. Replaced parts.
 WR# 102882 System 93. Block valve. Replaced parts.
 WR# 140746 System 39. Emergency Cooling IV 39-05. Refurbished.
 WR# 134088 System 2. RBCLC Hx 70-13R. Replaced parts.
 WR# 142421 System 2. #12 IAC aftercooler. Replaced parts.
 WR# 141557 System 3. #11. IA Dryer filters. Replaced parts.
 WR# 134043 System 6. MS ERV 01-113. Repaired component.
 WR# 140266 System 01. MS ERV 01-112. Repair. component.
 WR# 112417 System 44.2. Spare magnetrol. Cleaned and repaired.
 WR# 140835 System 54. Fuel Pool Cooling 54-R6-D. Replaced parts.
 WR# 141644 System 72. Emergency Service Water pump #11 discharge check valve. Replaced parts.
 WR# 142313 System 210.1. Chilled water control room. Repaired component.
 WR# 132916 System RXBM. Perform work to support new fuel bundle and channels. Performed inspections.
 WR# 133292 System 001. Snubber 01-HS-4. Rebuilt.
 WR# 142536 System 31. Feedwater. Replaced parts (support).
 WR# 113361 System 32. RCS System hangers/Snubbers. Loose parts.
 WR# 105519 System 39. Hydraulic Snubber. Rebuilt Snubber.
 WR# 142405 System 44. CRD 46-27. Replaced parts.
 WR# 142406 System 44. CRD 50-19. Replaced parts.
 WR# 141617 System 70. RBCLC Temp. Control Valve. Replaced parts.
 WR# 133240 System 94. After cooler for #11 I.A. Compressor. Replaced parts.
 WR# 105044 System 209. Hydraulic Snubber. Rebuilt.
 WR# 141886 System 01. Main Steam Electromatic. Replaced parts.
 WR# 142519 System 34. Rx head spray. Removed bolts ISI Inspection.
 WR# 142690 System 36. RPV Instrument lines. Repaired support 36-HS-6.
 WR# 142689 System 36. RPV Instrument lines. Repaired support 36-HS-5.
 WR# 142691 System 36. Reactor Instrument lines. Repaired support 36-HS-7.
 WR# 140151 System 39. Emergency Cooling Return IV. Repaired component.
 WR# 140819 System 39. EMC 39-HS-32. Adjustment.
 WR# 142528 System 39. EMC 39-HS-14. Repair component.
 WR# 140972 System 44.2. Scram pilot valves. Replaced parts.
 WR# 140537 System 44.2. CRD 22-19. Replaced parts.
 WR# 142701 System 81. Rx. Core Spray. Relabled support.



[The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and cannot be transcribed accurately.]

CLASS I WORK - INSTRUMENT AND CONTROL - JUNE 1988

WR# 140746 Emer. cooling return valve 39-05 failed LLRT. Performed N1-ISP-R-039-503.
 WR# 142245 Valve #126 too slow. Completed N1-IMP-X-044-008.
 WR# 134795 LPRM 36-41C. Cleaned connector.
 WR# 140338 CRD scram valve airlines. Snoopd all fittings and replaced leaking tubing and fittings.
 WR# 142243 CRD 30-03 scram valve will not close. Completed N1-IMP-X-044-008.
 WR# 112417 Level switches 044-2. Performed test per pref. 589 Rev. 1.
 WR# 141859 Inspect IRM #17 cables and connectors. N1-IMP-X-092-130.
 WR# 142255 Valve 14-11 #127 diaphragm leaks. Perform PMT N1-IMP-X-044-008.
 WR# 141857 Inspect IRM #15 cables and connectors. N1-IMP-X-092-130.
 WR# 142261 Diaphragm valve 22-03 #127. Performed partial PMT.
 WR# 140141 Valve 201.2-40 failed LLRT. Performed N1-ISP-R-201-527.
 WR# 141725 TC302 control room plastic tube running through barrier. Replaced union.
 WR# 140334 MSIV 01-04. Performed N1-ISP-C-01.
 WR# 142232 CRD 18-11 diaphragm leaks. Completed N1-IMP-X-044-008.
 WR# 141950 CRD 30-03 valve 127. N1-IMP-SOV-2.
 WR# 111265 Gauges on snubber testing equipment. Calibrated gauges.
 WR# 141643 Calibrate gauge and relief valve to N1-HYB-220. Calibrated gauge.
 WR# 141424 MG Set 167 troubleshoot as necessary. No problem found.
 WR# 112641 FW 29-25 valve leaks. Rebuilt positioner.
 WR# 140140 Valve 201.2-39 failed LLRT. Performed N1-ISP-R-201-527.
 WR# 142247 Repair #17 IRM cable. See WR #141465.
 WR# 140333 MSIV 01-03. Performed N1-ISP-C-01.
 WR# 141951 CRD valve 127 will not close. Rebuilt 117 SOV.
 WR# 141855 #11 IRM system cables and connectors. Cleaned drywell penetration, performed pre and post maintenance.
 WR# 141712 Penetration TC282. Replaced union.
 WR# 142177 CRD 26-03, valve 126 repair. Performed partial PMT.
 WR# 142183 Calibrate pressure gauge N1-ISI-GA-002.
 WR# 141935 Repair terminal strip on #11 FWF CV Ep. Replaced EP.
 WR# 141860 IRM #18 system cables and connectors. Cleaned drywell penetration and performed pre and post maintenance.
 WR# 142256 Adjust valve coupling valve 126. Adjusted coupling per GEI-92807A.
 WR# 141959 LPRM connector 36-33D. SMA connector cleaned and retightened.
 WR# 141858 Inspect IRM 16 system cables and connectors. Cleaned drywell penetration and performed pre and post maintenance.
 WR# 142254 SOV 117 leaks air. Rebuilt 117 SOV.
 WR# 141856 Inspect IRM #13 system cables and connectors. Cleaned drywell penetration and performed pre and post maintenance.
 WR# 141632 Valve positioner 29-25. Replaced rubber goods.
 WR# 140354 Valve IA26 leaking. No problem found; WR written to check IA24.
 WR# 141355 Refueling platform hi. range monitor will not alarm. Reset circuit breaker.
 WR# 142220 Recalibrate transmitters 29-53, 29-54 and ID106. Recalibrated.
 WR# 142424 Ch. 11, M panel fuse opened. Replaced fuse.
 WR# 142812 #113-78 repair regulator. Replaced assembly.
 WR# 142806 MG Set 171 voltage regulator. Replaced R3.



Small, faint, illegible marks or characters in the top right corner.

CLASS I WORK - ELECTRICAL MAINTENANCE - JUNE 1988

WR# 142188 Containment Spray Cooling Water; 93-73. Disconnected/
Reconnected limitorque.

WR# 133841 Containment Spray Cooling Water; 93-71. Disconnected/
Reconnected limitorque.

WR# 141568 Instrument Air; 94-30. Cleaned control switch.

WR# 133842 Containment Spray Cooling Water; 93-74. Disconnected/
Reconnected limitorque.

WR# 134503 Drywell Sump Piping; 83.1-09. Reset torque switch.

WR# 133840 Containment Spray Cooling Water; 93-72. Disconnected/
Reconnected limitorque.

WR# 134607 Main Steam; 01-02. Replaced cover bolts. Power lead
screws and grease relief valve.

WR# 141891 Containment Spray; 80-35C, 35D. Replaced lugs.

WR# 134191 Reactor Shutdown Cooling; 38-13. Replaced torque switch.

FIGURE 1

NINE MILE POINT NUCLEAR STATION UNIT 1 JUNE 1988

DOCUMENT TRANSMITTAL AND VERIFICATION

MONTHLY NRC OPERATING REPORT

ASSIGNED BY J. Willis TO T. Roman DATE 7/8/88
 DUE DATE 7/8/88 LOGGED DATE _____
 SUBJECT OPERATING STATISTICS AND SHUTDOWNS
FOR NINE MILE POINT UNIT 1
OPERATING EXPERIENCE FOR JUNE 1988

DOCUMENT ADDRESSED TO U.S. NUCLEAR REGULATORY COMMISSION
ATTENTION: DOCUMENT AND CONTROL DESK
WASHINGTON, D.C. 20555

PREPARED BY B. Stewart DATE _____
 REVIEWED BY M. Laris MJD Laris DE Roman DATE 7/7/88
B. Eastman MJD for Bruce Eastman DATE 7/7/88
W. James W.P. James DATE 7/8/88
C. Fischer W.C. Fischer DB DATE 7/8/88
R. Longo R. Longo DATE 7/8/88
R. Randall (narrative only) R. Randall DATE _____
 _____ DATE _____
 _____ DATE _____

VERIFIED BY T. Roman TR DATE 7/8/88
 _____ DATE _____
 _____ DATE _____

COMMENTS _____

RECEIVED FOR TRANSMITTAL _____ DATE _____

SENT TO ADDRESSEE BY _____ DATE _____

COPY RETURNED TO SITE BY _____ LOGGED AT SITE DATE _____
 FILED AT SITE DOC. CONTROL RECORD DATE _____

OFFICE STAMPS



Handwritten marks or characters in the top right corner.

Small handwritten mark or character on the left side.

Small handwritten marks or characters in the middle section.

Small handwritten marks or characters in the middle section.

Small handwritten mark or character on the left side.

Small handwritten marks or characters in the middle section.

Small handwritten marks or characters in the middle section.

Small handwritten mark or character at the bottom center.

July 8, 1988

U.S. Nuclear Regulatory Commission
Attention: Document and Control Desk
Washington, D.C. 20555


Subject: Operating Statistics & Shutdowns - June 1988
Docket No. 50-220
NINE MILE POINT UNIT 1

Dear Sir:

Submitted herewith is the Report of Operating Statistics and Shutdowns for June 1988 for the Nine Mile Point Nuclear Station Unit 1.

Also included is a narrative report of Operating Experience for June 1988.

Very truly yours,


James L. Willis
General Superintendent

JLW/TWR/bas

Attachments

cc: Regional Administrator, Region I
Resident Inspector

IE24
11

