NINE MILE POINT NUCLEAR STATION - UNIT 2

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT


JANUARY - JUNE 1988

DOCKET NO.: 50-410

LICENSE NO.:

NPF-69

NIAGARA MOHAWK POWER CORPORATION



NINE MILE POINT NUCLEAR STATION - UNIT 2

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

JANUARY - JUNE 1988

Facility: Nine Mile Point Unit #2 Licensee: Niagara Mohawk Power

Corporation

1. Technical Specification Limits:

- A) Fission and activation gases:
 - 1. The dose rate limit of noble gases from the site to areas at and beyond the site boundary shall be less than or equal to 500 mrem/year to the whole body and less than or equal to 3000 mrem/year to the skin.
 - 2. The air dose from noble gases released in gaseous effluents from the Nine Mile Point 2 Station to areas at and beyond the site boundary shall be limited during any calendar quarter to less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation and, during any calendar year to less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.

B&C) Tritium, Iodines and Particulates, half lives > 8 days:

- 1. The dose rate limit of Iodine-131, Iodine-133, Tritium and all radionuclides in particulate form with half-lives greater than eight days, released gaseous effluents from the site to areas at or beyond the site boundary, shall be less than or equal to 1500 mrem/year to any organ.
- 2. The dose to a member of the public from Iodine-131, Iodine-133, Tritium and all radionuclides in particulate form with half lives greater than 8 days as part of gaseous effluents released from the Nine Mile Point 2 Station to areas at and beyond the site boundary shall be limited during any calendar quarter to less than or equal to 7.5 mrem to any organ and, during any calendar year to less than or equal to 15 mrem to any organ.

D) Liquid Effluents

1. The concentration of radioactive material released in liquid effluents to unrestricted areas shall be limited to the concentrations specified in 10 CFR Part 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gas, the concentration shall be limited to 2E-04 microcuries/ml total activity.

,

₩

*

,

.

ng a e

x 1

4 . .

.

f

- D. Liquid Effluents (Cont'd)
 - 2. The dose or dose commitment to a member of the public from radioactive materials in liquid effluents released from Nine Mile Point Unit 2 to unrestricted areas shall be limited during any calendar quarter to less than or equal to 1.5 mrem to the whole body and to less than or equal to 5 mrem to any organ, and during any calendar year to less than or equal to 3 mrem to the whole body and to less than or equal to 10 mrem to any organ.
- 2. Maximum Permissible Concentrations
 - A) Fission and activation gases:

None specified

B&C) Iodines and particulates, half lives ≥ 8 days:

None specified

D) Liquid Effluents:

```
10CFR 20, Appendix B, Table II, Column 2.
Avg Fraction MPC ( Jan. - March ) = 5.86E-2
Avg Fraction MPC ( April - June ) = 1.94E-3
```

3. Average Energy (Fission and Activation gases - Mev)

```
Jan. - March: \overline{\underline{E}} = 0.988; \overline{\underline{E}}_{\beta} = 0.498
Oct. - Dec.: \overline{\underline{E}} = 0.904; \overline{\underline{E}}_{\beta} = 0.784
```

4. Measurements and Approximations of Total Radioactivity

Described below are the methods used to measure or approximate the total radioactivity and radionuclide composition in effluents.

- A) Fission and Activation Gases: Noble gas effluent activity is determined by on-line gamma spectroscopic monitoring (intrinsic germanium crystal) of an isokinetic sample stream.
- B) Iodines: Iodine effluent activity is determined by gamma spectroscopic analysis (at least weekly) of charcoal cartridges manually or automatically sampled from an isokinetic sample stream.
- C) Particulates: Activity released is determined by gamma spectroscopic analysis (at least weekly) of particulate filters manually or automatically sampled from an isokinetic sample stream.

. .

.

i g

4. (Cont'd)

- D) Tritium: Tritium effluent activity is measured by liquid scintillation or gas proportional counting of monthly samples taken with an air sparging/water trap apparatus.
- E) Liquid Effluents: Isotopic Analysis of a representative sample of each batch.
- F) Solid Effluents: Isotopic contents of waste shipments are determined by gamma spectroscopy and water content analyses of a representative sample of each batch. Scaling factors established from primary composite sample analyses conducted off-site are applied, where appropriate, to find estimated concentration of non-gamma emitters. For low activity trash shipments, curie content is estimated by dose rate measurement and application of appropriate scaling factors.

5. Batch Releases

The following information relates to batch releases of radioactive materials in liquid and gaseous effluents.

- A) Liquid -
 - 1. Number of batch releases: 131
 - 2. Total time period for batch releases: 444 hours 30 min.
 - 3. Maximum time period for a batch release: 3 hours 28 min.
 - 4. Average time period for a batch release: 3 hours 24 min.
 - 5. Minimum time period for a batch release: 3 hours 12 min.
 - 6. Average stream flow during period of release of effluent into a flowing stream: Not

Not Applicable

7. Total volume of water used to dilute the liquid effluent during release periods:

2.25 E9 liters

8. Total volume of water available to dilute the liquid effluent during reporting period :

2.25 E10 liters

- B) Gaseous (Primary Containment Purge)
 - 1. Number of batch releases:
 - 2. Total time period for batch releases: 128.6 hours
 - 3. Maximum time period for a batch release: 38.2 hours
 - 4. Average time period for a batch release: 14.3 hours
 - 5. Minimum time period for a batch release: 7.8 hours
- 6. Abnormal Releases
 - A. Liquids none
 - B. Gaseous none

3 ,

• 4:,

:

TABLE 1A

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES ELEVATED AND GROUND LEVEL

JANUARY - JUNE 1988

			UNIT	1st QUARTER	2nd QUARTER	EST.TOTAL ERROR, %
Α.	Fiss	sion & Activation gases	•			
	1.	Total release	Ci	6.52E+00	2.85E+01	5.0E+01
	2.	Average release rate	a. /	0 007 04	0.607.00	
	^	for period	μ Ci/sec	8.29E-01	3.62E+00	•
	3.	Percent of Technical Specification Limit	%	*	*	
в.	tboI	Ines				
	1.	Total iodine-131	Ci	1.33E-05	2.79E-06	5.0E+01
	2.	Average release rate				
		for period	μ Ci/sec	1.69E-06	3.55E-07	
	3.	Percent of Technical	~		*	
		Specification Limit	%	*	*	
c.	Part	iculates			1	
	1.	Particulates with half-				
		lives 8 days	Ci	6.03E-05	5.54E-05	5.0E+01
	2.	Average release rate				
	_	for period	μ Ci/sec	7.67E-06	7.05E-06	
	3.	Percent of Technical	a.		*	
	4.	Specification Limit	%	*	×	
	4.	Gross alpha radio- activity	Ci	3.05E-06	6.03E-06	5.0E+01
		accr, vicy	OI.	3.032 00	0.035 00	3.01.01
D.	Trit	ium				
	1.	Total release	Ci	1.05E+00	1.60E+00	5.0E+01
	2.	Average release rate for period	μCi/sec	1.34E-01	2.04E-01	
	3.	Percent of Technical Specification Limit	%	*	*	

^{*}See Item E attached.

P n •

6

ž

1

* '•

4 -

.

• 1

a.

#

TABLE 1A (Continued)

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES ELEVATED AND GROUND LEVEL

JANUARY - JUNE

			UNIT	4	1st QUARTER	2nd QUARTER	
E.	Per	cent of Technical Specifi	cation	Limit	<u> </u>		
	Fis	sion and Activation Gases	<u>:</u>				
	1.	Percent of Quarterly Gamma Air Dose Limit	%		5.18E-02	2.13E-01	
	2:	Percent of Quarterly Beta Air Dose Limit	%		3.68E-04		
	3.	Percent of Annual Gamma					
	4.	Air Dose Limit to Date Percent of Annual Beta	%		2.59E-02	1.33E-01	
	5.	Air Dose Limit to Date Percent of Whole Body	%	J	1.84E-04	1.75E-03	
	•	Dose Rate Limit	%	4	2.00E-03	8.19E-03	
	0.	Percent of Skin Dose Rate Limit	%		3.87E-04	1.61E-03	
	Tri	tium, Iodines and Particu	lates	(with 1	half-lives	greater than 8	days):
	1.	Percent of Quarterly Dose Limit	%		1.33E-03	3.61E-04	
	2.	Percent of Annual Dose					
	3.	Limit to Date Percent of Organ Dose	%		6.67E-04		
		Rate Limit	%		5.06E-05	1.04E-05	

Section 3.

· 6., 1

TABLE 1B

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 GASEOUS EFFLUENTS-ELEVATED (STACK)

JANUARY - JUNE

Nuc	lides Released	Unit	CONTINUO	US MÖDE - 2nd Quarter	BATCH Mo	ODE 2nd Quarter
1140	LLUCD MCLCODCU	OILL C	TOC QUALTER	and quarter	200 (402002	
1.	Fission Gases					
	Argon-41 Krypton-85m Krypton-87 Krypton-88 Xenon-133 Xenon-135 Xenon-135m Xenon-137	C1 C1 C1 C1 C1 C1 C1 C1	2.28E-01 1.20E-01 8.84E-02 1.06E-00 5.02E-00	5.36E-00 2.10E-01 7.57E-01 4.71E-01 		
2.	Iodines					
,	Iodine-131 Iodine-133 Iodine-135	Ci Ci Ci	1.33E-05 1.98E-04	2.79E-06 1.35E-06		
3.	Particulates				1 	
	Strontium-89 Strontium-90 Strontium-91 Cesium-134 Cesium-137 Cobalt-60 Cobalt-58 Manganese-54 Barium-Lanthanum-140 Antimony-125 Niobium-95 Cerium-141 Cerium-144 Iron-59 Cesium-136 Chromium-51 Zinc-65 Iron-55	C1 C1 C1 C1 C1 C1 C1 C1 C1 C1 C1 C1 C1 C	5.96E-05 6.90E-07	# 1.84E-05 		
4.	Tritium	Ci	2.54E-01	5.95E-01	4.77E-01	6.85E-01

[#] Sr89, 90 and Fe-55 analysis results have not been received yet, 1.79E-06 Ci of Sr89 was released during the fourth quarter of 1987 from the stack in a continuous mode.

٠, . * * x ·

, , , ,

1.0 4.4 •

- e**b e**,

k 1 % 6

• 1

i i

. 4 ∗सः उद्धाः सः

1 A WI e... -•

•

TABLE 1C

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 GASEOUS EFFLUENTS-COMBINED GROUND LEVEL-ELEVATED (REACTOR BUILDING VENT)

JANUARY - JUNE

			CONTINU	OUS MODE	ватсн	MODE
Nuc	lides Released	Unit	1st Quarter	2nd Quarter	1st Quarter	2nd Quarter
1.	Fission Gases					
	Argon-41	Ci				
	Krypton-85	Ci		2.06E-04		
	Krypton-85m	Ci				
	Krypton-87	Ci				
	Krypton-88	Ci				
	Xenon-133	Ci		2.19E-05		
	Xenon-135	Ci		4.96E-01		
	Xenon-135m	Ci				
	Xenon-137	Ci				
	Xenon-138	Ci	~~~~			
2.	Iodines					
	Iodine-131	Ci				
	Iodine-133	Ci				
	Iodine-135	Ci				
3.	Particulates	-41		•	ı	
	Strontium-89	Ci		#		
	Strontium-90	Ci		#		
	Cesium-134	Ci				~~~~~
	Cesium-137	Ci				
	Cobalt-60	Ci				
	Coba1t-58	Ci	-			
*	Manganese-54	Ci				
	Barium-Lanthanum-140					
	Antimony-125	Ci				
	Niobium-95	Ci		*********		
	Cerium-141	Ci				
	Cerium-144	Ci				
	Iron-59	Ci				
	Cesium-136	Ci				~~~~~
	Chromium-51	Ci		4.31E-05		***************************************
	Zinc-65	Ci		3.14E-06		
	Iron-55	Ci		#		
	Technictium-		,			·
	Molybdenum-99	Ci		6.88E-05		
4.	Tritium	Ci	3.21E-01	3.24E-01		

[#] Sr89, 90 and Fe-55 results have not been received yet, None of these nuclides were released from the vent during the fourth quarter of 1987.

^{*} Mn-54 release was erroneously reported in the last semiannual report for the stack continous 4th quarter of 1987 as 5.17 Ci. Correct value should have been 1.32E-6 Ci.

TABLE 2A

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

JANUARY - JUNE

	н		Unit	1st Quarter	2nd Quarter	Est. Total Error, %
A.	Fiss	ion and activation produc	ets	۹,		
	2.	Total release (not including tritium, gases, alpha) Average diluted con-	Ci	2.72E-00	2.36E-01	5.00E+1
	3.	centration during reporting period Percent of applicable limit	μ Ci/ml %	2.95E-06 5.80E-00	1.77E-07 1.44E-01	
в.	Trit		.~	0000	20112 02	
	1.	<u> </u>	Ci	1.61E-00	2.03E-00	5.00E+1
	3 .	centration during reporting period Percent of applicable limit	μ Ci/ml %		1.53E-06 5.10E-04	
c.	Diss	olved and entrained gases				
	1.		C1	2.75E-04	9.35E-05	5.00E+1
i	3.	centration during reporting period Percent of applicable limit	μ Ci/ml %	2.99E-10	7.02E-11 3.51E-05	
D.	Gros	s alpha radioactivity	<i>1</i> 6	T-42E-04	3.JIE-03	
יע.	1.	Total release	Ci.			
Ε.	Volu		0.			
±	1.	Prior to dilution Volume of dilution	liters	6.22E+06	5.90E+06	5.00E+1
	3.	water used during release period Volume of dilution	liters	9.20E+08	1.33E+09	5.00E+1
		water used during reporting period	liters	8.90E+09	1.36E+10	5.00E+1

3** '

A THE RESERVE 27.02.1

A CONTRACTOR AND A STATE OF

r se

11 32

The state of the s

138 . "

TABLE 2A (Continued)

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

JANUARY - JUNE

	•	<u>Unit</u>	je v	1st Quarter	2nd Quarter
Per	cent of Technical Specific	ation Lim	its		
1.	Percent of Quarterly Whole Body Dose Limit	%		1.86E+01	2.49E+00
2.	Percent of Quarterly Organ Dose Limit (GI-LLI)	%		1.95E+01	1.32E+00
3.	Percent of Annual Whole Body Dose Limit to Date	%	•	9.29E+00	1.05E+01
4.	Percent of Annual Organ Dose Limit to Date		F		
5.	(GI-LLI) Percent of 10CFR20	%	1	9.77E+00 °	1.04E+01
٠,	Concentration Limit	%		5.86E+00	1.95E-01
6.	Percent of Dissolved or Entrained Noble Gas	Ł			1
	Limit	%		1.49E-04	3.51E-05

:

• * *

*

•

TABLE 2B

RADIOACTIVE EFFLUENT RELEASE SEMI-ANNUAL REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 LIQUID EFFLUENTS RELEASED JANUARY - JUNE

		CONTINUOUS MODE		BATCH MODE	
	<u>Unit</u>	1st Quarter	2nd Quarter	1st Quarter	2nd Quarter
Nuclides Released					
Strontium-89	Ci				
Strontium-90	Ci				
Cesium-134	Ci				
Cesium-137	Ci				
Iodine-131	Ci				
Cobalt-58	Ci			6.89E-01	5.08E-02
Cobalt-60	Ci			3.91E-01	1.31E-02
Iron-59	Ci			1.78E-01	2.70E-03 ·
Zinc-65	CI			1.20E-01	3.94E-02
Manganese-54	Ci			3.27E-01	2.54E-02
Chromium-51	Ci			9.52E-01	1.04E-01
Zirconium-niobium-9	5 C i		P		
Molybdenum-99	Ci			5.14E-05	1.84E-04
Technetium-99m	Ci			3.32E-05	1.79E-04
Barium-lanthanum-14	0Ci				
Cerium-141	Ci				
Tungsten-187	Ci			1.29E-04	
Arsenic-76	Ci			2.82E-04	2.93E-04
Iodine-133	Ci				
Hydrogen-3	Ci			1.61E-00	2.03E-00
Iron-55	Ci				
Manganese-56	Ci				
Neptunium-239	Ci				
Nickel-65	Ci			9.41E-04	
Praseodymium-144	Ci				
Sodium-24	Ci			5.92E-02	5.75E-04
Total for Period					
(Above)	Ci			4.33E-00	2.27E-00
Xenon-133	Ci			2.35E-04	5.88E-05
Xenon-135	Ci			4.05E-05	3.47E-05

TABLE 3A

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

JANUARY - JUNE

A. Solid Waste Shipped Off-Site for Burial or Disposal (Not irradiated fuel)

1.	Type (of Waste	UNIT	6-MONTH PERIOD	EST. TOTAL ERROR, %
		Spent resins, filter sludge bottoms, etc.	m ³	1.80E+02	5.00E+01
			Ci	2.88E+01	5.00E+01
	1	Dry compressible waste, contaminated equip., etc.	_m 3		
			Ci	Card Start Gard, span, garg, garg, gags	
		Irradiated components, control rods, etc.	_m 3		U
			Ci	20 CD 10 10 CD 70 TO ²⁰	
	d. (Other (describe)	_m 3		
			Ci		

^{*}All were solidified in cement as Class A waste in strong, tight containers as LSA. One strong, tight container was shipped in a Type A cask due to radiation level.

THE RESERVE TO A THE WAS DETECTION TO THE THE SECOND TH

And the second of the second o

TABLE 3A (Continued)

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

2. Estimate of Major Nuclide Composition (by Type of Waste)

a. Spent Resins, filter sludges, evaporator bottoms, etc.

	Percent	Est. Total Error, %
Cobalt-60	1.00E+01	5.00E+01
Manganese-54	1.50E+01	5.00E+01
Iron-55	3.10E+01	5.00E+01
Cobalt-58	2.30E+01	5.00E+01
Chromium-51	7.00E+00	5.00E+01
Zinc-65	9.00E+00	5.00E+01
Others()	5.00E+00	5.00E+01

- b. Dry Compressible Waste, Contaminated Equips, Etc.
- c. Irradiated components, control rods, etc.
- d. Other (describe)

3. Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
18	Truck	Barnwell S.C.

B. IRRADIATED FUEL SHIPMENTS (DISPOSITION)

Number of Shipment	Mode of Transportation		Destination
*		•	
None	-		_

AND THE RESERVE TO THE RESERVE TO THE STATE OF THE STATE

Control of the Contro

PART FALL FROM LAND BOLL FOR LAND FROM LAND CONTRACT OF THE PART O

, *) (*

etterior en 1966 de la companya del companya de la companya del companya de la companya del companya de la companya de la companya de la companya del companya de la companya del la companya de la companya de la companya del la companya de

TABLE 4

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988)
NINE MILE POINT NUCLEAR STATION # 2
RECENT CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL

Change

Reason

ODCM Figures 2-1 thru 2-8 have been simplified

ODCM Figures 3-1 thru 3-4 have been simplified

Section 4.1 changed to calculate dose to either a teenager or an adult based on 67 hours per year

Section 4.4
Revision in calculation
of dose to members of the
public within the site
boundary

Table 5.1 changes in environmental monitoring program sample locations

Section 2.1.3.2 changed to 90 days after Commercial Operation

To comply with a NRC request

To comply with a NRC request

Due to the nature of the receptor and extensive fishing in the area, the critical individual may be either a teenager or an adult

Undocumented observations of extensive fishing activity

Changes in local dairy farm operations and fishing activity

To allow more time for completion of evaluation

, g . s s s

pl.

y 4

4

•

•

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 RECENT CHANGES TO PROCESS CONTROL PROGRAM

Change

Reason

There have been no changes to the Process Control Program during this reporting period.

SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (1988) NINE MILE POINT NUCLEAR STATION #2 EXPLANATION OF INSTRUMENTATION INOPERABILITY

INSTRUMENT	DATE OUT OF SERVICE	DATE RETURNED TO SERVICE	EXPLANATION
Stack Noble Gas, sample flow, system flow and Particulate and Iodine Samplers	9/23/87		Design deficiency with alarm annunciation reflash with Noble Gas Channel. Anticipated completion 9-1-88. Flow and samplers considered inop due to inter-relationship with Noble Gas Channel.
Vent Noble Gas, sample flow, system flow, and Particulate and Iodine Samplers	9/23/87	dan mak tadi dadi fadi Pri Sim ma	Design deficiency with alarm annunciation reflash with Noble Gas Channel. Anticipated completion 9-1-88. Flow and samplers considered inop due to inter-relationship with Noble Gas Channel.
Offgas System Flow	8/87		Original monitor has an inappropriate location. Modification awaiting disposition.
Offgas Hydrogen Monitors	8/87		Original monitors loses sample flow when placed in service. Awaiting modification. Expected completion 12/88.
Liquid Radwaste Radiation	11/87	,	Monitors background is very high. Detection chamber acts as a crud trap. Awaiting modification.

NOTE: The Nine Mile Point Nuclear Station (James A. FitzPatrick Nuclear Power Plant) has improved its processing of wind direction data this reporting period. This was accomplished by the replacement of it's 360 degree wind direction processors with 540 degree wind direction processors. The 540 degree processing of wind direction is state of the art and affords improved readability of north winds on analog wind direction recorders. All other aspects of the system remain the same.

A CONTRACTOR OF THE STATE OF TH

м v k The State of the s