

UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
NIAGARA MOHAWK POWER CORPORATION)
(Nine Mile Point Nuclear Station Unit No. 1)

Docket No. 50-220

APPLICATION FOR AMENDMENT
TO
OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. DPR-63, hereby requests that Sections 3.1.1/4.1.1 and 3.2.7/4.2.7 of the Technical Specifications set forth in Appendix A to that License be amended. These proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specification changes are set forth in Attachment A to this application. Sections 3.1.1, 4.1.1 and Bases have been proposed for amendment to provide testing and Limiting Condition for Operation (LCO) requirements for the Scram Discharge Volume (SDV) which will demonstrate that no blockage exists in the system's piping and ensure SDV operability. Surveillance Requirement 4.2.7.d has been redesignated in 4.1.1.e. The proposed changes would not authorize any change in the type of effluents or in the authorized power level of the facility in conjunction with this

8901050248 881227
PDR ADOCK 05000220
PDC

5340G

application for License Amendment. Supporting information and analysis, which demonstrate that the proposed change involves no significant hazards consideration pursuant to 10 CFR 50.92 are included as Attachment B.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By



Vice President
Nuclear Engineering and Licensing

Subscribed and sworn to before me
on this 27th day of December 1988.

Christine Austin
NOTARY PUBLIC

CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4787687
My Commission Expires 1/31/90.

60