

LIMITING CONDITIONS FOR OPERATION
Table 3.2.7 (Continued)

REACTOR COOLANT SYSTEM ISOLATION VALVES

<u>Line or System</u>	<u>No. of Valves (Each Line)</u>	<u>Location Relative to Primary Containment</u>	<u>Normal Position</u>	<u>Motive Power</u>	<u>Maximum Oper. Time (Sec)</u>	<u>Action on Initiating Signal</u>	<u>Initiating Signal (All Valves Have Remote Manual Backup)</u>
<u>Reactor Head Spray (One Line)</u>	1 1	Inside Outside	- Closed	Self Act. Ck. R.M.P.O.	-- 30	- -	-- --
<u>Liquid Poison (One Line)</u>	1 1	Inside Outside	- -	Self Act. Ck. Self Act. Ck.	-- --	- -	-- --
<u>Control Rod Drive Hydraulic (One Line)</u>	1 1	Inside Outside	- -	Self Act. Ck. Self Act. Ck.	-- --	- -	-- --
<u>Scram Discharge System Vent (One Line)</u>	2	Outside	Open	A.I.A.O.	10	Close	High neutron flux, High reactor pressure, High primary containment pressure, Low water level in the reactor, High level in the scram discharge volume, low vacuum in condensor
<u>Scram Discharge System Drain (One Line)</u>	2	Outside	Open	A.I.A.O.	10	Close	High radiation in main steam line, Closure of main steam isolation valves, Loss of normal and reserve AC power.
<u>Core Spray High Point Vent (Two Lines)</u>	1 1	Inside Outside	Closed Closed	AC Motor Air/DC Solenoid	30 30	Closed Closed	Reactor Water, Low-Low or High Level Drywell Pressure

A.I.P.O. - Automatically Initiated Power Operated.

* R.M.P.O. - Remote Manual Power Operated.

A.I.A.O. - Automatically Initiated Air Operated.

Amendment No. 43, 44

119

8902160411 890213
PDR ADDCK 05000220
PDC

