



SI APERTURE CARD

FOR START UP ONLY
INFORMATION ONLY
 DATE MAR 08 1989

NIAGARA MOHAWK POWER CORPORATION
 NINE MILE POINT NUCLEAR STATION
 REACTOR CLEAN-UP SYS.
 ASME SECTION XI BOUNDARY DIAGRAM

- BOUNDARY CLASSIFICATION NOTES**
- This diagram was developed from P&ID Diagram C-18009-C, SHT.1.
 - Areas classified as "exempt" are exempt from examination requirements only (per 101.10, 101.11, 101.12). Other requirements of ASME Section XI (e.g. repairs, replacements, pressure tests, etc.) apply to the extent specified by the code.
 - Pipes 1-inch and smaller are marked only with a flag to show boundaries.

REV	DATE	BY	CHKD	APP'D	REMARKS	DTM	DTN
1	3/16/89	3-31-88	NONE
2	N-21-530.4
3	F-42234-C

8903310265

C