

LIMITING CONDITIONS FOR OPERATION  
Table 3.2.7 (Continued)

REACTOR COOLANT SYSTEM ISOLATION VALVES

<u>Line or System</u>	<u>No. of Valves (Each Line)</u>	<u>Location Relative to Primary Containment</u>	<u>Normal Position</u>	<u>Motive Power</u>	<u>Maximum Oper. Time (Sec)</u>	<u>Action on Initiating Signal</u>	<u>Initiating Signal (All Valves Have Remote Manual Backup)</u>
<u>Reactor Head Spray (One Line)</u>	1	Inside	-	Self Act. Ck.	--	-	--
	1	Outside	Closed	R.M.P.O.	30	-	--
<u>Liquid Poison (One Line)</u>	1	Inside	-	Self Act. Ck.	--	-	--
	1	Outside	-	Self Act. Ck.	--	-	--
<u>Control Rod Drive Hydraulic (One Line)</u>	1	Inside	-	Self Act. Ck.	--	-	--
	1	Outside	-	Self Act. Ck.	--	-	--
<u>Scram Discharge System Vent (One Line)</u>	2	Outside	Open	A.I.A.O.	10	Close	High neutron flux, High reactor pressure. High primary containment pressure, Low water level in the reactor, High level in the scram discharge volume, low vacuum in condensor, High radiation in main steam line, Closure of main steam isolation valves, Loss of normal and reserve AC power.
<u>Scram Discharge System Drain (One Line)</u>	2	Outside	Open	A.I.A.O.	10	Close	
<u>Core Spray High Point Vent (Two Lines)</u>	1	Inside	Closed	AC Motor	30	Closed	Reactor Water Level Low-Low or High Drywell Pressure.
	1	Outside	Closed	Air/DC Solenoid	30	Closed	

\* A.I.P.O. - Automatically Initiated Power Operated.

\* R.M.P.O. - Remote Manual Power Operated.

A.I.A.O. - Automatically Initiated Air Operated.

Amendment No. 43, 44

8904200146 890410  
PDR ADDCK 05000220  
P PNU



11/11/11