



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-410

NINE MILE POINT NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 8  
License No. NPF-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated November 10, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-69 is hereby amended to read as follows:

8906210086 890614  
PDR ADCK 05000410  
P PNU



(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

*Robert A. Capra*

Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects, I/II

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: June 14, 1989



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 8 TO FACILITY OPERATING LICENSE NO. NPF-69

DOCKET NO. 50-410

Revise Appendix A as follows:

Remove Page

3/4 0-3

Insert Page

3/4 0-3



APPLICABILITY

SURVEILLANCE REQUIREMENTS

---

4.0.5 (Continued)

ASME BOILER AND PRESSURE VESSEL  
CODE AND APPLICABLE ADDENDA  
TERMINOLOGY FOR INSERVICE  
INSPECTION AND TESTING ACTIVITIES

REQUIRED FREQUENCIES  
FOR PERFORMING INSERVICE  
INSPECTION AND TESTING  
ACTIVITIES

---

|                                |                            |
|--------------------------------|----------------------------|
| Weekly                         | At least once per 7 days   |
| Monthly                        | At least once per 31 days  |
| Quarterly or every 3 months    | At least once per 92 days  |
| Semiannually or every 6 months | At least once per 184 days |
| Every 9 months                 | At least once per 276 days |
| Yearly or annually             | At least once per 366 days |

- c. The provisions of Specification 4.0.2 are applicable to the above required frequencies for performing inservice inspection and testing activities.
- d. Performance of the above inservice inspection and testing activities shall be in addition to other specified Surveillance Requirements.
- e. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supersede the requirements of any Technical Specification.
- f. The Inservice Inspection Program for piping identified in NRC Generic Letter 88-01 shall be performed in accordance with the staff positions on schedule, methods, personnel and sample expansion included in this generic letter.

