



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220


NINE MILE POINT NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 106  
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated September 22, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

8906280261 890619  
PDR ADOCK 05000220  
P PDC



(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 106, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.


FOR THE NUCLEAR REGULATORY COMMISSION

*Robert A. Capra*

Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects, I/II

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: June 19, 1989



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 106 TO FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220


Revise Appendix A as follows:

Remove Page

178

Insert Page

178



LIMITING CONDITION FOR OPERATION

3.4.5 CONTROL ROOM AIR TREATMENT SYSTEM

Applicability:

Applies to the operating status of the control room air treatment system.

Objective:

To assure the capability of the control room air treatment system to minimize the amount of radioactivity or other gases entering the control room in the event of an incident.

Specification:

- a. Except as specified in Specification 3.4.5e below, the control room air treatment system and the diesel generators required for operation of this system shall be operable at all times when reactor building integrity is required.
- b. The results of the in-place cold DOP and halogenated hydrocarbon test design flows on HEPA filters and charcoal adsorber banks shall show  $\geq 99\%$  DOP removal and  $\geq 99\%$  halogenated hydrocarbon removal when tested in accordance with ANSI N.510-1980.

SURVEILLANCE REQUIREMENT

4.4.5 CONTROL ROOM AIR TREATMENT SYSTEM

Applicability:

Applies to the testing of the control room air treatment system.

Objective:

To assure the operability of the control room air treatment system.

Specification:

- a. At least once per operating cycle, or once every 24 months, whichever occurs first, the pressure drop across the combined HEPA filters and charcoal adsorber banks shall be demonstrated to be less than 6 inches of water at system design flow rate ( $\pm 10\%$ ).
- b. The tests and sample analysis of Specification 3.4.5b, c and d shall be performed at least once per operating cycle or once every 24 months, or after 720 hours of system operation, whichever occurs first or following significant painting, fire or chemical release in any ventilation zone communicating with the system.

