

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8908180215 DOC. DATE: 89/08/10 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH. NAME AUTHOR AFFILIATION
 TERRY, C.D. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Advises of intent to use Winter 1983 Addendum to 1983
 Edition of ASME Code for certain ISI acceptance stds.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 2 SIZE: 1
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-1 LA	1	PD1-1 PD	5
	SLOSSON, M	1		5
INTERNAL:	ACRS	6	AEOD/DSP/TPAB	1
	NRR/DEST/MEB 9H	1	NRR/DEST/MTB 9H	1
	NUDOCS-ABSTRACT	1	OC/LFMB	1
	OGC/HDS1	1	<u>REG FILE</u> 01	1
	RES/DSIR/EIB	1		1
EXTERNAL:	EG&G BROWN, B	1	EG&G ROCKHOLD, H	1
	LPDR	1	NRC PDR	1
	NSIC	1		1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 26 ENCL 23

m/A-1



22-11

2

2

August 10, 1989
NMP1L 0430U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555Re: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63


Gentlemen:

The purpose of this letter is to inform the Nuclear Regulatory Commission of Niagara Mohawk's intention to use the Winter 1983 Addendum to the 1983 Edition of the ASME CODE for certain inservice inspection acceptance standards which is different from Niagara Mohawk's commitment in the Inservice Inspection Program Plan for Nine Mile Point Unit 1. Niagara Mohawk committed to use the 1983 Edition of ASME XI, through the Summer 1983 Addendum for the second ten year interval Inservice Inspection Program at Nine Mile Point Unit 1. This edition and addendum of the ASME CODE includes some acceptance standards that are "in the course of preparation". For the following exam categories which do not have acceptance standards in the 1983 Edition through Summer 1983 Addendum, Niagara Mohawk intends to use the Winter 1983 Addenda: B-G-1, B-G-2, B-L-2, B-M-2, B-N-1, B-N-2, B-N-3, and D-A thru C.

The Nuclear Regulatory Commission has approved later Addendum to the 1983 edition of the ASME Section XI CODE in Section 50.55a(b)(2) which are incorporated by reference therein. Therefore, Niagara Mohawk requests approval in accordance with 50.55a(g)(4)(iv) to use the 1983 Edition of the ASME Section XI Code, through the Winter 1983 Addenda for the inspections identified above.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

C. D. Terry
Vice President
Nuclear Engineering and Licensing8908180215 890810
PDR ADDCK 05000220
Q PNUPEF/mlf
7600Gxc: Regional Administrator, Region I
Mr. R. A. Capra, Director
Ms. M. M. Slosson, Project Manager
Mr. W. A. Cook, Resident Inspector
Records ManagementA047
1/0



22

1000

1000

1000

1000

1000

1000