

TABLE 3.6.2a

INSTRUMENTATION THAT INITIATES SCRAMLimiting Condition for Operation

<u>Parameter</u>	<u>Minimum No. of Tripped or Operable Trip Systems</u>	<u>Minimum No. of Operable Instrument Channels Per Operable Trip System</u>	<u>Set Point</u>	<u>Reactor Mode Switch Position in Which Function Must Be Operable</u>			
				<u>Shutdown</u>	<u>Refuel</u>	<u>Startup</u>	<u>Run</u>
(1) Manual Scram	2	1			X	X	X
(2) High Reactor Pressure	2	2	≤ 1080 psig	X	X	X	
(3) High Drywell Pressure	2	2	≤ 3.5 psig	X	(a)	(a)	
(4) Low Reactor Water Level	2	2	≥ 53 inches (Indicator Scale)	X	X	X	
(5) High Water Level Scram Discharge Volume	2	2	≤ 45 gal.	(b)	X	X	

