



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220

NINE MILE POINT NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 115
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated December 8, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

9004300019 900425
PDR ADOCK 05000220
P. PDC



(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 115, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 25, 1990



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 115 TO FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise Appendix A as follows:

<u>Remove Pages</u>	<u>Insert Pages</u>
126	126
127	127
128	128



LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENT

3.3.1 OXYGEN CONCENTRATION

Applicability:

Applies to the limit on oxygen concentration within the primary containment system.

Objective:

To assure that in the event of a loss-of-coolant accident any hydrogen generation will not result in a combustible mixture within the primary containment system.

Specification:

- a. The primary containment atmosphere shall be reduced to less than four percent by volume oxygen concentration with nitrogen gas whenever the reactor coolant pressure is greater than 110 psig and the reactor is in the power operating condition, except as specified in "b" below.

4.3.1 OXYGEN CONCENTRATION

Applicability:

Applies to the periodic testing requirement for the primary containment system oxygen concentration.

Objective:

To assure that the oxygen concentration within the primary containment system is within required limits.

Specification:




LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENT

- b. Within the 24-hour period subsequent to the reactor being placed in the run mode for the power operating condition, the containment atmosphere oxygen concentration shall be reduced to less than four percent by volume, and maintained in this condition. Deinerting may commence 24 hours prior to a major refueling outage or other scheduled shutdown.

- c. If Specifications "a" or "b" above are not met, the reactor coolant pressure shall be reduced to 110 psig or less within ten hours.



BASES FOR 3.3.1 AND 4.3.1 OXYGEN CONCENTRATION

The four percent by volume oxygen concentration eliminates the possibility of hydrogen combustion following a loss-of-coolant accident (Section VII-G.2.0 and Appendix E-11.5.2)^{*}. The only way that significant quantities of hydrogen could be generated would be if all core spray systems failed to sufficiently cool the core. As discussed in Section VII-A.2.0 and illustrated in Figure VII-2,^{*} the core spray system is capable of design flow of 3400 gpm at a reactor pressure of 113 psig. In addition to hydrogen generated by metal-water reaction, significant quantities can be generated by radiolysis. (Technical Specification to Petition for Conversion from Provisional Operating License to Full Term Operating License).

At reactor pressures of 110 psig or less, the reactor will have been shutdown for more than an hour and the decay heat will be at sufficiently low values so that fuel rods will be completely wetted by core spray. The fuel clad temperatures would not exceed the core spray water saturation temperature of about 344F.

The occurrence of primary system leakage following a major refueling outage or other scheduled shutdown is much more probable than the occurrence of the loss-of-coolant accident upon which the specified oxygen concentration limit is based. Permitting access to the drywell for leak inspections during a startup is judged prudent in terms of the added plant safety offered without significantly reducing the margin of safety. Thus to preclude the possibility of starting the reactor and operating for extended periods of time with significant leaks in the primary system, leak inspections are scheduled during startup periods when the primary system is at or near rated operating temperature and pressure. The 24-hour period to provide inerting is judged to be reasonable to perform the leak inspection and establish the required oxygen concentration.

The primary containment is normally slightly pressurized during periods of reactor operation. Nitrogen used for inerting could leak out of the containment but air could not leak in to increase the oxygen concentration. Once the containment is filled with nitrogen to the required concentration, no monitoring of oxygen concentration is necessary. However, at least once a week, the oxygen concentration will be determined as added assurance that Specification 3.3.1 is being met.

^{*}FSAR



Small, faint, illegible marks or characters in the top right corner.