

UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
NIAGARA MOHAWK POWER CORPORATION)
)
Docket No. 50-410)
)
(Nine Mile Point Nuclear Station Unit No. 2)

APPLICATION FOR AMENDMENT

TO

OPERATING LICENSE


Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Corporation, holder of Facility Operating License No. NPF-69, hereby requests that Section 3/4.0 of the Technical Specifications set forth in Appendix A to that License be amended. This proposed change has been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed changes to the Technical Specifications are set forth in Attachment A to this application. Specifically, Niagara Mohawk is requesting changes to portions of Section 3/4.0 of the Nine Mile Point 2 Technical Specifications that will permit selected refueling cycle surveillance tests to be conducted at a later time than the normally allowed maximum of 22 1/2 months (18 months plus 25%) for the (first) operating cycle only. This will allow delay of the scheduled refueling outage until September 8, 1990.


The proposed changes would not authorized any change in the types of effluents or in the authorized power level of the facility. Supporting information and analyses which demonstrate that the proposed changes involve no significant hazards consideration pursuant to 10CFR50.92 are included as Attachment B.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. NPF-69 be amended in the form attached hereto as Attachment A.

By:



C. D. Terry
Vice President
Nuclear Engineering and Licensing



Notary

DIANE R. KIMBALL
Notary Public in the State of New York
Qualified in Onondaga County No. 4933503
My Commission Expires May 31, 1992

9005040044 900427
PDR ADOCK 05000410
P PDC

