



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-410

NINE MILE POINT NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 15
License No. NPF-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated August 17, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-69 is hereby amended to read as follows:

9005210136 900515
PDR ADOCK 05000410
P PDC



(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. 15 are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.


3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 15, 1990



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 15 TO FACILITY OPERATING LICENSE NO. NPF-69

DOCKET NO. 50-410

Revise Appendix A as follows:

Remove Page

3/4 3-17

Insert Page

3/4 3-17



TABLE 3.3.2-2

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
1. <u>Primary Containment Isolation Signals (Continued)</u>		
a. Reactor Vessel Water Level*		
1) Low, Low, Low, Level 1	≥17.8 in.	≥10.8 in.
2) Low, Low, Level 2	≥108.8 in.	≥101.8 in.
3) Low, Level 3	≥159.3 in.	≥157.8 in.
b. Drywell Pressure - High	≤1.68 psig	≤1.88 psig
c. Main Steam Line		
1) Radiation - High	≤3x Full Power Background	≤3.6x Full Power Background
2) Pressure - Low	≥766 psig	≥746 psig
3) Flow - High	≤103 psid	≤109.5 psid
d. Main Steam Line Tunnel		
1) Temperature - High	≤165.7°F	≤169.9°F
2) ΔTemperature - High	≤ 66.7°F	≤ 71.3°F
3) Temperature - High MSL Lead Enclosure	≤146.7°F	≤150.9°F
e. Condenser Vacuum Low	≥8.5 in Hg vacuum	≥7.6 in. Hg vacuum
f. RHR Equipment Area Temperature - High (HXs/A&B Pump Rooms)	≤135°F	≤144.5°F
g. Reactor Vessel Pressure - High (RHR Cut-in Permissive)	≤128 psig	≤148 psig
h. SGTS Exhaust - High Radiation	≤5.7x10 ⁻³ μCi/cc	≤1.0x10 ⁻² μCi/cc

