



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220

NINE MILE POINT NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 116  
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated March 27, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

9006040062 900524  
PDR ADOCK 05000220  
P FDC



(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.116, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

*Robert A. Capra*

Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: May 24, 1990



•  
•  
•  
•  
•

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 116 TO FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise Appendix A as follows:

Remove Page

147

Insert Page

147



LIMITING CONDITIONS FOR OPERATION

Table 3.3.4 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES  
LINES ENTERING FREE SPACE OF THE CONTAINMENT

<u>Line or System</u>	<u>No. of Valves (Each Line)</u>	<u>Location Relative to Primary Containment</u>	<u>Normal Position</u>	<u>Motive Power</u>	<u>Maximum Oper. Time (Sec)</u>	<u>Action on Initiating Signal</u>	<u>Initiating Signal (All Valves Have Remote Manual Backup)</u>
O <sub>2</sub> Sampling							
<u>Drywell</u> (Three Lines)	2	Outside	Open	D.C. Sol.	60	Close (b)	Reactor Water Level Low-Low or High Drywell Pressure
<u>Suppression Chamber</u> (One Line)	2	Outside	Open	D.C. Sol.	60	Close (b)	

NOTES: (a) These valves may be open for containment fill with nitrogen.

(b) These valves will periodically be opened for sampling or nitrogen makeup.



2  
3  
4