

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

September 17, 1990

Docket No. 50-220

Mr. Lawrence Burkhardt III Executive Vice President, Nuclear Operations Niagara Mohawk Power Corporation 301 Plainfield Road Syracuse, New York 13212

Dear Mr. Burkhardt:

09240240

SUBJECT: RESPONSE TO GENERIC LETTER 86-01, "SAFETY CONCERNS ASSOCIATED WITH PIPE BREAKS IN THE BWR SCRAM SYSTEM". NINE MILE POINT UNIT 1 (TAC NO. 71392)

The Nuclear Regulatory Commission's Generic Letter 86-01 transmitted the staff's Safety Evaluation Report regarding the integrity of BWR scram discharge piping systems. The staff report endorsed the Boiling Water Reactor Owners Group letter (BWROG-8420) regarding periodic visual verification of the scram system piping integrity. BWROG-8420 recommended that licensees of plants with ASME Code Class 2 scram discharge volume piping perform an additional inspection once per refueling cycle consisting of a post-scram walkdown of the piping. BWROG-8420 also recommended that each utility individually evaluate and endorse the group position.

By letter dated December 15, 1986, Niagara Mohawk Power Corporation (NMPC) proposed to replace the post-scram walkdown inspection described in BWROG-8420 with a hydrostatic test in accordance with the ASME Code Section XI 1983 Edition, Summer 1983 Addenda, IWA-5000 and IWC-5000, for Nine Mile Point Unit 1.

In response to the staff's request for the bases for not performing a post-scram inspection as recommended in BWROG-8420 and justification to show that the hydrostatic test is equivalent to a post-scram walkdown inspection in detecting piping system leakage, NMPC provided the necessary information by letter dated April 2, 1990. The staff has reviewed this response and on the basis of its review, concludes that NMPC has provided adequate justification to

ma wit

.

.

.

, - , , F - , , , Mr. Lawrence Burkhardt

perform a hydrostatic test in lieu of a post-scram walkdown. The proposed hydrostatic test therefore satisfies the staff position in Generic Letter 86-01 regarding the scram system piping integrity. This completes our review of activities associated with TAC No. 71392.

Sincerely, Robert Martin

Robert E. Martin, Senior Project Manager Project Directorate I-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure: Safety Evaluation

cc w/enclosure:
See next page

' R

· ·

۰ ۱ ۱ •

,

Mr. L. Burkhardt III Wiagara Mohawk Power Corporation

cc:

Mr. Mark J. Wetterhahn, Esquire Bishop, Cook, Purcell & Reynolds 1400 L. Street, N.W. Washington, D. C. 20005-3502

Supervisor Town of Scriba R. D. #4 Oswego, New York 13126

Mr. Joseph F. Firlit General Supt.-Nuclear Generation Niagara Mohawk Power Corporation Nine Mile Point Nuclear Station Post Office Box 32 Lycoming, New York 13093

Resident Inspector U. S. Nuclear Regulatory Commission Post Office Box 126 Lycoming, New York 13093

Mr. Gary D. Wilson, Esquire Niagara Mohawk Power Corporation 300 Erie Boulevard West Syracuse, New York 13202

Regional Administrator, Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

Ms. Donna Ross New York State Energy Office 2 Empire State Plaza 16th Floor Albany, New York 12223 Nine Mile Pourt Nuclear Station, Unit No. 1

Mr. Kim Dahlberg Unit 1 Station Superintendent Nine Mile Point Nuclear Station Post Office Box 32 Lycoming, New York 13093

Mr. Peter E. Francisco, Licensing Niagara Mohawk Power Corporation 301 Plainfield Road Syracuse, New York 13212

Charlie Donaldson, Esquire Assistant Attorney General New York Department of Law 120 Broadway New York, New York 10271

Mr. Paul D. Eddy State of New York Department of Public Service Power Division, System Operations 3 Empire State Plaza Albany, New York 12223 . . · · ,

.

.

t.

• .

,

.

, . . , . . • ·





Mr. Lawrence Burkhardt

- 2 -

perform a hydrostatic test in lieu of a post-scram walkdown. The proposed hydrostatic test therefore satisfies the staff position in Generic Letter 86-01 regarding the scram system piping integrity. This completes our review of activities associated with TAC No. 71392.

Sincerely,

Original signed by: Daniele Oudinot for Robert E. Martin, Senior Project Manager Project Directorate I-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure: Safety Evaluation

cc w/enclosure: See next page

Distribution: Docket_File NRC/Local PDRs PDI-1 Reading SVarga RWessman CVogan RACapra REMartin OGC EJordan ACRS (10) Plant file JRajan JLinville

PDI-1	P DD -15	PD I-D	PDI-1 R ^{oc}
CVogan cơ	BOudinot	REMartin:rsc	RACapra
9/ 4/90	9// <i>3</i> /90	9//3/90	9/17 /90
	•		• • •

DOCUMENT NAME: LTR TO BURKHARDT TAC 71392

· · ·

•

· ·

') '