

UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Niagara Mohawk Power Corporation) Docket No.50-220
(Nine Mile Point Nuclear Station Unit No. 1)

APPLICATION FOR AMENDMENT
TO
OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. DPR-63, hereby requests that Section 3.6.2 and the associated bases for Section 3.6.2 as set forth in Appendix A to that License be amended. The proposed change has been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed change to the Technical Specifications is set forth in Attachment A to this application. The proposed change incorporates a revised setpoint for isolation of the Emergency Cooling System on high steam flow, which was determined by calculation and verified to be conservative by system test. The proposed change would not authorize any change in the types of effluents or in the authorized power level of the facility. Supporting information and an analysis which demonstrates that the proposed change involves no significant hazards consideration pursuant to 10C.F.R. 50.92 is included as Attachment B.

Wherefore, Applicant respectfully requests the Appendix A to Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

by *[Signature]*
Vice President
Nuclear Engineering

Subscribed and Sworn to before me
on this *7th* day of *November*, 1990.

[Signature]
NOTARY PUBLIC

000065ZZ3

DIANE R. KIMBALL
Notary Public in the State of New York
Qualified in Onondaga County No. 4933503
My Commission Expires May 31, 19*92*

9011130216 901106
PDR ADOCK 05000220
P PDC

