



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-410

NINE MILE POINT NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 24
License No. NPF-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated April 3, 1990, as supplemented June 29, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by the deletion of paragraph 2.C(9) Part (a) from Facility Operating License No. NPF-69.

9012310029 901218
PDR ADDCK 05000410
P PDR





3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



for Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Date of Issuance: December 18, 1990





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 24 TO FACILITY OPERATING LICENSE NO. NPF-69

DOCKET NO. 50-410

Revise Appendix A as follows:

Remove Page

Page 5 of License No. NPF-69

Insert Page

Page 5 of License No. NPF-69



(6) Initial Startup Test Program (Section 14, SER, SSERs 4 and 5)

Any changes to the Initial Test Program described in Section 14 of the Final Safety Analysis Report made in accordance with the provisions of 10 CFR 50.59 shall be reported in accordance with 50.59(b) within one month of such change.

(7) Operation with Reduced Feedwater Temperature (Section 15.1, SSER 4)

Niagara Mohawk Power Corporation shall not operate the facility with reduced feedwater temperature for the purpose of extending the normal fuel cycle. The facility shall not be operated with a feedwater heating capacity less than that required to produce a feedwater temperature of 400°F at rated steady-state conditions unless analyses supporting such operations are submitted by Niagara Mohawk Power Corporation and approved by the staff.

(8) Safety Parameter Display System (SPDS) (Section 18.2, SSERs 3 and 5)

Prior to startup following the first refueling outage, Niagara Mohawk Power Corporation shall have operational an SPDS that includes the revisions described in their letter of November 19, 1985. Before declaring the SPDS operational, the licensee shall complete testing adequate to ensure that no safety concerns exist regarding the operation of the Nine Mile Point Nuclear Station, Unit No. 2 SPDS.

(9) Detailed Control Room Design Review (Section 18.1, SSERs 5 and 6)

(b) Prior to startup following the first refueling outage, Niagara Mohawk Power Corporation shall provide the results of the reevaluation of normally lit and nuisance alarms for NRC review in accordance with its August 21, 1986 letter.

(c) Prior to startup following the first refueling outage, Niagara Mohawk Power Corporation shall complete permanent zone banding of meters in accordance with its August 4, 1986 letter.

D. The facility requires exemptions from certain requirements of 10 CFR Part 50 and 10 CFR Part 70.

