



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220

NINE-MILE-POINT-NUCLEAR STATION UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 126  
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated July 27, 1988, as supplemented May 21, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, page 5, section 2.E of Facility Operating License No. DPR-63 is hereby amended to read as follows:
  - E. This license is effective as of the date of issuance and shall expire on August 22, 2009.

9111080179 911022  
PDR ADOCK 05000220  
P PDR



3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

*Robert A. Capra*

Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Page 5 of license

Date of Issuance: October 22, 1991



2.D.(7) Fire Protection

The licensee may proceed with and is required to complete the modifications identified in Table 3.1 of the NRC's Nine Mile Point Unit 1 Safety Evaluation Report (SER), Fire Protection Review, dated July 26, 1979. These modifications shall be completed in accordance with the schedule in Table 3.1 of the SER or supplements thereto.

Further, Niagara Mohawk Power Corporation shall, prior to implementation, provide for Commission review and obtain Commission approval of the final design of modifications as indicated in section 3.1 of the Safety Evaluation Report.

Except for the modifications described in the approved fire protection plan and approved as a result of Commission review of the Nine Mile Point Unit 1 Nuclear Plant Fire Protection Program, Niagara Mohawk Power Corporation is authorized to make changes to the Program without prior Commission approval provided that such changes do not result in a decrease in the effectiveness of the Program.

The licensee is required to implement the administrative controls identified in Section 6 of the SE. The administrative controls shall be in effect by September 1, 1979.

2.D.(8) Hot Process Pipe Penetrations

Hot Process Pipe Penetrations in the Emergency Condenser Steam Supply (2 each), Main Steam (2 each), Feedwater (2 each), Cleanup Suction (1 each), and Cleanup Return (1 each) piping systems have been identified as not fully in conformance with FSAR design criteria. This anomaly in design condition from the original design is approved for the duration of Cycle 8 or until March 31, 1986, whichever occurs first, subject to the following conditions:

- (a) An unidentified leakage limit of a change of 1 gallon per minute in 24 hours to permit operation will be imposed by administrative control (Standing Order) at the facility for the interim period.
- (b) The licensee shall restore the facility to a condition consistent with the FSAR or provide a change to the FSAR criteria for staff review and approval prior to restart from the forthcoming Cycle 8 outage.

E. This license is effective as of the date of issuance and shall expire on August 22, 2009.

FOR THE ATOMIC ENERGY COMMISSION

Original Signed by

A. Giambusso, Deputy Director  
for Reactor Projects  
Directorate of Licensing

Attachment:

Appendices A & B -

Technical Specifications

Date of Issuance: December 26, 1974



.....  
.....  
.....

26