



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-410

NINE MILE POINT NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 35  
License No. NPF-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated August 21, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-69 is hereby amended to read as follows:

9201020313 911217  
PDR ADDCK 05000410  
PDR



(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. 35 are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.


FOR THE NUCLEAR REGULATORY COMMISSION

*Robert A. Capra*

Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 17, 1991



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 35 TO FACILITY OPERATING LICENSE NO. NPF-69

DOCKET NO. 50-410

Revise Appendix A as follows:

Remove Page

3/4 9-8

Insert Page

3/4 9-8



## REFUELING OPERATIONS

### 3/4.9.6 REFUELING PLATFORM

#### LIMITING CONDITIONS FOR OPERATION

---

3.9.6 The refueling platform shall be OPERABLE and used for handling fuel assemblies or control rods within the reactor pressure vessel.

APPLICABILITY: During handling of fuel assemblies or control rods within the reactor pressure vessel.

#### ACTION:

With the requirements for refueling platform OPERABILITY not satisfied, suspend use of any inoperable refueling platform equipment from operations involving the handling of control rods and fuel assemblies within the reactor pressure vessel after placing the load in a safe condition.

#### SURVEILLANCE REQUIREMENTS

---

4.9.6 Each refueling platform crane or hoist used for handling of control rods or fuel assemblies within the reactor pressure vessel shall be demonstrated OPERABLE within 7 days before the start of such operations with that crane or hoist by:

- a. Demonstrating operation of the overload cutoff on the main hoist when the load exceeds  $1200 \pm 50$  pounds.
- b. Demonstrating operation of the overload cutoff on the frame mounted and monorail mounted auxiliary hoists when the load exceeds  $1000 \pm 50$  pounds.
- c. Demonstrating operation of the main and auxiliary hoist uptravel stops when the grapple is lower than or equal to 7 feet  $3 \frac{3}{4}$  inches below the platform tracks.
- d. Demonstrating operation of the downtravel mechanical cutoff on the main hoist when grapple hook down travel reaches 4 inches below fuel assembly handle.
- e. Demonstrating operation of the slack cable cutoff on the main hoist when the load is less than  $50 \pm 10$  pounds.
- f. Demonstrating operation of the loaded interlock on the main hoist when the load exceeds  $485 \pm 50$  pounds.
- g. Demonstrating operation of the redundant loaded interlock on the main hoist when the load exceeds  $550 \pm 50$  pounds.

