

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9203300118 DOC. DATE: 92/03/20 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH. NAME AUTHOR AFFILIATION
 SYLVIA, B.R. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License DPR-63, changing TS Sections
 3.1.3, 4.1.3, 3.6.2 & 4.6.2 to increase setpoint for emergency
 cooling sys automatic initiation time delay from 10 s to
 12 s to prevent unnecessary actuation of sys.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+3
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME		LTR	ENCL
	PD1-1 LA		1	1	PD1-1 PD		1	1
	BRINKMAN, D.		2	2				
INTERNAL:	ACRS		6	6	NRR/DET/ECMB 7D		1	1
	NRR/DET/ESGB		1	1	NRR/DOEA/OTSB11		1	1
	NRR/DST 8E2		1	1	NRR/DST/SELB 7E		1	1
	NRR/DST/SICB8H7		1	1	NRR/DST/SRXB 8E		1	1
	NUDOCS-ABSTRACT		1	1	OC/LEMB		1	0
	OGC/HDS1		1	0	<u>REG FILE 01</u>		1	1
	RES/DSIR/EIB		1	1				
EXTERNAL:	NRC PDR		1	1	NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL 22

R
I
D
S
/
A
D
D
S



•
•
•
•
•

•
•
•
•
•
•
•

•

•

•

• •

•

•

B. Ralph Sylvia
Executive Vice President
Nuclear

March 20, 1992
NMP1L 0653

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Gentlemen:

Niagara Mohawk proposes a change in the Bases for Nine Mile Point Unit 1 Technical Specification Sections 3.1.3 and 4.1.3, and Sections 3.6.2 and 4.6.2. The proposed change increases the setpoint for the Emergency Cooling System (ECS) automatic initiation time delay from 10 seconds to 12 seconds to allow a greater margin for preventing unnecessary actuation of the ECS during anticipated turbine trips.

Attachment A to this letter is the proposed revised Technical Specification Bases change and Attachment B provides supporting information justifying the change.

Very truly yours,



B. Ralph Sylvia
Exec. Vice President-Nuclear

DLC/pr
Attachment
000722DD

xc: Regional Administrator, Region I
Mr. W. L. Schmidt, Senior Resident Inspector
Mr. R. A. Capra, Project Director, NRR
Mr. D. S. Brinkman, Senior Project Manager, NRR
Mr. L. E. Nicholson, Section Chief, Reactor Projects, Branch No. 1B
Records Management
Ms. Donna Ross
Division of Policy
Analysis and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, NY 12223

9203300118 920320
PDR ADOCK 05000220
PDR

A001
11



ATTACHMENT A

**NIAGARA MOHAWK POWER CORPORATION
DOCKET NO. 50-220
LICENSE NO. DPR-63**

Proposed Change to Technical Specification Bases

Replace existing pages 49 and 235 with the attached revised pages. These pages have been retyped in their entirety with marginal markings to indicate changes to the text.

