



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-410

NINE MILE POINT NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 39  
License No. NPF-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated September 17, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-69 is hereby amended to read as follows:

9212040549 921120  
PDR ADDCK 05000410  
P PDR



(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. 39 are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

*Robert A. Capra*

Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: November 20, 1992



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 39 TO FACILITY OPERATING LICENSE NO. NPF-69

DOCKET NO. 50-410

Revise Appendix A as follows:

Remove Pages

3/4 3-72

3/4 3-73

Insert Pages

3/4 3-72

3/4 3-73




TABLE 3.3.7.2-1

SEISMIC MONITORING INSTRUMENTATION

<u>INSTRUMENTS AND SENSOR LOCATIONS</u>	<u>MEASUREMENT RANGE</u>	<u>MINIMUM INSTRUMENTS OPERABLE</u>
1. Triaxial Time-History Accelerographs and Trigger		
a. Reactor Bldg. Mat. El. 175'-0"	0 ± 1.0 g	1
b. Reactor Bldg. Refueling Floor El. 353'-10"	0 ± 1.0 g	1
c. Control Bldg. Mat. El. 214'-0"	0 ± 1.0 g	1
2. Triaxial Peak Accelerographs		
a. Diesel Generator Bldg. Service Water Piping	0-5 g*	1
b. Prim. Cont. High Pr. Core Spray Piping	0-10 g*	1
c. Prim. Cont. Reactor Pedestal	0-10 g*	1
3. Triaxial Seismic Switches		
Reactor Bldg. Mat. El. 175'-0"	0.025-0.25 g (Adjustable)	1**
4. Triaxial Response-Spectrum Recorders		
a. Reactor Bldg. Mat. El. 175'-0"	0 ± 2 g*	1**
b. Prim Cont. RHR Piping Pene. El. 294'-6"	0 ± 2 g*	1
c. Reactor Bldg. Refueling Fl. El. 353'-10"	0 ± 2 g*	1
d. Control Bldg. Mat. El. 214'-0"	0 ± 2 g*	1

\* Calibration required to be for the range: ± 1g.

\*\* With control room annunciation.





TABLE 4.3.7.2-1

SEISMIC MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENTS AND SENSOR LOCATIONS</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>
1. Triaxial Time-History Accelerographs and Trigger			
a. Reactor Bldg. Mat. El. 175'-0"	M*	SA	R
b. Reactor Bldg. Refueling Fl. El. 353'-10"	M*	SA	R
c. Control Bldg. Mat. El. 214'-0"	M*	SA	R
2. Triaxial Peak Accelerographs			
a. Diesel Gen. Bldg. Service Water Piping	NA	NA	R**
b. Prim. Cont. High Pr. Core Spray Piping	NA	NA	R**
c. Prim. Cont. Reactor Pedestal	NA	NA	R**
3. Triaxial Seismic Switches			
Reactor Bldg. Mat. El. 175'-0"	M***	SA	R
4. Triaxial Response-Spectrum Recorders			
a. Reactor Bldg. Mat. El. 175'-0"	M	SA	R**
b. Prim. Cont. RHR Piping Pene. El. 294'-6"	NA	NA	R**
c. Reactor Bldg. Refueling Fl. El. 353'-10"	NA	NA	R**
d. Control Bldg. Mat. El. 214'-0"	NA	NA	R**

\* Battery and Trigger only.

\*\* Calibration required to be for the range:  $\pm 1$  g.

\*\*\* Except seismic trigger.

