



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220


NINE MILE POINT NUCLEAR STATION UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 134
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated November 20, 1990, as superseded February 7, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

9212150126 921203
PDR ADOCK 05000220
P PDR



(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 134, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.


FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 3, 1992



ATTACHMENT TO LICENSE AMENDMENT


AMENDMENT NO. 134 TO FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise Appendix A as follows:

Remove Page
146

Insert Page
146




LIMITING CONDITION FOR OPERATION

Table 3.3.4

PRIMARY CONTAINMENT ISOLATION VALVES
LINES ENTERING FREE SPACE OF THE CONTAINMENT

<u>Line or System</u>	<u>No. of Valves (Each Line)</u>	<u>Location Relative to Primary Containment</u>	<u>Normal Position</u>	<u>Motive Power</u>	<u>Maximum Oper. Time (Sec)</u>	<u>Action on Initiating Signal</u>	<u>Initiating Signal (All Valves Have Remote Manual Backup)</u>
<u>Drywell Vent & Purge</u>							
<u>N₂ Connection (One Line)</u>	1	Outside	Closed (a)	Air/D.C. Sol.	60	Close	Reactor water level low-low or high drywell pressure or high radiation at stack monitoring.
	1	Outside	Closed (a)	A.C. Motor	60	Close	
<u>Air Connection (One Line)</u>	1	Outside	Closed (a)	Air/D.C. Sol.	60	Close	
	1	Outside	Closed (a)	A.C. Motor	60	Close	
<u>Suppression Chamber Vent & Purge</u>							
<u>N₂ Connection (One Line)</u>	1	Outside	Closed (a)	Air/D.C. Sol.	60	Close	Reactor water level low-low or high drywell pressure or high radiation at stack monitoring.
	1	Outside	Closed (a)	A.C. Motor	60	Close	
<u>Air Connection (One Line)</u>	1	Outside	Closed (a)	Air/D.C. Sol.	60	Close	
	1	Outside	Closed (a)	A.C. Motor	60	Close	
<u>Drywell N₂ Makeup (One Line)</u>	2	Outside	Closed (b)	Air/D.C. Sol.	60	Close	Reactor water level low-low or drywell high pressure
<u>Suppression Chamber N₂ Makeup (One Line)</u>	2	Outside	Closed (b)	Air/D.C. Sol.	60	Close	Reactor water level low-low or drywell high pressure
<u>Drywell Equipment Drain Line (One Line)</u>	1	Inside	Open	A.C. Motor	60	Close	Reactor water level low-low or drywell high pressure
	1	Outside	Open	Air/D.C. Sol.	60	Close	
<u>Floor Drain Line (One Line)</u>	1	Inside	Open	A.C. Motor	60	Close	
	1	Outside	Open	Air/D.C. Sol.	60	Close	
<u>Suppression Chamber Water Makeup (One Line)</u>	1	Outside	Closed (b)	A.C. Motor	60	-	Remote manual
	1	Outside	-	Self Act. Ck.	--	-	-
<u>Vacuum Relief Atmosphere to Pressure Suppression System (Three Lines)</u>	1	Outside	Closed	A.C. Motor	5	Open	Negative pressure rel- ative to atmosphere
	1	Outside	-	Self Act. Ck.	--	-	-
<u>Reactor Cleanup System Relief Valve Discharge (One Line to Suppression Chamber)</u>	2	Outside	-	Self Act. Ck.	--	-	-



.

1
2
3

1
2

•
•

•

•

•