

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9303040165      DOC. DATE: 93/02/26      NOTARIZED: NO      DOCKET #  
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe      05000220  
 AUTH. NAME      AUTHOR AFFILIATION  
 TERRY, C.D.      Niagara Mohawk Power Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                                  Document Control Branch (Document Control Desk)

SUBJECT: Forwards Final Rept MPM-USE-293216, "Elastic-Plastic Fracture Mechanics Assessment of Nine Mile Pint Unit 1 Beltline Plates for Service Level C & D Loadings," in response to Rev 1 to GL 92-01. *See Reports*

DISTRIBUTION CODE: A028D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 2 + 150  
 TITLE: Generic Letter 92-01 Responses (Reactor Vessel Structural Integrity 1

**NOTES:**


	RECIPIENT ID CODE/NAME	COPIES	L	T	R	ENCL	RECIPIENT ID CODE/NAME	COPIES	L	T	R	ENCL	
	PDI-1 PD	1				1	BRINKMAN, D.	2				2	
INTERNAL:	ACRS	6				6	NRR MCDONALD, D	1				1	
	NRR/DE/EMCB	2				2	NRR/DORS/OGCB	1				1	
	NUDOCS-ABSTRACT	1				1	OC/LEMB	1				0	
	OGC/HDS1	1				0	<u>REG FILE</u> 01	1				1	
	RES/DSIR/EIB	1				1							
EXTERNAL:	NRC PDR	1				1	NSIC	1				1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR      20      ENCL      18

*MA-2*



February 26, 1993  
NMPIL 0739

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63  
TAC No. M83486

SUBJECT: GENERIC LETTER 92-01, REVISION 1, REACTOR VESSEL  
STRUCTURAL INTEGRITY, ELASTIC-PLASTIC FRACTURE  
MECHANICS ASSESSMENT FOR SERVICE LEVEL C AND D  
LOADINGS

Gentlemen:

By letter dated August 12, 1992, the Staff recommended that Niagara Mohawk perform an analysis to demonstrate that two beltline plates with Charpy upper shelf energies (USE) less than 50 ft-lbs have margins of safety against fracture equivalent to those required by Appendix G of the ASME Code. Our letter of October 16, 1992 (NMPIL 0707), responded to the Staff's request and provided an analysis of the two beltline plates for Service Level A and B loadings. A revised analysis for the Level A and B loadings was submitted on December 17, 1992 (NMPIL 0723), in response to the Staff's request of November 13, 1992. Our letter of December 17, 1992, indicated that a separate report addressing Service Level C and D loading calculations would be submitted by March 1, 1993.

Enclosed is a copy of our report entitled, "Elastic-Plastic Fracture Mechanics Assessment of Nine Mile Point Unit 1 Beltline Plates for Service Level C and D Loadings." As we had anticipated, the Service Level A and B loadings (and not the Level C and D) are limiting in terms of ductile fracture. Based on the calculations previously submitted for Service Level A and B loadings and those contained herein, Niagara Mohawk has concluded that NMP1 plate G-8-1 is limiting from a ductile fracture perspective, and the USE must be maintained above 23 ft-lbs.

040039

9303040165 930226  
PDR ADDCK 05000220  
P PDR

ADZP 1/1

11

In addition, our letter of December 17, 1992, indicated that a separate report on USE estimates for the beltline welds would be submitted by March 1, 1993. However, due to the Staff's recent request to provide a determination of the beltline plate orientation, the report on USE estimates for beltline welds will now be submitted by March 22, 1993. The Staff has agreed that this date is acceptable.

Very truly yours,



C. D. Terry  
Vice President  
Nuclear Engineering

AER/mls  
003611GG  
Enclosure

xc: Regional Administrator, Region I  
Mr. R. A. Capra, Director, Project Directorate I-1, NRR  
Mr. D. S. Brinkman, Senior Project Manager, NRR  
Mr. W. L. Schmidt, Senior Resident Inspector  
Mr. K. Cozens, NUMARC  
Records Management

