



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

March 24, 1993

Docket No. 50-220

Mr. B. Ralph Sylvia  
Executive Vice President, Nuclear  
Niagara Mohawk Power Corporation  
301 Plainfield Road  
Syracuse, New York 13212

Dear Mr. Sylvia:

SUBJECT: RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING  
SUPPLEMENT 1 TO GENERIC LETTER (GL) 87-02 - NINE MILE POINT  
NUCLEAR STATION UNIT NO. 1 (TAC NO. M69461)

By letter dated September 18, 1992, Niagara Mohawk Power Corporation (NMPC) submitted its response to Supplement 1 to GL 87-02, "Verification of Seismic Adequacy of Mechanical and Electrical Equipment in Operating Reactors, Unresolved Safety Issue (USI) A-46," for Nine Mile Point Nuclear Station Unit No. 1 (NMP-1). The NRC staff provided its safety evaluation (SE) regarding this submittal in an enclosure to a letter dated November 17, 1992. The NRC staff's SE concluded in part that the NMPC submittal of September 18, 1992, did not provide sufficient information regarding the development of the ground response spectrum (GRS) and the in-structure response spectra (IRS). Therefore, NMPC was requested to provide certain additional information that was identified in the SE. NMPC responded to this request for additional information (RAI) by letter dated January 22, 1993.

The NRC staff has reviewed NMPC's January 22, 1993, response to the RAI. We have determined the following as a result of this review:

1. NMPC developed a new seismic GRS for NMP-1 in 1984. The new GRS was based on a NUREG/CR-0098, "Development of Criteria for Seismic Review of Selected Nuclear Power Plants," 50th percentile spectrum anchored at a peak ground acceleration of 0.13g. NMPC stated that the new GRS enveloped the original licensing basis five percent damped GRS. The GRS was increased by a factor of 1.5 to serve as an in-structure response spectrum for equipment located less than 40 feet above grade.
2. For equipment located above 40 feet, NMPC generated new IRS for the NMP-1 reactor building and turbine building. The new IRS were developed using four sets of artificial time histories. Each set consisted of three statistically independent components (two horizontal and one vertical). The average of the calculated ground response spectra from the four sets of time histories enveloped the original licensing basis GRS.

9303300278 930324  
PDR ADDCK 05000220  
P PDR

NRC FILE CENTER COPY

A4-3  
DF011/0

580034


March 24, 1993

3. Three-dimensional lumped mass stick models were used to generate the IRS. The motions in the three directions were applied simultaneously. Four IRS were generated for each of the four sets of time histories. At each frequency, the four individual IRS were averaged to produce a single averaged spectrum. The single in-structure response spectrum was peak broadened by plus/minus 15 percent to produce a design in-structure response spectrum. A seven percent structural damping value was used in the analysis.
4. No soil-structure interaction was considered since the reactor and turbine buildings are founded on bedrock.
5. No torsional effects in the dynamic analysis were considered.

Based on our review of the NMPC response of January 22, 1993, and the NRC staff positions delineated in Supplemental Safety Evaluation Report No. 2 that was transmitted by GL 87-02, we have concluded that the procedure used to generate the IRS is adequate and acceptable. However, we note that the IRS presented in the NMPC submittal should be treated as median-centered response spectra primarily due to the use of a NUREG/CR-0098 50th percentile spectrum as a basis for the development of the new GRS.

The NRC staff may elect to audit the procedures used in generation of the floor response spectra to verify they correctly reflect the licensing basis. Therefore, please maintain this information in a readily accessible status.

Sincerely,



Donald S. Brinkman, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc: See next page



Mr. B. Ralph Sylvia  
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station  
Unit No. 1

cc:

Mark J. Wetterhahn, Esquire  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005-3502

Mr. Kim Dahlberg  
Unit 1 Station Superintendent  
Nine Mile Point Nuclear Station  
Post Office Box 32  
Lycoming, New York 13093

Supervisor  
Town of Scriba  
Route 8, Box 382  
Oswego, New York 13126

Mr. David K. Greene  
Manager Licensing  
Niagara Mohawk Power Corporation  
301 Plainfield Road  
Syracuse, New York 13212

Mr. Neil S. Carns  
Vice President - Nuclear Generation  
Niagara Mohawk Power Corporation  
Nine Mile Point Nuclear Station  
Post Office Box 32  
Lycoming, New York 13093

Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, New York 10271

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Post Office Box 126  
Lycoming, New York 13093

Mr. Paul D. Eddy  
State of New York  
Department of Public Service  
Power Division, System Operations  
3 Empire State Plaza  
Albany, New York 12223

Gary D. Wilson, Esquire  
Niagara Mohawk Power Corporation  
300 Erie Boulevard West  
Syracuse, New York 13202

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Ms. Donna Ross  
New York State Energy Office  
2 Empire State Plaza  
16th Floor  
Albany, New York 12223



March 24, 1993

3. Three-dimensional lumped mass stick models were used to generate the IRS. The motions in the three directions were applied simultaneously. Four IRS were generated for each of the four sets of time histories. At each frequency, the four individual IRS were averaged to produce a single averaged spectrum. The single in-structure response spectrum was peak broadened by plus/minus 15 percent to produce a design in-structure response spectrum. A seven percent structural damping value was used in the analysis.
4. No soil-structure interaction was considered since the reactor and turbine buildings are founded on bedrock.
5. No torsional effects in the dynamic analysis were considered.

Based on our review of the NMPC response of January 22, 1993, and the NRC staff positions delineated in Supplemental Safety Evaluation Report No. 2 that was transmitted by GL 87-02, we have concluded that the procedure used to generate the IRS is adequate and acceptable. However, we note that the IRS presented in the NMPC submittal should be treated as median-centered response spectra primarily due to the use of a NUREG/CR-0098 50th percentile spectrum as a basis for the development of the new GRS.

The NRC staff may elect to audit the procedures used in generation of the floor response spectra to verify they correctly reflect the licensing basis. Therefore, please maintain this information in a readily accessible status.

Sincerely,

Original signed by:  
Donald S. Brinkman, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File  
NRC & Local PDRs  
PDI-1 Reading  
SVarga  
JCalvo  
RACapra  
CVogan  
DBrinkman  
JMenning

YKim, 7/H/15  
DDorman, 14/D/1  
GBagchi, 7/H/15  
KManoly, 7/E/23  
OGC  
ACRS (10)  
CCowgill, RGN-I  
Plant File

|        |            |             |           |         |         |
|--------|------------|-------------|-----------|---------|---------|
| OFFICE | LA:PDI-1   | PM:PDI-1    | PM:PDI-1  | BC:ECQB | D:PDI-1 |
| NAME   | CVogan (w) | JMenning:av | DBrinkman | GBagchi | RACapra |
| DATE   | 3/24/93    | 3/24/93     | 3/24/93   | 3/24/93 | 3/24/93 |

OFFICIAL RECORD COPY  
FILENAME: G:\NM169461.LTR

1. The first part of the document discusses the importance of maintaining accurate records of all activities. It emphasizes that this is essential for ensuring the integrity and reliability of the information collected.

2. The second part of the document outlines the procedures for collecting and analyzing data. It describes the various methods used to gather information and the steps involved in processing and interpreting the results.

3. The third part of the document provides a detailed account of the findings of the study. It presents the data in a clear and concise manner, highlighting the key trends and patterns observed.

4. The fourth part of the document discusses the implications of the findings and offers recommendations for future research. It suggests that further studies should be conducted to explore the underlying causes of the observed phenomena.

5. The fifth part of the document concludes the report and summarizes the main points. It reiterates the importance of accurate record-keeping and the need for ongoing research in this field.