

Docket File



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

April 9, 1993

Docket No. 50-220

LICENSEE: Niagara Mohawk Power Corporation
FACILITY: Nine Mile Point Nuclear Station Unit No. 1
SUBJECT: SUMMARY OF MARCH 23, 1993, MEETING TO DISCUSS DIFFERENCES IN
METHODOLOGY USED FOR SUMMING CONDENSATION OSCILLATION LOADS IN NINE
MILE POINT UNIT NO. 1 TORUS SHELL MATERIALS (TAC NO. M85003)

A meeting was held in the NRC One White Flint North Office in Rockville, Maryland, with Niagara Mohawk Power Corporation (NMPC) and NRC staff representatives to discuss differences in methodology used for summing condensation oscillation loads in Nine Mile Point Unit No. 1 (NMP-1) torus shell materials. The NRC staff had requested this meeting. Enclosure 1 is a list of meeting attendees. Enclosure 2 is a copy of the handout material provided by NMPC.

By letter dated May 14, 1991, NMPC submitted a report to the NRC proposing a reduction in the condensation oscillation (CO) loads in the NMP-1 torus. The NRC staff reviewed that submittal and issued its safety evaluation on August 25, 1992. In its safety evaluation, the NRC staff concluded that CO stresses in the torus walls should be combined by the absolute sum method. NMPC's position was that these stresses should be combined by the square root of the sum of the square method plus the absolute sum of the stresses for four frequency peaks.

NMPC noted this difference in methodology in a letter to the NRC dated November 23, 1992, and requested a rereview. The November 23, 1992, letter also proposed to defer implementation of possible torus modifications for one additional fuel cycle. The NRC staff responded by letter dated December 23, 1992. Our response approved continued operation provided the criteria specified in our January 22, 1985, safety evaluation continue to be satisfied and the monitoring programs specified in our August 25, 1992, safety evaluation are implemented. Our December 23, 1992, letter also suggested that a meeting be held to discuss the differences in methodology for summing the CO loads.

By letter dated March 12, 1993, NMPC reported the results of the latest wall thickness measurements of the NMP-1 torus. NMPC reported that the NMP-1 torus is still in conformance with the NRC's safety evaluation of January 22, 1985, and based on the observed corrosion rate, the torus will not corrode below the required minimum wall thickness by the next refueling outage.


NMPC and their consultants presented information (see Enclosure 2) which appeared to be supportive of NMPC's methodology position for summing the CO

DF

9304190155 930409
PDR ADDCK 05000220
PDR

NRC FILE CENTER COPY

M6m0-4




1954-1955

April 9, 1993

loads. The NRC staff agreed to rereview the NMPC methodology. To perform this review, we request that two reports (NEDO-24010-03, August 1979 and SMA 12101.04-R001D, March 1981) referenced in Enclosure 2 be submitted to the NRC within 30 days.

The NRC staff also requested NMPC to document, within 30 days, the assertion that the Continuum Dynamics, Inc. acoustic model, which implies a unity reduction factor (no reduction) for the case of uncorrelated downcomers within a torus bay with all bays correlated, is correct.

Sincerely,




Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. License Handout Material

cc w/enclosures:
See next page



Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit No. 1

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Mr. Kim Dahlberg
Unit 1 Station Superintendent
Nine Mile Point Nuclear Station
Post Office Box 32
Lycoming, New York 13093

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, New York 13126

Mr. David K. Greene
Manager Licensing
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Mr. Neil S. Carns
Vice President - Nuclear Generation
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
Post Office Box 32
Lycoming, New York 13093

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 126
Lycoming, New York 13093

Mr. Paul D. Eddy
State of New York
Department of Public Service
Power Division, System Operations
3 Empire State Plaza
Albany, New York 12223

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223



11

Attendance List

March 23, 1993 Meeting to Discuss Differences

in Methodology Used for Summing CO Loads

<u>Name</u>	<u>Position</u>	<u>Organization</u>
Donald S. Brinkman	Senior Project Manger	NRC/NRR/PDI-1
Robert A. Capra	Director, PDI-1	NRC/NRR/PDI-1
Robert P. Kennedy	Struct. Mech. Consulting	Consultant, NMPC
Richard H. Berks	Principal Engineer	Teledyne Engr. Serv.
Richard A. Enos	Principal Engineer	Teledyne Engr. Serv.
Lee Klosowski	Gen. Supv. Nuc. Des U1	MMPC
Mohammed F. Alvi	Supervisor Civil/Struct U1	NMPC
Philip B. George	Engineer	NMPC
Alan Bilanin	Senior Associate	Continuum Dynamics
John Lehner	Group Leader	BNL
Constantino Economos	Engineer	BNL
S. K. Chaudhary	Sr. Reactor Engr.	USNRC-RGN-I
J. Kudrick	Section Chief	NRC/NRR/SCSB
M. Snodderly	Reactor Engineer	NRC/NRR/SCSB
Tony D'Angelo	Sr. Reactor Engineer	NRC/NRR/SCSB
Jim Davis	Materials Engineer, NRR	NRC/NRR/DE
Robert B. Burtch, Jr.	Manager, Nuclear Communications	NMPC
Gary D. Wilson	Managing Counsel	NMPC
Nick Spagnoletti	Program Director-Licensing	NMPC
Robert Pollard	Nuclear Safety Engineer	Union of Concerned Scientists



2

NIAGARA MOHAWK POWER CORPORATION

PRESENTATION

TO

NRC

MARCH 23, 1993

NINE MILE POINT UNIT 1

**REDUCTION IN MARK I TORUS PROGRAM CONDENSATION
OSCILLATION LOAD DEFINITION AND RESULTING EFFECT
ON MINIMUM SHELL THICKNESS REQUIREMENTS**



1 2 3

- AGENDA -

INTRODUCTION

L. KLOSOWSKI

CONDENSATION OSCILLATION LOADS

A. BILANIN

STRESS SUMMATION


R. KENNEDY

SUMMARY

L. KLOSOWSKI

Q & A

ALL



NMP1 TORUS CO LOAD REDUCTION

PURPOSE

RESOLVE INCONSISTENCY BETWEEN NRC SER DATED AUGUST 25, 1992 AND NMPC SUBMITTAL DATED MAY 14, 1991

NMPC SUBMITTAL PROVIDES BASIS FOR REDUCTION IN CONDENSATION OSCILLATION (CO) LOADS DUE TO GEOMETRY DIFFERENCES BETWEEN FSTF AND NMP1 TORUS

NRC SER APPROVES LOAD REDUCTION

NMPC SUBMITTAL COMBINES STRESS HARMONICS USING MODIFIED SRSS* (INCLUDING STRESSES FROM REDUCED CO LOADS)

MODIFIED SRSS SUMMATION ACCEPTED BY NRC IN MARK I TORUS PROGRAM

NRC SER APPROVES MODIFIED SRSS SUMMATION OF STRESS HARMONICS BUT NOT WHEN USING REDUCED CO LOADS

CO LOAD REDUCTION AND MODIFIED SRSS SUMMATION INDEPENDENT

USE OF MODIFIED SRSS (INCLUDING STRESSES FROM REDUCED CO LOADS) APPROPRIATE

THIS ADDITIONAL CLARIFICATION WAS PROVIDED IN NMPC SUBMITTAL DATED NOVEMBER 23, 1992

(* - ABSOLUTE SUM OF 4 LARGEST STRESS HARMONICS PLUS SQUARE ROOT SUM OF SQUARES REMAINING 27 STRESS HARMONICS)



11

MODIFIED SRSS STRESS COMBINATION

**FSTF BUILT (1/16 SEGMENT, 1-BAY, 8 DOWNCOMERS, RIGID
END CAPS)**

TESTS RUN - LOADS, PRESSURES AND STRESSES MEASURED

**ANALYTICAL MODELS DEVELOPED TO MATCH MEASURED
LOADS, PRESSURES AND STRESSES**

**MODIFIED SRSS (ABSOLUTE SUM 4 LARGEST STRESS
HARMONICS AND SRSS REMAINING 27 STRESS HARMONICS)
RESULTED IN GOOD CORRELATION WITH MEASURED
STRESSES**

**(ALL STRESSES WERE CLOSE TO OR EXCEEDED MEASURED
STRESSES)**



24

CO LOAD REDUCTION

FSTF NOT REPRESENTATIVE OF NMP1 TORUS

- RIGID END CAPS
- 8 DOWNCOMERS

NMP1 HAS 8-4-8-4.... DOWNCOMER BAYS

END CAP EFFECTS RESULT IN HIGHER CO LOADS IN ALL
FREQUENCY RANGES

THEREFORE, LOADS AND PRESSURES MEASURED IN FSTF ARE
CONSERVATIVE FOR NMP1 TORUS



24

NMP1 TORUS CO LOAD REDUCTION

SUMMARY

ABSOLUTE SUM OF 4 LARGEST STRESS HARMONICS AND SRSS OF REMAINING 27 STRESS HARMONICS CORRELATES MEASURED AND CALCULATED STRESSES WELL

MEASURED LOADS ARE UNREALISTICALLY HIGH DUE TO END CAP EFFECTS AND 8 DOWNCOMER BAYS

MODIFIED SRSS COMBINATION OF STRESSES FROM REDUCED CO LOADS IS APPROPRIATE


MANY OTHER CONSERVATISMS EXIST

THEREFORE, STRESS REDUCTIONS IN NMPC MAY 14, 1991 SUBMITTAL ARE APPROPRIATE




11

TORUS CO LOAD REDUCTION FULL SCALE TEST FACILITY (FSTF)



VENT
1
2
3
4
5
6
7
8

TRANSDUCER
P5123
P5243
P5323
P5443
P5523
P5643
P5723
P5843



Downcomer exit pressure transducers in FSTF.



44

..

.

.





Figure 3.2. Comparison of the phase angles between harmonic components in the vent exit transducer P5123 (Run M-8)



TORUS CO LOAD REDUCTION CORRELATION OF PRESSURE SOURCES-FSTF RESULTS




Figure 2. Mean Square pressure signals between downcomers 5 and 6, FSTF Run M8, 20 - 35 seconds during condensation oscillation as a function of frequency (measured from zero frequency).



4

TORUS CO LOAD REDUCTION FSTF TEST RESULTS

- ANALYSIS RESULTS BASED ON THE FSTF TESTS HAVE SHOWN THAT DURING CONDENSATION OSCILLATION
 - THE PULSATING CONDENSATION AT EACH EXIT IS RANDOM (UNCORRELATED) IN THE FREQUENCY DOMAIN EXCEPT AT TWO FREQUENCY RANGES
 - THE PULSATING CONDENSATION AT THE DOWN-COMER EXITS ARE STRONGLY CORRELATED BETWEEN DOWNCOMERS AT 4-6 HZ AND WEAKLY CORRELATED AT 8-12 HZ.
 - THESE FINDINGS WERE PRESENTED TO THE NRC ON MARCH 4, 1981
- THE CONSEQUENCE OF THIS RANDOMNESS AND THE GEOMETRY OF THE FULL SCALE TEST FACILITY IS A MEASURED CONDENSATION OSCILLATION TORUS LOAD WHICH IS VERY CONSERVATIVE.



44

TORUS CO LOAD REDUCTION NMP1 TORUS PLAN VIEW




Figure 3. Plan view of Nine Mile Point suppression pool showing 8-4-8-4 downcomer/bay geometry. (Not to Scale)



11

TORUS CO LOAD REDUCTION NMP1 CURRENT ANALYSIS PLAN

- UTILIZE MULTI-BAY HYDRODYNAMIC MODEL AND APPLY SPECIFICALLY TO NINE MILE POINT UNIT 1 TO PROVIDE A MORE REALISTIC CONDENSATION OSCILLATION TORUS SHELL LOAD
- THIS MULTI-BAY HYDRODYNAMIC MODEL TAKES INTO ACCOUNT
 - UNCORRELATED STEAM CONDENSATION
 - ALTERNATING 8 AND 4 DOWNCOMER BAYS



24

Response Combination
Background References

- 1.) Kennedy , R.P, and N.M. Newmark, "Bases for Criteria for Combination of Earthquake and other Transient Responses by the Square-Root-Sum-of-the Squares-Method," NEDO-24010-2, General Electric Company, San Jose, California, December 1978.
- 2.) Kennedy, R.P., Tong, W.H., and N.M. Newmark, "Study to Demonstrate that Approximately the SRSS Combined Response Has Greater than an 84 Percent Nonexceedance Probability When the Newmark-Kennedy Acceptance Criteria are Satisfied, NEDO-24010-03, General Electric Company, San Jose, California, August 1979.

These References State and Demonstrate That:

1. The goal of a response combination procedure should be to retain approximately the same level of conservatism (as expressed by the non-exceedance probability) as exists for each of the component responses contained in the combination.
2. It is unnecessary for the response combination procedure to add additional conservatism.
3. The desired level of conservatism should be placed at other levels in the design process such as the definition of the loading, the response calculational method, and the definition of acceptable response levels.
4. The response combination methodology cannot rationally or uniformly cover potential unconservatism inadvertently introduced elsewhere in the design process.



44

Response Combination Goal of Retaining Conservatism
Introduced Elsewhere is Met So Long As:

$$R_C \geq R_{50\%} \quad (1)$$

And

$$R_C \geq \frac{R_{84\%}}{1.2} \quad (2)$$

Where:

R_c = Combined Response for Defined Loading

$R_{50\%}$ = 50% Non-Exceedance Probability (NEP)
Combined Response For Defined Loading

$R_{84\%}$ = 84% NEP Combined Response For Defined
Loading



100

C.O. Loading

- Defined By Fourier Harmonic Amplitude Coefficients Within 1-HZ Frequency Bands
- Individual Harmonic Amplitudes Are Predominantly Randomly Phases
- It is Incredibly Unlikely that More than A Few Individual Fourier Amplitude Responses Will Worst-Case Combine (Absolute Sum) When Phasing is Random
- Absolute Combination of All Individual Fourier Amplitude Responses is Excessively Conservative and Cannot Be Justified Technically When Phasing is Random.
- Issues Studied Extensively in :
 1. Kennedy, R.P., S.A. Short and W.H. Tong, "Evaluation of Harmonic Phasing for Mark I Torus Shell Condensation Oscillation Loads," SMA 12101.02-R-001, Structural Mechanics Associates, Newport Beach, California, July 1980.
 2. Kennedy, R.P., S.A. Short and R.B. Narver, "Evaluation of FSTF Tests M-12 and M-11B Condensation Oscillation Loads and Responses," SMA 12101.04-R001D, Structural Mechanics Associates, Newport Beach, California, March, 1981.



10

RESPONSE FACTORS APPROPRIATE FOR
USE WITH CO HARMONIC RESPONSE
COMBINATION DESIGN RULES

by

Robert P. Kennedy

AUTHOR Robert P. Kennedy
Robert P. Kennedy
President

APPROVED Thomas R. Kipp
Thomas R. Kipp
Manager, Quality Assurance

Prepared For

GENERAL ELECTRIC COMPANY
NUCLEAR ENERGY DIVISION
San Jose, California

July, 1981





24

Response Combination Goal is Met So Long As:

$$R_c = \sum_{i=1}^3 |R_i| + \sqrt{\sum_{i=4}^N (R_i)^2} \quad (3)$$

where R_i represents the response of the i^{th} response harmonic with R_1 , R_2 , and R_3 being the largest three (3) response harmonics. By this rule the largest 3 response harmonics are combined absolutely and added absolutely to the SRSS combination of the remainder of the response harmonics. This combination is equivalent to assuming that the largest 4 response harmonics are worst-case phased (absolute sum phasing) and the remainder are random phased at the time of peak response. This combination is consistent with the assumption of nearly constant amplitude harmonics with random phasing between harmonics such that the possibility of more than 4 or 5 harmonics achieving nearly worst-case phasing at any one time is highly remote.



24

Conclusions

Recommended Response Combination Procedure Depends Only On:

1. Acceptance of Response Combination Goal of Retaining Conservatism Introduced Elsewhere
2. Adequately Conservative Definition of Loading Such That Item 1 is Accepted
3. Predominately Random Phasing of Individual Harmonic Amplitudes
4. Ratio of Absolute Sum (AS) to SRSS Combined Response Being Similar to Those Obtained for GE LDR Loading (i.e., Less Than About Four)
 - The Number N_1 of Harmonics Which Must be Combined Absolutely Increases As the Ratio AS/SRSS Increases.



24

- BASED UPON THEORETICAL CONSIDERATIONS
N1 INCREASES WITH INCREASE OF
AS/SRSS RATIO



24

SMA 12101.05-R001

DESIGN APPROACH BASED ON FSTF DATA FOR
COMBINING HARMONIC AMPLITUDES FOR
MARK I POST-CHUG RESPONSE CALCULATIONS

by

Robert P. Kennedy
Stephen A. Short
Wen-How Tong

prepared for

GENERAL ELECTRIC COMPANY
San Jose, California


May, 1982



STRUCTURAL
MECHANICS
ASSOCIATES
A Calif. Corp.



24



N1(50%NEP) VS. AS/SRSS PLOT USING CO AND
 CHUG STUDY DATA



27
2


OVERALL SUMMARY

IT IS TECHNICALLY CORRECT TO:

- (1) REDUCE CO LOADS BASED ON RANDOM PHASING BETWEEN DOWNCOMERS AND GEOMETRIC DIFFERENCES BETWEEN NMP1 AND FSTF

AND

- (2) COMBINE STRESSES BY MODIFIED SRSS SUM OF STRESS HARMONICS TO ACCOUNT FOR RANDOMNESS OF HARMONIC PHASING



April 9, 1993

loads. The NRC staff agreed to rereview the NMPC methodology. To perform this review, we request that two reports (NEDO-24010-03, August 1979 and SMA 12101.04-R001D, March 1981) referenced in Enclosure 2 be submitted to the NRC within 30 days.

The NRC staff also requested NMPC to document, within 30 days, the assertion that the Continuum Dynamics, Inc. acoustic model, which implies a unity reduction factor (no reduction) for the case of uncorrelated downcomers within a torus bay with all bays correlated, is correct.

Sincerely,

Original signed by:

Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. List of Attendees
- 2. License Handout Material

cc w/enclosures:

See next page

DISTRIBUTION:(*Licensee's handout only)

Docket File*	NRC & Local PDRs*
PDI-1 Reading*	TMurley/FMiraglia, 12/G/18
JPartlow, 12/G/18	SVarga
JCalvo	RACapra
DBrinkman*	CVogan
OGC	EJordan, MNBB 3701
JKudrick, 8/D/1	TD'Angelo, 8/D/1
JDavis, 7/D/4	MSnodderly, 4/E/4
ACRS (10)	CCowgill, RGN-1*
VMcCree, RGN-1	

OFFICE	PDI-1:LA	PDI-1:PM	PDI-1:D		
NAME	CVogan <i>w</i>	DBrinkman:avl <i>D/S</i>	RACapra <i>Row</i>		
DATE	4/8/93	4/8/93	4/9/93	/ /	/ /

OFFICIAL RECORD COPY
FILENAME: G:\NMPI\NM185003.MTS



Handwritten marks or scribbles in the top right corner.

Small handwritten mark or characters.

Small handwritten mark or characters.

Large, faint handwritten text or scribbles in the bottom right area.