

JUN 28 1985

Docket No. 50-220

Niagara Mohawk Power Corporation  
ATTN: Mr. B. G. Hooten  
Executive Director  
Nuclear Operations  
c/o Miss Catherine R. Seibert  
300 Erie Boulevard West  
Syracuse, New York 13202

Gentlemen:

Subject: Inspection Report No. 50-220/85-01

This refers to your letter dated May 1, 1985, in response to our letter dated April 2, 1985.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

With reference to your response to Unresolved Item 85-01-02 (Adequacy of Fire Protection for Redundant Safe Shutdown Trains in Reactor Building), you are urged to resolve the issue directly with NRR as it is a licensing related matter. After it is resolved with NRR and all your related actions are complete, Region I will close out this item from the Region Outstanding Item File.

With reference to your response to Unresolved Item 85-01-03 (Security Modifications to Fire Doors), we understand that you have instituted appropriate interim compensatory measures (fire watches), for those fire doors identified as having potentially invalid UL labels, in accordance with the Technical Specifications requirements. You are required to continue these measures until the issue is satisfactorily resolved.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:  
Jacque P. Durr

Stewart D. Ebnetter, Director  
Division of Reactor Safety

8507170621 850628  
PDR ADOCK 05000220  
G PDR

OFFICIAL RECORD COPY

RL NMP1 85-01 - 0001.0.0  
06/20/85

11 1E01



cc w/encl:

- T. E. Lempges, Vice President, Nuclear Generation
- T. Perkins, General Superintendent, Nuclear Generation
- D. Palmer, Manager of Quality Assurance
- T. Roman, Station Superintendent
- J. Aldrich, Supervisor, Operations
- W. Drews, Technical Superintendent
- Troy B. Conner, Jr. Esquire
- R. Herman, PM (NMP-1), NRR
- V. Benoroya, CMEB/NRR
- J. Stang, CMEB/NRR
- John W. Keib, Esquire
- Director, Power Division
- Public Document Room (PDR)
- Local Public Document Room (LPDR)
- Nuclear Safety Information Center (NSIC)
- NRC Resident Inspector
- State of New York

bcc w/encl:

- Region I Docket Room (with concurrences)
- DRP Section Chief

*7/17/85  
for*

RI:DRS:  
Pullani/mmb  
6/21/85

RI:DRS  
Anderson  
6/21/85

*clg*

*[Signature]*  
RI:DRS  
Durr  
6/24/85

*[Signature]*  
RI:DRS  
Ebnetter  
*for* 6/26/85

OFFICIAL RECORD COPY

RL NMP1 85-01 - 0002.0.0  
06/20/85



15

