



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

March 18, 1986

Docket No. 50-410

Mr. B. G. Hooten  
Executive Director of Nuclear Operations  
Niagara Mohawk Power Corporation  
300 Erie Boulevard West  
Syracuse, New York 13202

Dear Mr. Hooten:

Subject: Environmental Qualification for Nine Mile Point, Unit 2

In a conference call on January 22, 1986 with Messrs. N. Rademacher and D. Hill of your staff, we requested Niagara Mohawk clarify the qualified status of equipment in the Neutron Monitoring System (Spec. No. 145A5201).

The specified accident temperature is 380°F; however, the stated qualification temperature is 347°F. We request a clarification be provided and a correction made to the environmental qualification submittals (SCEW sheets) by March 31, 1986.

Sincerely,

*Mary F. Haughey*  
Mary F. Haughey, Project Manager  
BWR Project Directorate No. 3  
Division of BWR Licensing

DESIGNATED ORIGINAL

Certified By *[Signature]*

8603250552 860318  
PDR ADOCK 05000410  
A PDR



Mr. B. G. Hooten  
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station  
Unit 2

cc:

Mr. Troy B. Conner, Jr., Esq.  
Conner & Wetterhahn  
Suite 1050  
1747 Pennsylvania Avenue, N.W.  
Washington, D.C. 20006

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Richard Goldsmith  
Syracuse University  
College of Law  
E. I. White Hall Campus  
Syracuse, New York 12223

Mr. Paul D. Eddy  
New York State Public Service  
Commission  
Nine Mile Point Nuclear Station -  
Unit II  
Post Office Box 63  
Lycoming, New York 13093

Ezra I. Bialik  
Assistant Attorney General  
Environmental Protection Bureau  
New York State Department of Law  
2 World Trade Center  
New York, New York 10047

Don Hill  
Niagara Mohawk Power Corporation  
Suite 550  
4520 East West Highway  
Bethesda, Maryland 20814

Resident Inspector  
Nine Mile Point Nuclear Power Station  
P. O. Box 99  
Lycoming, New York 13093

Mr. John W. Keib, Esq.  
Niagara Mohawk Power Corporation  
300 Erie Boulevard West  
Syracuse, New York 13202

Mr. James Linville  
U. S. Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Norman Rademacher,  
Licensing  
Niagara Mohawk Power Corporation  
300 Erie Boulevard West  
Syracuse, New York 13202

