



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

May 28, 1991

Docket No. 50-410

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13211

Dear Mr. Sylvia:

SUBJECT: UTILIZATION OF AN ULTRASONIC FLOW METER ON RHR MINIMUM FLOW LINES
AT NINE MILE POINT NUCLEAR STATION UNIT NO. 2 (TAC NO. 79383)

Niagara Mohawk Power Corporation (NMPC) submitted a response to NRC staff questions concerning the Nine Mile Point Unit 2 inservice testing program for pumps and valves on September 30, 1988. One of the questions (6b) raised a concern that testing to verify flow in the check valves in the residual heat removal (RHR) minimum flow lines would not be conclusive. The NRC staff's concern was that the instrumentation may not be able to detect adequate flow within the accuracy of the pump differential pressure gauge because the readings are on the flatter portion of the pump characteristic curve. NMPC responded to this concern stating that modifications to the RHR minimum flow line would be required to verify the minimum flow rate.

In a letter submitted January 3, 1991, NMPC stated it had decided to use a calibrated clamp-on ultrasonic flowmeter to verify flow in the minimum flow lines. NMPC stated that it had been using the flowmeter in surveillance testing and had obtained satisfactory results. NMPC also stated that the modifications to install flow elements in the RHR system are no longer necessary.

NRC staff members held discussions with members of your staff on May 21, 1991, regarding the selection, installation, and calibration of the ultrasonic flow meters. The vendor for these meters supplies application and installation guidelines and certificates of calibration based on those guidelines. Based on these discussions, we have concluded that the use of ultrasonic flowmeters

NRC FILE CENTER COPY

9106060173 910528
PDR ADOCK 05000410
P PDR

M/A-4
ck

DF01
110



Mr. B. Ralph Sylvia

- 2 -

May 28, 1991

in this application will be suitably accurate for full-flow exercising of the RHR minimum flow line check valves. Therefore, the NRC staff concerns on this subject have been resolved.


This completes our efforts on TAC No. 79383.

Sincerely,

Donald S. Brinkman

Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page



Mr. B. Ralph Sylvia
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit 2

cc:

Mr. Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW.
Washington, D.C. 20005-3502

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, New York 12223

Charlie Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Resident Inspector
Nine Mile Point Nuclear Power Station
P. O. Box 126
Lycoming, New York 13093

Mr. Richard M. Kessel
Chair and Executive Director
State Consumer Protection Board
99 Washington Avenue
Albany, New York 12210

Mr. Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Mr. Martin J. McCormick Jr.
Plant Manager, Unit 2
Nine Mile Point Nuclear Station
Niagara Mohawk Power Corporation
P. O. Box 32
Lycoming, NY 13093

Mr. David K. Greene
Manager Licensing
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Mr. Joseph F. Firlit
Vice President - Nuclear Generation
Nine Mile Point Nuclear Station
Niagara Mohawk Corporation
P. O. Box 32
Lycoming, New York 13093

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

Supervisor
Town of Scriba
R. D. #4
Oswego, New York 13126



Small, illegible marks or characters in the top right corner.

Mr. B. Ralph Sylvia

- 2 -

May 28, 1991

in this application will be suitably accurate for full-flow exercising of the RHR minimum flow line check valves. Therefore, the NRC staff concerns on this subject have been resolved.

This completes our efforts on TAC No. 79383.

Sincerely,

Original signed by:

Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File
PDI-1 Reading
NRC/Local PDRs
SVarga
JCalvo
CVogan
RACapra
DBrinkman
OGC
EJordan
ACRS(10)
Plant File
HColaccino
JNorberg
CCowgill

PDI-1:LA
CVogan *CV*
5/24/91

PDI-1PM *DB*
DBrinkman:psc
5/24/91

RAC
PDI-1:D
RACapra
5/28/91

DOCUMENT NAME: NMP 2 LTR TO SYLVIA 79383



100-100000-100000

THE UNITED STATES OF AMERICA
DEPARTMENT OF JUSTICE
FEDERAL BUREAU OF INVESTIGATION

WASHINGTON, D. C. 20535

MEMORANDUM FOR THE DIRECTOR
FROM THE SAC, NEW YORK
SUBJECT: [Illegible]

[Illegible text, possibly a list or report details]

[Illegible text, possibly a signature or date]

[Illegible text, possibly a footer or reference]