



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220


NINE MILE POINT NUCLEAR STATION UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 124
License No. DPR-63

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated March 13, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

9106120370 910606
PDR ADOCK 05000220
PDR



(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 124, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.


FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 6, 1991



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 124 TO FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220


Revise Appendix A as follows:

Remove Pages

251
270

Insert Pages

251
270



6.3 Facility Staff Qualifications

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for the Manager Radiation Protection who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975 and the Shift Technical Advisor who shall have a bachelor's degree in a physical science or engineering or a professional engineer license issued by examination and shall have received specific training in plant design, and response and analysis of the plant for transients and accidents.

6.4 Training

6.4.1 A retraining and replacement training program for the facility staff shall be maintained under the direction of the Manager Training and shall meet or exceed the recommendations and requirements of Section 5.5 of ANSI N18.1-1971 and Appendix "A" of 10CFR Part 55.

6.4.2 A training program for the Fire Brigade shall be maintained under the direction of the Manager Training and Supervisor-Fire Protection, Nuclear and shall meet or exceed the requirements of Appendix R to 10CFR50.

6.5 Review and Audit

6.5.1 Station Operations Review Committee (SORC)


Function

6.5.1.1 The Station Operations Review Committee shall function to advise the Plant Manager on all matters related to nuclear safety.

Composition

6.5.1.2 The SORC shall be composed of the:

Chairman: Plant Manager
Member: Manager Operations
Member: Manager Maintenance
Member: Manager Technical Support
Member: Manager Chemistry
Member: Manager Radiation Protection
Member: General Supervisor Instrument and Control Maintenance
Member: General Supervisor System Engineering
Member: General Supervisor Operations
Member: Supervisor Reactor Engineering



6.12 High Radiation Area (Continued)


- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rates in the area have been established and personnel have been made knowledgeable of them.
- c. An individual qualified in radiation protection, with a radiation dose rate monitoring device, who is responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the Manager Radiation Protection or designate in the Radiation Work Permit.

6.12.2 In addition to the requirements of 6.12.1 areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose greater than 1000 mrem** shall be provided with locked doors*** to prevent unauthorized entry, and the hard keys or access provided by magnetic keycard shall be maintained under the administrative control of the Station Shift Supervisor or designate on duty and/or the Manager Radiation Protection or designate. Doors shall remain locked except during periods of access by personnel under an approved RWP which shall specify in accordance with site approved procedures accordingly, the dose rate levels in the immediate work area and the maximum allowable stay time for individuals in that area. In lieu of the stay time specification of the RWP, continuous surveillance, direct or remote, such as use of closed circuit TV cameras, may be made by personnel qualified in radiation protection procedures to provide positive exposure control over the activities within the area. For individual areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose in excess of 1000 mrem** that are located within large areas, such as the drywell, where no enclosure exists for purposes of locking, and no enclosure can be reasonably constructed around the individual areas, then that area shall be roped off, conspicuously posted and a flashing light shall be activated as a warning device.

* by accessible passage and permanently fixed ladders

** measurement made at 18" from source of radioactivity

*** The requirement for locked doors to prevent unauthorized entry does not apply to areas which may temporarily exceed 1000 mrem/hr during the hydrogen water chemistry tests to be conducted during approximately a six-week period following startup from the spring 1986 refueling outage.





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

NIAGARA MOHAWK POWER CORPORATION


DOCKET NO. 50-410

NINE MILE POINT NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 32
License No. NPF-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated March 13, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-69 is hereby amended to read as follows:




(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. 32 are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.


FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 6, 1991



ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 32 TO FACILITY OPERATING LICENSE NO. NPF-69

DOCKET NO. 50-410


Revise Appendix A as follows:

Remove Pages

6-8
6-25

Insert Pages

6-8
6-25



ADMINISTRATIVE CONTROLS

6.5 REVIEW AND AUDIT

6.5.1 STATION OPERATIONS REVIEW COMMITTEE

FUNCTION

6.5.1.1 The Station Operations Review Committee (SORC) shall function to advise the Plant Manager on all matters related to nuclear safety.

COMPOSITION

6.5.1.2 The SORC shall be composed of the

Chairman:	Plant Manager
Member:	Manager Operations
Member:	Manager Maintenance
Member:	Manager Technical Support
Member:	Manager Chemistry
Member:	Manager Radiation Protection
Member:	General Supervisor Instrument and Control Maintenance
Member:	General Supervisor System Engineering
Member:	General Supervisor Operations
Member:	Supervisor Reactor Engineering

ALTERNATES

6.5.1.3 All alternate members shall be appointed in writing by the SORC Chairman to serve on a temporary basis; however, no more than two alternates shall participate as voting members in SORC activities at any one time.

MEETING FREQUENCY

6.5.1.4 The SORC shall meet at least once every calendar month and as convened by the SORC Chairman or a designated alternate.


QUORUM

6.5.1.5 The quorum of the SORC necessary for the performance of the SORC responsibility and authority provisions of these Technical Specifications shall consist of the Chairman or a designated alternate and five members including alternates.

RESPONSIBILITIES

6.5.1.6 The SORC shall be responsible for:

- a. Investigation of all violations of the Technical Specifications, including the preparation and forwarding of reports covering evaluation and recommendations to prevent recurrence, to the Vice President - Nuclear Generation and to the Safety Review and Audit Board;



ADMINISTRATIVE CONTROLS

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by 10 CFR 20.203 (c) (2), each high radiation area in which the intensity of radiation is greater than 100 mrem/hr* but less than 1000 mrem/hr* shall be barricaded and conspicuously posted as a high radiation area, and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit (RWP)**. Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate levels in the area have been established and personnel have been made knowledgeable of them
- c. An individual qualified in radiation protection (i.e., qualified in radiation protection procedures) with a radiation dose rate monitoring device who is responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the Manager Radiation Protection or the Manager Radiation Protection designee in the RWP.

6.12.2 In addition to the requirements of Specification 6.12.1, areas accessible to personnel with radiation levels such that a major portion of the body could receive in 1 hour a dose greater than 1000 mrem* shall be provided with locked doors to prevent unauthorized entry, and the keyed access shall be maintained under the administrative control of the Station Shift Supervisor or the designee on duty and/or the Manager Radiation Protection or designee. Doors shall remain locked except during periods of access by personnel under an approved RWP which shall specify the dose rate levels in the immediate work area and the maximum allowable stay time for individuals in that area. For individual areas accessible to personnel with such radiation levels that a major portion of the body could receive in 1 hour a dose in excess of 1000 mrem* that are located within large areas, such as the drywell, where no enclosure exists that can be locked, and no enclosure can be reasonably constructed around the individual areas, then that area shall be roped off,

*Measurements made at 18 inches from the source of radioactivity.

**Health Physics personnel or personnel escorted by health physics personnel shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection duties, provided they are otherwise following plant radiation protection procedures for entry into high radiation areas.

