

# FORD 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9109030004      DOC. DATE: 91/08/26      NOTARIZED: NO      DOCKET #  
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe      05000220  
 AUTH. NAME      AUTHOR AFFILIATION  
 TERRY, C.D.      Niagara Mohawk Power Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Forwards written confirmation of licensee response to  
           specific discussion items re implementation of Reg Guide  
           1.97 at facility.

DISTRIBUTION CODE: A002D      COPIES RECEIVED: LTR 1 ENCL 0      SIZE: 4  
 TITLE: OR Submittal: Inadequate Core Cooling (Item II.F.2)      GL 82-28

NOTES:

RECIPIENT ID CODE/NAME	COPIES	LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTTR	ENCL
PD1-1 LA	1		1	PD1-1 PD	1		1
BRINKMAN, D	2		2				
INTERNAL: ACRS	6		6	NRR KARSCH, R	1		1
NRR SCHWENK, G	1		1	OC/LFMB	1		0
<u>REG FILE</u> 01	1		1	RES DE	1		1
RES/DSIR/EIB	1		1	RES/DSIR/RPSB	1		1
EXTERNAL: NRC PDR	1		1	NSIC	1		1

TOTAL NUMBER OF COPIES REQUIRED: LTTR      19      ENCL      18

R  
I  
D  
S  
/  
F  
O  
R  
D  
1  
D  
O  
C  
U  
M  
E  
N  
T

MAY

22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31  
 32  
 33  
 34  
 35  
 36  
 37  
 38  
 39  
 40  
 41  
 42  
 43  
 44  
 45  
 46  
 47  
 48  
 49  
 50  
 51  
 52  
 53  
 54  
 55  
 56  
 57  
 58  
 59  
 60  
 61  
 62  
 63  
 64  
 65  
 66  
 67  
 68  
 69  
 70  
 71  
 72  
 73  
 74  
 75  
 76  
 77  
 78  
 79  
 80  
 81  
 82  
 83  
 84  
 85  
 86  
 87  
 88  
 89  
 90  
 91  
 92  
 93  
 94  
 95  
 96  
 97  
 98  
 99  
 100  
 101  
 102  
 103  
 104  
 105  
 106  
 107  
 108  
 109  
 110  
 111  
 112  
 113  
 114  
 115  
 116  
 117  
 118  
 119  
 120  
 121  
 122  
 123  
 124  
 125  
 126  
 127  
 128  
 129  
 130  
 131  
 132  
 133  
 134  
 135  
 136  
 137  
 138  
 139  
 140  
 141  
 142  
 143  
 144  
 145  
 146  
 147  
 148  
 149  
 150  
 151  
 152  
 153  
 154  
 155  
 156  
 157  
 158  
 159  
 160  
 161  
 162  
 163  
 164  
 165  
 166  
 167  
 168  
 169  
 170  
 171  
 172  
 173  
 174  
 175  
 176  
 177  
 178  
 179  
 180  
 181  
 182  
 183  
 184  
 185  
 186  
 187  
 188  
 189  
 190  
 191  
 192  
 193  
 194  
 195  
 196  
 197  
 198  
 199  
 200  
 201  
 202  
 203  
 204  
 205  
 206  
 207  
 208  
 209  
 210  
 211  
 212  
 213  
 214  
 215  
 216  
 217  
 218  
 219  
 220  
 221  
 222  
 223  
 224  
 225  
 226  
 227  
 228  
 229  
 230  
 231  
 232  
 233  
 234  
 235  
 236  
 237  
 238  
 239  
 240  
 241  
 242  
 243  
 244  
 245  
 246  
 247  
 248  
 249  
 250  
 251  
 252  
 253  
 254  
 255  
 256  
 257  
 258  
 259  
 260  
 261  
 262  
 263  
 264  
 265  
 266  
 267  
 268  
 269  
 270  
 271  
 272  
 273  
 274  
 275  
 276  
 277  
 278  
 279  
 280  
 281  
 282  
 283  
 284  
 285  
 286  
 287  
 288  
 289  
 290  
 291  
 292  
 293  
 294  
 295  
 296  
 297  
 298  
 299  
 300  
 301  
 302  
 303  
 304  
 305  
 306  
 307  
 308  
 309  
 310  
 311  
 312  
 313  
 314  
 315  
 316  
 317  
 318  
 319  
 320  
 321  
 322  
 323  
 324  
 325  
 326  
 327  
 328  
 329  
 330  
 331  
 332  
 333  
 334  
 335  
 336  
 337  
 338  
 339  
 340  
 341  
 342  
 343  
 344  
 345  
 346  
 347  
 348  
 349  
 350  
 351  
 352  
 353  
 354  
 355  
 356  
 357  
 358  
 359  
 360  
 361  
 362  
 363  
 364  
 365  
 366  
 367  
 368  
 369  
 370  
 371  
 372  
 373  
 374  
 375  
 376  
 377  
 378  
 379  
 380  
 381  
 382  
 383  
 384  
 385  
 386  
 387  
 388  
 389  
 390  
 391  
 392  
 393  
 394  
 395  
 396  
 397  
 398  
 399  
 400  
 401  
 402  
 403  
 404  
 405  
 406  
 407  
 408  
 409  
 410  
 411  
 412  
 413  
 414  
 415  
 416  
 417  
 418  
 419  
 420  
 421  
 422  
 423  
 424  
 425  
 426  
 427  
 428  
 429  
 430  
 431  
 432  
 433  
 434  
 435  
 436  
 437  
 438  
 439  
 440  
 441  
 442  
 443  
 444  
 445  
 446  
 447  
 448  
 449  
 450  
 451  
 452  
 453  
 454  
 455  
 456  
 457  
 458  
 459  
 460  
 461  
 462  
 463  
 464  
 465  
 466  
 467  
 468  
 469  
 470  
 471  
 472  
 473  
 474  
 475  
 476  
 477  
 478  
 479  
 480  
 481  
 482  
 483  
 484  
 485  
 486  
 487  
 488  
 489  
 490  
 491  
 492  
 493  
 494  
 495  
 496  
 497  
 498  
 499  
 500  
 501  
 502  
 503  
 504  
 505  
 506  
 507  
 508  
 509  
 510  
 511  
 512  
 513  
 514  
 515  
 516  
 517  
 518  
 519  
 520  
 521  
 522  
 523  
 524  
 525  
 526  
 527  
 528  
 529  
 530  
 531  
 532  
 533  
 534  
 535  
 536  
 537  
 538  
 539  
 540  
 541  
 542  
 5

August 26, 1991  
NMP1L 0601

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

Gentlemen:

SUBJECT: Documentation of questions and responses in regards to  
the July 30, 1991 Telephone Conference on Regulatory  
Guide 1.97

The attached provides written confirmation of Niagara Mohawk's  
response to specific discussion items regarding the  
implementation of Regulatory Guide 1.97 at Nine Mile Point  
Unit 1. This information was orally provided to the NRC Senior  
Project Manager, Mr. D. S. Brinkman during a July 30, 1991  
telephone conference.

Very truly yours,



C.D. Terry  
Vice President  
Nuclear Engineering

NAS:drc  
000713SS  
Enclosure

xc: Regional Administrator, Region I  
Mr. R. A. Capra, Project Director, NRR  
Mr. D. S. Brinkman, Senior Project Manager, NRR  
Mr. W. L. Schmidt, Senior Resident Inspector  
Mr. D. R. Haverkamp, Chief, Reactor Projects Section No. 1B  
Records Management

9109030004 910826  
PDR DOCK 05000220  
P PDR

4002 1/0



Question 1:

Primary Containment Isolation Valve Position

- a. Primary containment isolation valve position indication components:

40-30-1LSC	40-30-1LSO
41-31-1LSC	41-31-1LSO
40-02-01LSC	40-02-01LSO

are not environmentally qualified. Since they are located inside the containment they may be subjected to a potentially harsh environment. Therefore, these components should be environmentally qualified under the licensee's 10 CFR 50.49 program.

- b. Primary containment isolation valve position indication components:

44.2-15-1LSC	44.2-15-1LSO	44.2-15A
44.2-16-1LSC	44.2-16-1LSO	44.2-16A
44.2-17-1LSC	44.2-17-1LSO	44.2-17A
44.2-18-1LSC	44.2-18-1LSO	44.2-18A
40-02-01LSC	40-02-1LSO	40-02B
40-12-01LSC	40-12-1LSO	40-12B

are not powered from Class 1E power sources. The licensee has not provided a specific justification for not supplying Class 1E power to the above components. The licensee should provide Class 1E power for these components.

Response 1:

- a. Environmental qualification of the listed primary containment isolation valve (PCIV) components is not required for the reasons stated below. Detailed evaluation information for each of these PCIVs is maintained in the Equipment Qualification Program files.

<u>PCIV Components</u>	<u>Reason for Not Being EQ Program Equipment</u>
40-30-1LSC 40-30-1LSO 40-31-1LSC 40-31-1LSO	Administrative controls are implemented whereby the downstream manual valve in each line is Locked Closed except for the performance of required testing. Therefore, this downstream manual isolation accomplishes the required isolation except during valve testing time which is limited to once per month for approximately one (1) minute.



10-1-74

40-02-1LSC  
40-02-1LSO  
40-12-1LSC  
40-12-1LSO

Administrative controls are implemented whereby the breaker for each of the listed valves is racked out except for the performance of required testing. Thus, these normally open valves will remain in their required open state during accident conditions. The only exception to this condition is during quarterly testing for approximately one (1) hour during which time an Reactor Protection System signal will be provided in the unlikely event an accident occurs.

- b. Although the open/closed position indication located immediately adjacent to the respective control switch for the following primary containment isolation valves (PCIVs) is not powered from a Class 1E power source, redundant position indication for each of these valves is separately provided on the control room PCIV mimic display and the power supply to the PCIV mimic is from a Class 1E power source. For this reason, the position indication located immediately adjacent to the respective control switch is not required to be backfitted with a Class 1E power source. Applicable valves are as follows:

<u>Valve Component Number</u>	<u>Valve "Closed" Position Contact</u>	<u>Valve "Open" Position Contact</u>
44.2-15A	44.2-15-1LSC	44.2-15-1LSO
44.2-16A	44.2-16-1LSC	44.2-16-1LSO
44.2-17A	44.2-17-1LSC	44.2-17-1LSO
44.2-18A	44.2-18-1LSC	44.2-18-1LSO
40-02B	40-02-1LSC	40-02-1LSO
40-12B	40-12-1LSC	40-12-1LSO

Question 2:

Drywell Atmosphere Temperature

The licensee lists drywell atmosphere temperature as an EOP key parameter. Therefore, drywell atmosphere temperature should meet the Category 1 criteria. The licensee's current instrumentation does not meet the redundancy or recording criteria. The licensee has committed to provide the recommended additional Category 1 channel. The licensee also states that they will isolate the computer from this instrument. However, it is not clear that this variable will be recorded by the computer. The licensee should provide confirmation that at least 1 channel of drywell temperature information is recorded.

Response 2:

The capability of recording one channel of average drywell temperature will be provided as part of the installation of the





new separate and independent Category 1 channel of drywell temperature monitoring instrumentation. The recording function for average drywell temperature will be provided by a dedicated strip chart recorder which is to be located on Control Room Panel L.

Question 3:

High Pressure Coolant Injection System Flow

R.G. 1.97 recommends Category 2 instrumentation to monitor high pressure coolant injection (HPCI) system flow. The licensee states that the main feedwater pumps perform the HPCI function. The licensee's main feedwater flow instrumentation does not meet the environmental qualification criteria for Category 2 instrumentation. Therefore, since the main feedwater pumps perform the HPCI function, the main feedwater flow instrumentation should meet the Category 2 criteria.

Response 3:

FT 29-53 and FT 29-54 (Feedwater/HPCI flow transmitters) are not Environmental Qualification Program Equipment because these flow transmitters are physically located on turbine building floor elevation 293' (column/row H-9 and H-10, respectively), which has been determined to be a "mild environment" for accidents this equipment is required to mitigate. Documentation is maintained in the Equipment Qualification Program files to support these analyses.

Question 4:

Standby Liquid Control System

The licensee's standby liquid control system storage tank level instrumentation has a range of 350 gallons to 4150 gallons. Based upon the information provided, this is an acceptable deviation. However, the licensee has stated that they are planning to modify this range, the licensee has not provided any justification for the proposed modification. The licensee should justify the proposed modification.

Response 4:

The new level monitoring instrumentation to be installed for the Standby Liquid Control System storage tank liquid level will provide display of indicated level over a range extending from 0 gallons (the bottom of the tank) to approximately 2000 gallons. Because a high boron concentration solution is now used, the expected range of operation for this tank is 0 to 1500 gallons and the Technical Specification for minimum storage tank level is 1185 gallons. The new monitoring instrumentation for tank liquid level bounds this range while providing the operator with better resolution, greater accuracy, and higher reliability.

