

SECRET

SECRET

SECRET

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET


▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>2</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44-8	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

TABLE OF CONTENTS


<u>Subject</u>	<u>Page no.</u>
Table of Contents	2
Objective	4
Assumptions	4
Sources	7
Conclusions	9
Reasons for Revision	10
Loads Connected to battery	11
Determination of the Battery Duty Cycle	19
Explanation of battery Sizing form	23
Voltage Profile determination	30
Battery Charger Calculation	33
Attachments :	
EBOP name plate data	35
General Electric letter dated 8/28/87	36
IOC from G. Fligg to J. Knudsen, 2/26/81	37
Panel Schedule , 2BYS-PNLA101	38
Panel Schedule , 2BYS-PNLA102	39
Panel Schedule , 2BYS-PNLA107	40
Gould , all type NCX Capacity Table	41



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>3</u>
J.O. OR W.O. NO. 2177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	
1				
2				
3	Gould curve no. TC-107011B			42
4				
5	Relay load charts			43
6				
7	IOM dated 5/10/82			48
8				
9	IOC from J. Sternchos to J. Knudsen, 6/13/85			54
10				
11	IOC from J. Knudsen to J. Sternchos; 6/11/85			55
12				
13	IOC from J. Sternchos to A.K. Gwal, 6/25/85			56
14				
15	General Electric letter dated 6/19/85			57
16				
17	Table of circuit breakers tripping on bus			60
18	undervoltage - with references			△ 9
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET



▲ 5010.65


CALCULATION IDENTIFICATION NUMBER				PAGE <u>4</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1. Objective

EC-44 checks the Ampere-Hour capacity of Battery 2BYS-BA71A (1A1, 1A2, 1A3, 1A4) in order to verify the adequacy of the batteries already purchased, and the adequacy of the purchased Battery charger 2BYS-CHG1A1.

2. Assumptions

- a. The UPS loads used in this calculation are based on  calculation EC-123 Rev. 2, instead of the rated capacity of the UPS.
- b. No factors for inaccuracies and growth are used.
- c. Battery is sized to support the necessary loads for an orderly shutdown, following simultaneous LOOP and  unit trip.
- d. Battery is sized for a two hour support time.
- e. The lowest expected electrolyte temperature is the lowest room temperature in which the battery will be installed ie. 65°F
- f. The method employed is the sizing procedure outlined in IEEE-485, 1978.
- g. UPS Inverters are not a charger load.



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>5</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

h. The essential lighting load of UPS 2VBB-UPSIC is assumed to occur for 90 minutes to satisfy the requirements of NEC article 700.

i. Only 20 Amperes out of 68.90 Amperes of auxiliary relay and indicating light loads on "CEC" panels (pages 43 through 47) are considered in the battery duty cycle since all the loads will not be energized simultaneously. This is considered a random load that may appear at any time during the duty cycle. The load is considered to occur for one full minute, to be conservative.


j. The circuit breakers assumed to be tripping are shown on pages 60 & 61. The tripping load is based on the 13.8kW, 4.16 kV and 600V undervoltage timers, all set at 3.0 seconds in accordance with applicable ER drawings.

Since each switchgear and loadcenter DC bus could be connected to either battery (2BYS-BAT1A or 2BYS-BAT1B), for the purpose of this calculation it is assumed that the entire breaker trip load is supplied by 2BYS-BAT1A.

k. EBOP is assumed to operate for 45 minutes per source w. (page 59)

9

9




STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>6</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
12177	ELECTRICAL	EC-44	N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

- l. One high voltage disconnect switch is assumed to $\triangle 9$ operate. Only the inrush current is assumed for one full minute which is conservative. This is considered as a random load.
- m. The load required to close one 13.8KV and one 4.16KV \triangle circuit breakers simultaneously has been assumed as the worst case closing load. This is considered to be a random load that may occur at any time during the duty cycle. The breaker closing load has been assumed for one full minute, to be conservative.
- n. The EBOP and the diesel generator fuel oil booster $\triangle 9$ pump are not considered as charge continuous load, because it is assumed they will have performed their intended function before AC power is restored (120 minutes).



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>7</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE NA	

3. Sources


- a. Purchase Specification NMP2-E033A, Addendum 2, dated November 2, 1982
- b. Technical Data by the Seller, Gould Inc., dated March 17 1977 (Received 5/27/83).
- c. IEEE recommended practice for sizing Large Storage Batteries for Generating Stations and Substations. IEEE-485, 1978
- d. ETP-110.0.1, Verification of Lead Storage Battery Size (REV. 0)
- e. Purchase Specification NMP2-E035A, Uninterruptable Power Supplies dated 6/29/81 (Add. 4); Instruction manuals, EXIDE and ELGAR.
- f. Drawings: 12177-EE-1 -5, 12177-EE-M019-1, 12177-EE-M01D-1
- g. IDC, G. Fligg to J. Knudsen dated 2/26/81, attached.
- h. Purchase specification NMP2-E034A, Addendum 5. November 3, 1982, Static Battery Chargers.
- i. Gould-Brown Boveri Bulletin 10.2-1E
- j. SWEC ESK-11TML01-9
- k. BROWN BOVERI Bulletin 2.3.1.1b
- l. SWEC ESK-6WCS01-10

△

△ 9

△ 9

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>8</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

- m. ELGAR Instruction Manual UPS 103-1-176, REV B
(SWEC NO 01.560-5003) (SUPERSEDED BY NMPC DOC NO N2E20900IPWSUP002
UPS - 253-1-106, REV. 00 (NMPC DOC. NO. N2E20900IPWSUP001)
- n. EXIDE Instruction Manual 101-710-343-77223 (UPS),
REV. 00 (NMPC DOC. NO N2E35600IPWSUP001)
- o. General Electric Bulletin GET-6590, Page 8-7, 8-10
- p. General Electric 4.16KV (GEK 419020) Switchgear
Instruction manual.
- q. General Electric Starter drawing 1.080-002-020A
- r. General Electric EBOP motor diagram 1.080-002-013A
- s. General Electric motor Data Sheet (EBOP) 1.080-002-006E
- t. Telecon data from nameplate of EBOP received from
the field, page 35 this calculation.
- u. Relay charts, pages 43 through 47, this calculation.
- v. Letter, G.E. P. Patel to C. Zappile of SWEC dated 8/28/84.
- w. IOC, from J. Sternchos to J. Knudsen dated 6/25/85.
- x. Calculation EC-123 REV. 2
- y. SWEC IOM dated 5/10/82, attached.
- z. ESK's :


6AAS01-9	6GMCO2-10	6HVR03-10
6AGM03-4	6HVH01-6	6HVR04-10
6ABM04-3	6HVH02-6	6HVR05-10
6ARCO1-16	6HVH04-5	6HVR06-8
6ARCO2-16	6HVN01-5	6HVR07-9
6CNS04-6	6HVN02-5	6HVR08-9
6CNS05-6	6HVN03-5	6HVR09-10
6GMCO1-10	6HVN04-5	6HVT01-8

△

△

△ 9


△ 9



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ S010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>8A</u> 9
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
12177	ELECTRICAL	EC-44	NA	
1				
2				
3	6HVT02-8	6HVW08-5	6SWP31-5	
4	6HVT03-9	6IAS01-9	6SWT01-5	
5	6HVT04-8	6IAS02-9	6SWT02-5	
6	6HVT05-8	6IAS03-9	6TMB01-10	
7	6HVT06-9	6LWS06-7	6TMB02-10	
8	6HVW05-5	6LWS07-7	6WCS01-10	
9	6HVW06-5	6LWS13-2	6WCS02-9	
10	6HVW07-5	6LWS14-2		
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33	---			
34	--			
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>9</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
12177	ELECTRICAL	EC-44	N/A	


4 Conclusions

The battery size, (2) 60, 35 plate cells, as recommended by Gould Inc. in proposal "Technical Data by Seller", Section 3 of Purchase Specification NMP2-E033A, Addendum 1, dated 3/2/78, is acceptable.*

The 500 Ampere Battery Charger as supplied by Power Conversion Products in "Technical Data by Seller", Section 3 of Purchase Specification NMP2-E034A, Addendum 2, dated 1/4/79, is acceptable.

* This is based on ① 2VBB-UPS1A loading of 65.52 KVA @ .8 PF. instead of 75 KVA ② 2VBB-UPS1C loading of 63 KVA @ .9 PF. instead of 75 KVA. per EC-123, Rev. 2

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>10</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

5. Reason for Revision

5a. Revision no. 5

All assumptions and input data are complete. Any future changes will be incorporated by revising this calculation.

5b. Revision no. 6

Final Emergency Bearing Oil Pump data received in source v. ; General Electric letter, page 36 of this calculation is incorporated in EC-100. Also in depth review of logic changed Switchgear D.C. loads.

5c. Revision no. 7

Revision no. 7 was done to correct EBOP and switchgear loads.


5d. Revision no. 8

Revision no. 8 was done to improve legibility and to correct inaccuracies and typographical errors throughout the calculation. The inputs and conclusions of this calculation remain unchanged.

5e. Revision no. 9


Revision no. 9 was done to revise 2BYS-PNLA101, A102 and A107 loads. Also, the breaker trip load for LOOP with





STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>10A</u> 
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
12177	ELECTRICAL	EC-44	N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

Unit trip scenario was incorporated. This scenario represents the worst possible case.

Revised pages : 1,3-8,10,16-18,20,21,23-31,33,34

New pages : 8A,10A,60,61


Replaced pages : 22,38-40

Redrawn pages : 32

5f. REVISION no. 10

REVISION NO. 10 WAS DONE TO ADD APPLICABLE REV./ DATE TO SOURCES D, M & N

PAGES REVISED : 7, 8, 10A



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>11</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

6. Loads Connected to the Battery

Loads Connected to the Battery are shown on Table 1, pages 16 & 17. These loads were determined as follows:

a. Circuit Breaker Operation

15KV, 5KV manufactured by General Electric Co. :

CLOSE OPERATION

1. circuit breaker control switch to close position.
2. close release coil (6 Amperes) is energized, releasing closing spring. (Opening spring is charged simultaneously).
3. closing spring is then charged (14 Amperes) while close circuit is interlocked open.


TRIP OPERATION

1. circuit breaker control switch to trip position or protective relay contact closes.
2. trip coil (6 Amperes) is energized, releasing opening spring.
(See NMP2-E015F instruction manual, GE bulletin GEK-419026)

b. 600V Electrically Operated breakers manufactured by I.T.E.:

CLOSE OPERATION.

1. circuit breaker control switch to close position.



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>12</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46


2. close release coil is energized, releasing closing spring.
both CLOSE and TRIP springs are charged simultaneously
(10 Amperes).

TRIP OPERATION


1. circuit breaker control switch to trip position or protective relay contact closes.
2. trip coil is energized (1.3 Amperes) releasing opening spring.

See ESK-6WLS07 (typical)

C. Emergency Bearing Lube Oil Pump (EBOP)



Where , $R_s =$ Series field resistance $= 0.0007 \Omega$
 $R_c =$ Commutating Pole resistance $= 0.0036 \Omega$ (source v.)
 $R_b =$ Brush resistance $= 0.0098 \Omega$
 $R_{sf} =$ Shunt field resistance $= 40.0 \Omega$ (source t.)



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>13</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EL-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

$$R_3 = 0.05 \Omega$$

$$R_2 = 0.105 \Omega$$

$$R_a = \text{Armature Resistance} = 0.0126 \Omega \text{ (Source v.)}$$

$$T_C = \text{Time to Close; Open at start (source j)}$$

$$I_{SF} = 2.25 \text{ Amperes (source t.)}$$


The value of R_b was calculated based on a brush voltage drop of 2 volts (source v.) and armature current of 205 Amperes (source t.); $2V/205 A \approx 0.0098 \Omega$.

EBOP starting current can be found as follows:

$$I_{START} = \frac{\text{VOLTS}}{R_s + R_c + R_b + R_a + R_3 + R_2} + I_{SF}$$

$$I_{START} = \frac{123.8V}{0.1817 \Omega} + 2.25 = 683.59 \text{ Amperes}$$

where VOLTS is the battery open circuit voltage.



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>14</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EL-44	OPTIONAL TASK CODE N/A	

d. UPS Input kW

2VBB-UPS1A : load is 72,820 VA from source x.

load power factor = 0.8

Diversity Utilization factor = 0.9, from source y.

Efficiency when supplied by the battery = 0.84, from source n.

$$\text{Input kW} = \frac{72,800 \times 0.8 \times 0.9}{0.84} = 62.4$$

based on the above kW load, the load current is calculated at various times of the battery duty cycle taking into consideration that the battery voltage is gradually decreasing

$$I_{0\text{time}} = \frac{62400 \text{ W}}{123.8 \text{ V}} = 504 \text{ Amperes}; 123.8 \text{ V} = \text{Battery Open Circuit Volts}$$


$$I_{120\text{ minutes}} = \frac{62,400 \text{ W}}{101 \text{ V}} = 618 \text{ Amperes}; 101 \text{ V} = \text{Minimum Volts at load}$$

$$I_{120\text{ minutes}} - I_{0\text{time}} = 618 - 504 = 114 \text{ Amperes}$$

$$I_{90\text{ minutes}} = \frac{90}{120} \times 114 + 504 = 590 \text{ Amperes} *$$

$$I_{45\text{ minutes}} = \frac{504 + 590}{2} = 547 \text{ Amperes} *$$

* Assuming linear discharge characteristics and constant UPS load, for ease of calculation.



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>15</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EL-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

2VBB-UPSIC : load is 70,000 VA from source x.

load power factor = 0.9 , from Lighting Specialist

Diversity Utilization factor = 0.9 , from source y.

Efficiency when supplied by the battery = 0.84 , from source n.

$$\text{Input KW} = \frac{70,000 \times 0.9 \times 0.9}{0.84} = 67,500 \text{ KW}$$

$$I_{\text{otime}} = \frac{67,500 \text{ KW}}{123.8 \text{ V}} = 545 \text{ Amperes}$$

$$I_{120 \text{ minutes}} = \frac{67,500 \text{ KW}}{101 \text{ V}} = 668 \text{ Amperes}$$

$$I_{120 \text{ minutes}} - I_{\text{otime}} = 668 - 545 = 123 \text{ Amperes}$$

$$I_{90 \text{ minutes}} = \frac{90}{120} \times 123 + 545 = 637 \text{ Amperes}^*$$

$$I_{45 \text{ minutes}} = \frac{637 + 545}{2} = 591 \text{ Amperes}^*$$

I_{120 minutes} was calculated above only to determine I_{45 minutes} and I_{90 minutes}.

D. Miscellaneous loads

Miscellaneous loads are depicted in Table 1 along with the loads already discussed in this section.

* Assuming linear discharge characteristics and constant UPS load, for ease of calculation.





TABLE 1 : CONNECTED LOADS continued on page 17

DESCRIPTION	LOAD								AMPERES		RATED HP	RATED KW	RATED KVA	ACTUAL INPUT KW	J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	PAGE 16
	TRIP COIL		TIMERS		AUX RELAYS		IND. LIGHTS		INRUSH	STEADY STATE									
	QUANT.	AMP/COIL	QUANT.	AMP/TIM	QUANT.	AMP/REL	QUANT	AMP/LT											
2VBB-UPS1A	-	-	-	-	-	-	-	-	-	-	-	-	75	62.4					
2VBA-UPSIC	-	-	-	-	-	-	-	-	-	-	-	-	75	67.5					
2TML-P5	-	-	-	-	-	-	-	-	684	207.25	30	-	-	-					
2EGF-P3	-	-	-	-	-	-	-	-	30	7.50	1	-	-	-					
13.8KV SWGR 2NPS-SWG001	8*	6*	1*	1*	-	-	28*	0.06	49.68*	1.68*	-	-	-	-					
2NPS-SWG003	8*	6*	1*	1*	-	-	28*	0.06	49.68*	1.68*	-	-	-	-					
2NPS-SWG002	2*	6*	-	-	-	-	6*	0.06	12.36*	0.36*	-	-	-	-					
2NPS-SWG004, 5	-	-	-	-	-	-	4*	0.06	0.24*	0.24*	-	-	-	-					
4.16KV SWGR 2NNS-SWG011,012, 013,014,015	17*	6	1*	1*	-	-	65*	0.06	105.9*	3.9*	-	-	-	-					
2NNS-SWG016,017 018	-	-	-	-	-	-	6*	0.06	0.36*	0.36*	-	-	-	-					
600V SWGR FEEDER BREAKERS	49*	1.3*	3*	0.06*	13*	0.06*	43*	0.06*	67.24*	2.58*	-	-	-	-					

* CHANGED REV. 9





A 5010.65

TABLE 1

DESCRIPTION	LOAD								AMPERES		HP	KW	KVA	ACTUAL INPUT KW
	TRIP COIL		TIMERS		AUX RELAYS		IND. LIGHTS		INRUSH	STEADY STATE				
	QUANT	AMP/COIL	QUANT	AMP/TM	QUANT	AMP/REL	QUANT	AMP/LT						
2BYS-SWG001A	-	-	-	-	-	-	1	0.06	0.06	-	-	-	-	-
2CEC-PNL732	-	-	-	-	10	0.03	10	0.06	0.90	6.4*	-	-	-	-
2CEC-PNL734	-	-	-	-	9	0.03	8	0.06	0.75	17.25*	-	-	-	-
2CEC-PNL735	-	-	-	-	8	0.03	7	0.06	0.66	17.16*	-	-	-	-
2CEC-PNL744	-	-	-	-	7	0.03	7	0.06	0.63	28.13*	-	-	-	-
2YUL-MDS1	1	5.93	-	-	-	-	1	0.06	30.0**	7.0	0.75	-	-	-
2YUC-MDS3	1	5.93	-	-	-	-	1	0.06	30.0**	7.0	0.75	-	-	-
2YUC-MDS5	1	5.93	-	-	-	-	1	0.06	30.0**	7.0	0.75	-	-	-
2YUC-MDS10	1	5.93	-	-	-	-	1	0.06	30.0**	7.0	0.75	-	-	-
2BYS-PNLA101	-	-	-	-	-	-	-	-	-	10.0***	-	-	-	-
2BYS-PNLA102	-	-	-	-	-	-	-	-	-	30.0***	-	-	-	-
2BYS-PNLA107	-	-	-	-	-	-	-	-	-	27.0***	-	-	-	-


22 V D C

J.O. OR W.O. NO. 12177
 DIVISION & GROUP ELECTRICAL
 CALCULATION NO. EC-44
 OPTIONAL TASK CODE N/A

CALCULATION IDENTIFICATION NUMBER



* See pages 41-45 for load determination; only 20A out of 68.94A is considered in the battery duty cycle because all the loads will not be energized simultaneously.
 ** See Assumption 2, page 6 of this calculation.
 *** See panel schedules, pages 38-40 of this calculation.



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>18</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

NOTES FOR TABLE 1

1. The tripping load occurs within 0.237 seconds.

Tripping load is 274.66 Amperes, maximum.
 $(18 \times 6) + (17 \times 6) + (49 \times 1.3) + (16 \times 0.3)$




2. The immediate motor inrush is 714 (684.0 + 30.0) Amperes, starting at 0.75 seconds; it is assumed it will last for the entire 1st minute of the duty cycle, to be conservative.

3. Used total of ⁹180 indicating lights for all switchgear; $180 \times 0.06 = 10.8$ ⁹Amperes. This value plus 2.94 ⁹Amperes for PGCC indicating lights and relays (74 relay) and 0.24 amperes for HV switch indicating lights equals 13.98 amperes. This load of 13.98 Amperes is used on page 20 ⁹of this calculation



4. See sources m. and n. for UPS sources, page 8 of this calculation.



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65


CALCULATION IDENTIFICATION NUMBER				PAGE <u>19</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3 7. Determination of the Battery Duty Cycle
4
5

6
7 Page 20 depicts the battery loads considered,
8 the time they occur and their duration. Certain
9 loads such as 2YUL-MDS1, etc, have
10 been designated as RANDOM LOADS since they
11 may appear any time during the duty cycle.
12
13
14
15
16
17

18
19 Page 21 depicts the sum of battery loads by time
20 period. The $\frac{1}{2}$ total load is also shown, because
21 the Duty Cycle Diagram is constructed for a single battery
22 although in reality two identical batteries are used.
23 Page 22 depicts the Battery Duty Cycle Diagram.
24
25
26
27
28

29 The following constitutes the basis for selection of "Start Time" and
30 "duration" for ZEGE-P3. Per FSAR page 9.5-24a the electric motor
31 driven fuel booster pump is a standby pump. However, the pump starts
32 and primes the engine driven pump, when the start signal is given
33 for the engine to start. The pump stops after a speed signal is given from
34 the engine. But the fuel booster pump will also start if fuel pressure in the
35 main header downstream of the engine driven pump falls to 25psi.
36
37 Based on the above it will be assumed that the pump starts at $t=0$
38 and continues to run for 120 minutes.
39
40
41
42
43
44
45
46



CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

12177 / EC-44

REVISION

PAGE

20

ASOTC-1

PREPARED/DATE

REVIEWER/CHECKER/DATE

INDEPENDENT REVIEWER/DATE

SUBJECT/TITLE

QA CATEGORY/CODE CLASS

WORK SHEETS


FOR STORAGE BATTERIES - LEAD-ACID

A. Length of duty cycle 120 minutes

B. Loads

	Amp	Start Min	Duration Min	
Breaker Tripping (2)				
<u>ALL SWITCHGEAR AND PGCC PNLs</u>	<u>274.66</u>	<u>0</u>	<u>1</u> ✓	△ 9
Continuous Control				
<u>INDIC. LIGHTS FOR ZCEC-PNL732,734,735,744 & SWYD: 138KV, 4.16KV & 125VDC SWGRs.</u>	<u>13.98</u>	<u>0</u>	<u>120</u>	△ 9
Emergency Lighting				
<u>2VBB-UPSIC</u>	<u>545-591-637</u>	<u>0</u>	<u>90</u> ✓	
Inverters				
<u>2VBB-UPSIA</u>	<u>504-547-590</u>	<u>0</u>	<u>120</u> ✓	
	<u>618</u>			
Motor Starting Inrush (3)				
<u>EBOP (2TML-P5)</u>	<u>684</u>	<u>0</u>	<u>1</u> ✓	
<u>ZEGF-P3 (DIESEL GENER. FUEL PUMP)</u>	<u>30</u>	<u>0</u>	<u>1</u> ✓	
Motor Running				
<u>EBOP (2TML-P5)</u>	<u>207.25</u>	<u>1</u>	<u>44</u>	
<u>ZEGF-P3 (DIESEL GENER FUEL PUMP)</u>	<u>7.5</u>	<u>1</u>	<u>119</u>	
Other Loads				
<u>MISCELLANEOUS LOADS ON 2BYS-PNL101, 102, 107</u>	<u>67</u>	<u>0</u>	<u>120</u> ✓	△ 9
<u>RANDOM LOAD: ZCEC-PNL732,734,735,744</u>	<u>20</u>		<u>1</u> ✓	
<u>: 2YUL-MDS1</u>	<u>30</u>		<u>1</u> ✓	
Breaker Closing, etc. (4)				
<u>13.8KV & 4.16KV SWGR (1 PER SWGR) (RANDOM LOAD)</u>	<u>28</u>		<u>1</u> ✓	


(1) "Start" means time from start of cycle to load application.



▲ 5010.65

PAGE <u>21</u>	<u>BATTERY LOAD; TABULATION</u> <u>BY TIME PERIOD</u>		
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE
CALCULATION IDENTIFICATION NUMBER			
TIME PERIOD	INCREMENTAL LOADS, AMPERES	TOTAL LOAD AMPERES	1/2 TOTAL LOAD (AMPERES)
0 - 1 min.	$274.66 + 13.98 + 545 + 504 + 684 + 30 + 67$	2118.64	1059.32
JUST AFTER 1 MIN.	$13.98 + 545 + 504 + 207.25 + 7.5 + 67$	1344.73	672.36
45 min	$13.98 + 591 + 547 + 207.25 + 7.5 + 67$	1433.73	716.86
JUST AFTER 45 min	$13.98 + 591 + 547 + 7.5 + 67$	1226.48	613.24
90 min	$13.98 + 637 + 590 + 7.5 + 67$	1315.48	657.74
JUST AFTER 90 min.	$13.98 + 590 + 7.5 + 67$	678.48	339.24
120 min.	$13.98 + 618 + 7.5 + 67$	706.48	353.24
<p>RANDOM LOAD = $30 + 20 + 28 = 78$ Amperes</p> <p>1/2 RANDOM LOAD = $\frac{78}{2} = 39$ Amperes.</p>			


1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46




STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>22</u> 9
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	





STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET


▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>23</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

8. Explanation of Battery sizing form (page 28, this calculation)
Complying with IEEE-485 and EC-110.0.1.1-0 Page 3

- (1) Period is a particular segment of the load profile. For example, 0 to 1 minute is period no. 1, since it is the first period starting from zero (or the left side). The term section is the number of periods under consideration. Section 3 indicates 3 periods are being considered.
- (2) Load (amperes), A_1 for example, is the load for period 1. ($2118.64/2$ or 1059 amperes in this case). △ 9
- (3) Change in load (amperes), is the change from one period to the next.
- (4) Duration of period (minutes) M_1 , is the time for a particular period in minutes.
- (5) Time to end of section (minutes), T , is the time from $T=0$ to the time at the end of the section under consideration.
- (6A) R_T = Amperes per positive plate
Section 1 R_T is obtained by first referring to Gould Capacity Table, page 41, 1 minute rating to 1.75 volts per cell column and finding the nearest value equal to or greater than A_1 . (See (2), above).



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>24</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

This value is then divided by $\frac{\text{Plates/cell}-1}{2}$ for the battery type matching the 1 minute rating used above, the quotient being R_T . For example, type NCX-1050 has a 1 minute rating of 1204 Amperes; this type has 15 plates per cell; $\left(\frac{15-1}{2}\right)$ equals 7; $1204/7 = 172$ Amperes/p.p. In our case, $A_1 = 1059$ Amperes; therefore $1059/172 (R_T) = 6.16$ p.p. or positive plates for section 1. It should be noted that there is always one more negative plate than positive plates.

Section 2 R_T is obtained directly from the battery manufacturer's discharge characteristic for the type of cell whose size this calculation is attempting to verify. In our case the Gould characteristic curve is TC-107011B for NCX-2550, shown on page 42 of this calculation. For example, Section 2, period A1, shows a value of 1059 Amperes. $T, [see (4) above] = M_1 + M_2 = 45$ minutes. Refer to TC-107011B where the 3/4 hour line intersects the 1.75 final voltage curve. A vertical line dropped from this point will intersect the base line or Amperes per positive plate line at 86.5 Amperes/p.p. This is the discharge rate for 3/4 hours to 1.75 volts per cell final voltage.

✓

✓



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET


▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>25</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

(7) Required Section Size : $(3) \div (6A) =$ Number of positive plates ; using the numbers above we have ,
 $1059 \text{ Amperes} \times \frac{1 \text{ P.P.}}{86.5 \text{ Amperes/P.P.}} = +12.24 \text{ P.P.}$ △ 9


This represents the required number of positive plates for the following period.




Continuing with Section 2 the second period is $694 - 1059 = -365$ Amperes. The time T is 44 minutes. Referring to TC - 107011B yields 87.0 Amperes/p.p. ; thus $-365 \text{ Amperes} \times \frac{1 \text{ P.P.}}{87.0 \text{ A/P.P.}} = -4.20 \text{ Amperes}$ for a fictitious period shown below. △ 9



Superimposed, the profile looks as follows with no random load.





STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>26</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	


- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46

The difference value (4.20) is subtracted from the positive value (12.24), giving the number of positive plates required; this is 8.04 p.p.

△ 9

Since each subsequent section in the duty cycle is not greater than the previous section, the only additional consideration is the Random Equipment Load, which as mentioned earlier is 39 Amperes and has not been included in the duty cycle.

—
—



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>27</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

R = Random period, minutes

AR = Random load, amperes applied at the end of the section from which the largest number of positive plates was obtained.

MR = Duration of Random period

T = Time to end of Random section


To obtain R_T (6A), do the following:

Take the number of positive plates required from Section 2 above, as previously calculated. For our case 8.04 p.p. . Go to Gould Capacity Table on 9 page 41 and in the one minute rating to 1.75 volts per cell column, find the value corresponding to a type with the same or greater number of positive plates. For our case 9.0 is the next greater whole number. Select NCX-1350 with one minute rating of 1494 Amperes.

For NCX-1350 $R_T = 1494 \text{ Amperes} / 9 \text{ p.p.} = 166 \text{ A/p.p.}$

Dividing AR by R_T : $39 \text{ Amperes} \times \frac{1 \text{ p.p.}}{166 \text{ Amperes}} = 0.23 \text{ p.p.}$
for the random load.

The number of positive plates from Section 2 8.04 pp, and 0.23 p.p. from Random Load are 9 inserted in ^{the} appropriate spaces on page 28 for final verification sizing.



A 5010 85

CALCULATION IDENTIFICATION NUMBER

J.O. OR W.O. NO.
12177

DIVISION & GROUP
ELECTRICAL

CALCULATION NO.
E-44

OPTIONAL TASK CODE
N/A

PAGE 28

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46

Lowest Expected Electrolyte Temp: 65°F Minimum Cell Voltage 1.75VPC Cell Manufacturer GOULD Cell Type NCX-2550 9

(1) Period	(2) Load (Amperes)	(3) Change in Load (Amperes)	(4) Duration of Period (Minutes)	(5) Time to End of Section (Minutes)	(6) Capacity at T Min. Rate @ 77 F (6A) Amps/Pos (RT) or (6B) K Factor (KT)	(7) Required Section Size (3) ÷ (6A) = Positive Plates (3) x (6B) = Rated Amp Hours Pos Values Neg Values
---------------	-----------------------	---------------------------------	-------------------------------------	---	--	--

Section 1 - First Period Only - If A2 is greater than A1, go to Section 2.

1	A1= 1059	A1-0= 1059	M1= 1	T-M1= 1	172	6.16	***
Sec 1 Total						6.16	***

Section 2 - First Two Periods Only - If A3 is greater than A2, go to Section 3.

1	A1= 1059	A1-0+ 1059	M1+ 1	T-M1+M2= 45	86.5	12.24	***
2	A2= 694	A2-A1= -365	M2= 44	T-M2= 44	87.0	-4.20	***
Sec Sub Total						12.24	-4.20
2 Total						8.04	***

Section 3 - First Three Periods - If A4 is greater than A3, go to Section 4

1	A1=	A1-0=	M1=	T-M1+M2+M3=			
2	A2=	A2-A1=	M2=	T-M2+M3			
3	A3=	A3-A2=	M3=	T-M3=			
Sec Sub Total							***
3 Total							***

Section 4 - First Four Periods Only - If A5 is greater than A4, go to Section 5


1	A1=	A1-0=	M1=	T-M1+...M4=			
2	A2=	A2-A1=	M2=	T-M2+M3+M4=			
3	A3=	A3-A2=	M3=	T-M3+M4=			
4	A4=	A4-A3=	M4=	T-M4=			
Sec Sub Total							***
4 Total							***

Section 5 - First Five Periods Only - If A6 is greater than A5, go to Section 6

1	A1=	A1-0=	M1=	T-M1+...M5=			
2	A2=	A2-A1=	M2=	T-M2+...M5=			
3	A3=	A3-A2=	M3=	T-M3+M4+M5=			
4	A4=	A4-A3=	M4=	T-M4+M5=			
5	A5=	A5-A4=	M5=	T-M5=			
Sec Sub Total							***
5 Total							***

Random Equipment Load Only (if needed)

R	AR= 39	AR-0= 39	MR= 1	T-MR= 1	166	0.23	***
---	--------	----------	-------	---------	-----	------	-----



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>29</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

Maximum Section Size 8.04 Plus Random Section Size 0.23 Equals 8.27

Uncorrected Size 8.27. Uncorrected Size 8.27 Times Temperature

Correction 1.08 Times Design Margin 1.0 Times Aging Factor 1.25


Equals 11.16. When the cell size is greater than a standard cell size,
the next larger cell is required.

Required Cell Size: (A) 12 Positive Plates or 25 total plates
per cell; this corresponds
to an NCX-1800
or
(B) 1800 Ampere Hours

Therefore cell NCX-1800 is acceptable
for $\frac{1}{2}$ the total load. Since (2) NCX-2550
(acceptable, ~~not acceptable~~)

60-cell batteries have been purchased for NMP2,
excess capacity exists, in the order of (2550/1800)
or 41.66%.






STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>30</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3 9. Voltage Profile determination
4

5
6 To determine the voltage at different times during
7 the duty cycle the Work sheet for Lead-Acid Batteries
8 Voltage Profile Calculation is filled-out; this appears
9 on page 31 of this calculation. Columns (2) & (3) ⁹
10 are based on data from the battery duty cycle.
11
12 Column (4) or Adjusted Amperes is determined by
13 multiplying the Ampere Rate on column (3) by the
14 temperature correction factor, 1.08 and by the Aging
15 Factor, 1.25. Columns (5) and (6) are defined on
16 the Work Sheet, itself. Columns (3) and (4) use
17 average values when the time span is long (30 minutes
18 or longer); When the time span is short, say 1
19 minute, maximum values are used. Column (7)
20 assumes that Ampere-Hours at the end of one step
21 is equal to the beginning of the next step.
22 Data on Column (8) is obtained from Gould Graph
23 # TC-107011B, by plotting the appropriate curve
24 at the intersection of the lines defined by
25 data on columns (5) and (7).
26
27 Column (9) is defined on the work. sheet. Based on
28 column (9) the voltage profile is plotted as shown on page 32.
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46



WORK SHEETS FOR STORAGE BATTERIES
LEAD - ACID - VOLTAGE PROFILE CALCULATIONS

J.O. No. 12177
 Client NMPC
 Station NMP2
 Battery No. 2BYS-6RT 1A
 Spec No. NMP2-E033A
 Spec Dated _____


Calculated by _____
 Date _____
 Checked by _____
 Date _____

Length of Duty Cycle _____ minutes
 Nominal Battery Voltage _____ v
 Amp Hours per positive plate vs Amps per positive plate data source _____

BATTERY TYPE ; NCX-2550 (2 UNITS IN PARALLEL)

No. Positive Plates per cell 17
 No. of cells 60


(1) Step	(2) Time in Min.	(3) Ampere Rate	(4) Adjusted Amps	(5) # Pos. Plates Amps per Positive Plate	(6) (2) x (5) 60 Amp Hours Per Pos.	(7) Cumulative A. H. Discharge	(8) Volts per Cell (5) at (7)	(9) Battery Voltage (8) x number of cells in Series
1	1	1059 ▲	1430 ▲	84.12 ▲	1.40 ▲	Beginning 0	1.880 ▲	112.80 ▲
						End 1.40 ▲	1.878 ▲	112.68 ▲
2	43	694 ▲	937 ▲	55.11 ▲	39.50 ▲	Beginning 1.40 ▲	1.925 ▲	115.50 ▲
						End 40.90 ▲	1.880 ▲	112.80 ▲
3	1	756 * ▲	1021 ▲	60.06 ▲	1.00 ▲	Beginning 40.90 ▲	1.872 ▲	112.32 ▲
						End 41.90 ▲	1.870	112.20
4	45	636 ▲	859 ▲	50.50 ▲	37.88 ▲	Beginning 41.90 ▲	1.890	113.40
						End 79.78 ▲	1.825 ▲	109.50 ▲
5	30	346 ▲	467 ▲	27.48 ▲	13.74 ▲	Beginning 79.78 ▲	1.900	114.00
						End 93.52 ▲	1.880	112.80
6						Beginning		
						End		
7		* RANDOM LOAD WORST SECTION.		SUPERIMPOSED ON THE		Beginning		
						End		
n		▲ VALUE CHANGED IN REV. 9			▲	Beginning		
						End		




STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE 32 REDRAWN 9
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	



2BYS - BATIA
 VOLTAGE PROFILE



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>33</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

10. Battery Charger Calculation

Calculate the minimum charger rating:

$$A_r = \frac{AH \times C}{T_1} + A_c$$

- where A_r = Required minimum charger rating in amperes
 AH = Total ampere hours discharged from the battery during its specified duty cycle
 C = Constant to allow for ampere hour efficiency. Use 1.10
 A_c = Continuous battery load while charging, amperes
 T_1 = Required maximum time for recharging


In this case AH equals (1734 Ampere hours x 2) or 3468 Ampere-hours. 1734 Ampere hours is obtained from Gould curve # TC-107011B, for a 2 hour discharge cycle as follows: for a discharge cycle of 2 hours and 1.75 volts per cell. The discharge characteristics of cell NCX-2550 yields 102 Ampere hours per p.p.; since a NCX-2550 has 17 p.p., the discharge current will be $17 \times 102 = 1734$ Amperes-hours. For additional information on the determination of AH, see source g., attached.

T_1 is taken as 24 hours, in accordance with source g.

$$A_c = 13.98 + 67 = 80.98 \text{ Amperes} \quad \triangle 9$$

$$A_r = \frac{1734 \times 2 \times 1.1}{24} + 80.98 \approx 240 \text{ Amperes} \quad \triangle 9$$

Assume a 300 Ampere Charger is provided and check the charging time.



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>34</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
12177	ELECTRICAL	EC-44	N/A	


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

$$T_1 = \frac{1734 \times 1.1 \times 2}{300 - 80.98} = 17.42 \text{ hours} \quad \triangle 9$$

Since a 500 Ampere battery charger is actually being supplied by Power Conversion Products, the charging time (T_{500}) will be shorter. This time (T_{500}) can be calculated as follows:

$$T_{500} = \frac{1734 \times 1.1 \times 2}{500 - 80.98} \approx 9.1 \text{ hours} \quad \triangle 9$$

A 500 Ampere Battery Charger is satisfactory since a 9.1 hour recharge time is less than 24 hours. △ 9



EBOP

Ia = 205

R_F = 40^w 25°C

{ Received from R. York on Tele-Con
1/4/84

30HP =

1750RPM

Slab Shimt

I_F = 2.25

Same Cl F

Duty Cont

Max temp 40°C

PSC 0

Part # 254A4103


Temp. CO365APY

DFFG

Duty GEH-3967

Mod. 5C0192V080.6A801

Ser. # CL-1-1363-CL



APPARATUS AND ENGINEERING SERVICES OPERATIONS
GENERAL ELECTRIC COMPANY • MASCHHELLMAC OFFICE COMPLEX, 1000 FIRST AVENUE KING OF PRUSSIA, PENNSYLVANIA 19406

H. M. ...
T. B. Madden
Div #6

64 062584

NO 30 NO 23

(215) 962-6105

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT NUCLEAR STATION, UNIT #2
STEAM TURBINE GENERATOR EQUIPMENT
TURBINE NO. 170X632
REQUISITION 306-31261

cc: R. A. Plant/S&W
R. M. Bozarth/S&W
W. F. Morrison/Nine Mile
T. E. Lempges/Niagara Mohav

Subject: DC Motor Parameters

NOTED SEP 04 1984 E. ...

August 28, 1984

Mr. C. Zappile
Stone & Webster Engineering Corp.
P. O. Box 5200
Cherry Hill, New Jersey 08034

NOTED AUG 31 1984 J. ...

NOTED SEP 04 1984 E. ...

Gentlemen:

This is in reply to the request for information for the DC-EBOP (Model #5CD192VD806A801) that you asked for in your letter of April 19, 1984.

- 1) Max. stall time @ 300% rated current is 10 seconds.
- 2) Acceleration time of the DC motor at varying voltage is not available. Acceleration of the DC motor is dependent upon many variables (starter operation, voltage, currents, oil temps, etc.)
- 3) Motor efficiency is:


Full Load	-	88.5%
1/2 Load	-	87.2%
3/4 Load	-	83.7%
- 4) Armature resistance was previously given - .0126 ohms @ 25°C.
- 5) The brush voltage drop is 2 volts nominal.
- 6) The motors rotor has a MK² of 15.6 lbft².
- 7) The commutating field resistance was also previously supplied - .0036 ohms @ 25°C.

If you have any questions, don't hesitate to give me a call.

Very truly yours,

Pradip V. Patel

PRADIP V. PATEL
... ..



INTEROFFICE CORRESPONDENCE

TO: John Dodson	QEOC	LOCATION SR	SUBJECT / REFERENCE / J.O. NO. Sizing of Battery Chargers
FROM: George Fligg		LOCATION 345/7	

MESSAGE:- As per your request, I have attached information as to the sizing of battery chargers. The recharge time to be used is 24 hours for the main station and eight hours for an unattended station. This will yield the smallest battery charger which could be used. However, it is SSMC's policy to size the battery charger for the size of the battery and the length of time of the duty cycle. For example, assume that you were using a duty cycle of two hours and a Gould battery BX 1500 which has a two hour discharge current rating of 510 amperes. In this case you would assume that 1,020 amperes HOURS had been discharged and you would size the battery charger on that basis.

If you need further information, just give me a call on 3-0024.

February 26, 1961

DATE

George Fligg

SIGNATURE

TELEPHONE


REPLY:

DATE

SIGNATURE

TELEPHONE

▲ 041128



DESIGNED BY

DESIGNED BY

DESIGNED BY

DESIGNED BY

DESIGNED BY

PRINTS	ISSUE	ISSUE	ISSUE	ISSUE
APP. CARD	1	2	3	4

CLIENT N.M.P.C. STA NINE MILE - UNIT 2 REF DWGS 000/420-221-095 JO 12177
 PNL NO SERIES GVB EQPT NO 2BYS-PNLA101 LOC CONTROL BLDG COL 10.5/AG ELEV 306
 SVCE 125VDC PH W 2 NEUT MNS: LUGS ONLY, 6KT BRKR FUSED SW - CONN: TOP
 BR CKTS - 6KT BRKR, FUSED SW - MTG: FT, SURF - NEMA TYPE 12 FDR SIZE 2-1/2" #750 BOT
 XFMR MK NO EQPT NO KVA ADD'L FEATURES BUS CAPACITY : 225A

NO	SERVICE	LOAD		A M P	1	2	A M P	LOAD		SERVICE	NO
		CONN	TERM CAB					TERM CAB	CONN		
	2WCSN17(828E25STY) ^{2WCS IPNL107}	10VA		30	1	2	30	-848		EHC01 SH.15	
	2EGFA05(7EGFO2)	6VA	*753		3	4		*753	36VA	2HVRN04(11HVRO1)	
	2DRSA05(11DRS01)	6VA	*753		5	6			2A	2FPL-PNL176(1)	
	2FPL-PNL177(1)	2A			7	8		-703	75W	2RCSA15(761E79TY)SH5	
	2EGAA03(11EGA01)	10VA*	*745		9	10		-701	2A	2WCSN40(807E175TY,SH.2)	
	SPARE				11	12		*753	30W	2FPWA06(7FPW06)	
	2WCS-IPNL18.7(3)	1.5A*	-		13	14			1A*	2FPLN32(7FPL16)	
	SPARE			60	15	16	60			SPARE	
				60	17	18	60				
					19	20					
					21	22					
					23	24					
					25	26					
					27	28					
					29	30					
					31	32					
					33	34					
					35	36					
					37	38					
					39	40					
					41	42					

STONE & WEBSTER ENGINEERING CORP.
BOSTON, MASS.

DWG. NO. **EE-10C**

ZBYS-PNLA101


EC-44
PAGE 38

CONN LOAD: EST 10AMPS

ULT LOAD: _____

TOTAL LOAD: _____

* ESTIMATED LOAD



AS3510

DESIGNED BY

DRAWN BY A. KENT

DSGN CHG'D BY

CHK'D BY

PRINTS

APP. CARD

1

ISSUE

2

3

ISSUE

4

ISSUE	1	2	3	4
DESCRIPTION	ORIGINAL ISSUE			

CLIENT N.M.P.C. STA NINE MILE - UNIT 2 REF DWGS 000/420-221-095 JO 12177
 PNL NO SERIES 6VB EQPT NO 2BYS-PNLA102 LOC CBCR COL 14/A6 ELEV 306
 SVCE 125VDC .PH W 2 NEUT MNS: LUGS ONLY, CKT BRKR FUSED SW - CONN: TOP
 BR CKTS -CKT BRKR, FUSED SW - MTG: FE, SURF - NEMA TYPE 12 FOR SIZE 2-1/6 750KCM BOT
 XFMR MK NO EQPT NO KVA ADD'L FEATURES BUS CAPACITY: 225A

NO	SERVICE	LOAD		A M P	1	2	A M P	LOAD		SERVICE	NO
		CONN	TERM CAB					TERM CAB	CONN		
	2FWSN32(807EK60Y) ^{SH.2}	5A	*704	30	1	2	30	*704	200W	2WCSN45(807E175TY/SH.2)	
	2EGFCOS(7EGFO2)	6VA	*754		3	4		*754	10VA*	2EGACO1(11EGAO3)	
	2CES*IPNL406	10A*			5	6			10A*	2CES*IPNL408	
	SPARE				7	8			2A*	2SCIB06(7SCI14)	
	2ICSN31(807E173TY/SH.3)		*702		9	10		*754	1A*	2SFCB13(7SFCOB)	
	SPARE				11	12		*704		2WCSN50(WCSO1)	
				60	13	14				SPARE	
				60	15	16		60			
					17	18		60			
					19	20					
					21	22					
					23	24					
					25	26					
					27	28					
					29	30					
					31	32					
					33	34					
					35	36					
					37	38					
					39	40					
					41	42					

CONN LOAD: EST 30Amps
 ULT LOAD: _____
 TOTAL LOAD: _____

*- ESTIMATED LOAD

PAGE 39

EC-44




DWG. NO. EE-100

2BYS-PNLA102

RESP. ENGR:

DSGN ENGR:



AS21510

DESIGNED BY

DRAWN BY A KENYIT

DSGN CHK'D BY

CHK'D BY

PRINTS	ISSUE	ISSUE	ISSUE	ISSUE
APR CARD	(2)	(3)	(4)	

STONE & WEBSTER ENGINEERING CORP.
BOSTON, MASS.

ISSUE	DESCRIPTION
1	ORIGINAL ISSUE
2	
3	
4	

CLIENT N.M.P.C. STA NINE MILE - UNIT 2 REF DWGS 0001.420-221-120 JO 12177
 PNL NO VB-6 EQPT NO 2BYS-PNLA107 LOC NORMAL SWGR COL 7.5/AK ELEV 237
 SVCE 125VDC PH W 2 NEUT MNS: LUGS ONLY, EKT-BRKR FUSED SW - CONN: TOP
 BR CKTS -EKT-BRKR, FUSED SW - MTG: FT, SURF - NEMA TYPE FDR SIZE 1-1/2" x 4/0 BOT
 PER LOG
 XFMR MK NO EQPT NO KVA ADD'L FEATURES BUS: 225A

NO	SERVICE	LOAD		A M P	Diagram		A M P	LOAD		SERVICE	NO
		CONN	TERM CAB		1	2		TERM CAB	CONN		
	2RTX-XSRIA ^{1.130-203} ₀₀₆	1A*		30	1	2	30	2A	2SPI-OSCOO1		
	2STX-XNSI ^{1.120-202} ₀₀₈	20VA			3	4		P856	25FCA13 (75FC07)		
	2MTX-XMIA (AUX CT)	1A			5	6			6A	2EXC-CUB04(3)(8EXS03)	
	2RCS-PNLA(3) ^(2RCSA22) _(71B791TY)	250W			7	8			3A	2CES-IPNL205(9MH02)	
	2MTX-XMIC (AUX CT)	1A			9	10				SPARE	
	2EGF*P3	8.4A			11	12					
	SPARE				13	14					
	2CES-PNLA21 (8SPX09)	2A		60	15	16	60				
	SPARE			60	17	18	60				
					19	20					
					21	22					
					23	24					
					25	26					
					27	28					
					29	30					
					31	32					
					33	34					
					35	36					
					37	38					
					39	40					
					41	42					

2BYS-PNLA107



DWG. NO. EE-10E


CONN LOAD: EST 27AMPS
 ULT LOAD:
 TOTAL LOAD

*-EST


PAGE 40



RESP. ENGR: _____ DSGN ENGR: _____



GENERAL

Storage:
Positive Cell:
(Cellular) 

TYPE: NCX

**CAPACITIES—500 A.H. TO 2550 A.H.
@ 8 HOUR RATE TO 1.75 V.P.C. AVERAGE**

SPECIFICATIONS

- Container—Styrene-Acrylonitrile Plastic.
- Cover—Acryl-Buta-Styr. Terpolym. Plastic.
- Separators—Microporous Material.
- Retainers—Fiberglass Mats.
- Pests—See Below.®
- Pest Seats—Floating O-Ring—Seal Nut.
- Vents—Screw Type—Spray Proof.®
- Level Lines—High and Low—All Jar Faces.
- Electrolyte—Height Above Plates—2-3/4".
- Electrolyte Withdrawal Tube—Each Cell.
- Sediment Space—1-1/16".
- Specific Gravity—1.215 @ 77°F. (25°C.).
- Inter-Cell Connectors—Lead Plated Copper.





Plate Dimensions	Height	Width	Thickness
Positive Plate	15"	12 1/2"	.230
Negative Plate	15"	12 1/2"	.215

® Pests—500 A.H. to 1300 A.H. Top—1 1/2" square. 1344 A.H. to 1650 A.H. Four—1" square. (Except 1648 A.H.) 1648 A.H. to 2550 A.H. Four—1 1/2" square.
® Combined Filling Form—Explosion resistant vent is available at additional cost. Specialty Seal "Pre-Vent"...

Type	Plates Per Cell	Ampere Hour Capacities to 1.75 V.P.C. Average*				1 Minute Rate in Amperes*		Overall Dimensions in inches			Approximate Wgt. in Lbs.		Eect. Calc. Per Cell	
		8 Hr.	8 Hr.	8 Hr.	1 Hr.	To 1.75 V.P.C. Avg.	To 1.80 V.P.C. Avg.	L	W	H	Net Wgt.	Packed Wgt.		
NCX-600	9	600	640	688	300	77	712	1335	7-3/8	14-1/2	22-1/8	177	180	6.0
NCX-672	9	672	696	720	300	836	1270	1315	7-3/8	14-1/2	22-1/8	178	190	6.0
NCX-750	11	750	675	585	375	890	1675	1375	7-3/8	14-1/2	22-1/8	186	207	5.5
NCX-840	11	840	735	615	375	780	1500	1300	7-3/8	14-1/2	22-1/8	186	208	5.6
NCX-900	12	900	810	702	450	1044	1955	1385	7-3/8	14-1/2	22-1/8	213	225	5.1
NCX-1008	12	1008	892	736	450	842	1780	1420	7-3/8	14-1/2	22-1/8	214	226	5.1
NCX-1050	15	1050	945	819	525	1204	2280	1500	7-3/8	14-1/2	22-1/8	231	243	4.8
NCX-1200	17	1200	1080	936	600	1380	2545	1585	7-3/8	14-1/2	22-1/8	249	261	6.0
NCX-1344	17	1344	1176	984	600	1240	2380	1620	9-1/4	14-1/2	22-1/2	268	280	6.8
NCX-1350	18	1350	1215	1063	675	1484	2940	1680	9-1/4	14-1/2	22-1/2	282	294	6.3
NCX-1500	21	1500	1350	1170	750	1620	3060	1740	9-1/4	14-1/2	22-1/2	301	313	6.0
NCX-1650	23	1650	1485	1267	825	1782	3380	1800	11-3/8	14-1/2	22-1/2	348	366	8.0
NCX-1680	21	1680	1470	1230	750	1830	2910	1830	11-3/8	14-1/2	22-3/2	332	350	8.3
NCX-1800	25	1800	1620	1404	900	1832	3675	1932	11-3/8	14-1/2	22-1/2	384	382	7.5
NCX-1848	23	1848	1617	1363	825	1861	3180	1961	14-8/16	14-1/2	22-1/2	387	415	12.8
NCX-1950	27	1950	1736	1321	975	2080	3835	2080	11-3/8	14-1/2	22-1/2	380	398	7.3
NCX-2016	25	2016	1764	1476	900	1728	3400	2016	14-8/16	14-1/2	22-1/2	415	433	12.1
NCX-2100	29	2100	1890	1638	1050	2240	4280	2100	14-8/16	14-1/2	22-1/2	448	464	11.5
NCX-2184	27	2184	1911	1589	975	1824	3880	2184	14-8/16	14-1/2	22-1/2	433	451	11.5
NCX-2250	31	2250	2025	1736	1125	2400	4565	2250	14-8/16	14-1/2	22-1/2	462	480	10.9
NCX-2400	33	2400	2160	1872	1200	2560	4865	2400	14-8/16	14-1/2	22-1/2	479	497	10.3
NCX-2550	36	2550	2295	1969	1275	2720	5170	2550	14-8/16	14-1/2	22-1/2	486	514	9.7


* Includes voltage drop across intercell connectors used in standard layouts. ** MCGraw, Inc.




1.88V x 60 = 112.8


1.86V x 60 = 111.6

Capacity of cell



15.7 x 9.2 x 10 =






2BYS-SWGO01B to 2CEC-PNL732 (P809, P810, P815, P802)				
DWG No	STEADY STATE LOAD	TRANSIENT LOAD	AMPS	SIZE AMPS
ESK-BSPRO7	(1) 74-HGA		0.03	0.03
	(1) Light	(1) 86-HEA	0.25 5.50	0.25 0.06 5.50
ESK-BSPRO8	(1) 74-HGA		0.03	0.03
	(1) Light	(1) 63-HGA (1) 30-HAA	0.25 0.027 0.022	0.25 0.06
ESK-8YUC05	(1) 74-HGA		0.03	0.03
	(1) Light	(1) 94-HFA	0.25 0.486	0.25 0.06
ESK-8SPX0B	(1) 74-HGA		0.03	0.03
	(1) Light	(1) 86-HEA	0.25 5.50	0.25 0.06
ESK-5NNS13	(1) 74-HGA		0.03	0.03
	(1) Light	(1) 86-HEA	0.25 5.50	0.25 0.06
ESK-5NNS13	(1) 74-HGA		0.03	0.03
	(1) Light	(1) 86-HEA	0.25 5.50	0.25 0.06
ESK-8SPR10	(1) 74-HGA		0.03	0.03
	(1) Light	(1) 86-HEA	0.25 5.50	0.25 0.06
ESK-8SPR11	(1) 74-HGA		0.03	0.03
	(1) Light	(1) 63-HGA (1) 30-HAA	0.25 0.027 0.022	0.25 0.06
ESK-8YUC05	(2) 74-HGA (2) Light		0.06	0.06
			0.50	0.50 0.12
		{ (1) 94-HAA } { (1) 94-HFA }	0.486	
		{ (1) 94-HAA } { (1) 94-HFA }	0.486	
TOTAL SIZE AMPS				8.30


~~8.30 x 1.5 = 12.45~~

0.9 amps in
6.4, random



2BYS-SW001A to 2CEC-PN734 (P808, P813, P804, P811)				
DNG No	STEADY STATE LOAD	TRANSIENT LOAD	AMP	SIZE AMPS
ESK-8NNS08	(1) 74-HGA (1) Light	(3) 86-HEA	0.03 0.25 16.50	0.03 0.25 16.50 * .06
ESK-8SPR13	(1) 74-HGA (1) Light	(1) 86-HEA (1) 67	0.03 0.25 5.50 -	0.03 0.25 .06
ESK-8YUC04	(1) 74-HGA (1) Light	{ (1) 94-HAA } { (1) 94-HFA }	0.03 0.25 0.48	0.03 0.25 .06
ESK-5NPS05	(1) 74-HGA (1) Light	(1) 86-HEA	0.03 0.25	0.03 0.25 .06
ESK-5NPS14	(1) 74-HGA	(1) 94 (1) AGA (1) 62-HGA	0.03	0.03
ESK-5NPS10	(1) 62-TU	(3) 27-HFA		
ESK-5NNS24	(1) 74-HGA (1) Light	(2) 62-TU	0.03 0.25	0.03 0.25 .06
ESK-8NNS07	(1) 74-HGA (1) Light	(3) 86-HEA	0.03 0.25 16.50	0.03 0.25 .06
ESK-8SPR12	(1) 74-HGA (1) Light	(1) 86-HEA	0.03 0.25 5.50	0.03 0.25 .06
ESK-8YUC04	(1) 74-HGA (1) Light	{ (1) 94-HFA } { (1) 94-HAA }	0.03 0.25 0.48	0.03 0.25 .06


0.75A - 1M, 17.25 Random. TOTAL SIZE AMPS 18.77



fed from 733

2BYS-SW600IA to 2CEC-PNL735 (P805, P812, P803, P812)				
DWG No.	STEADY STATE LOAD	TRANSIENT LOAD	AMPS	SIZE AMPS
ESK-8NNS06	(1) 74-HGA	(3) 86-HEA	0.03	0.03
	(1) Light		0.25	0.25 ^{1.5}
ESK-8SPR05	(1) 74-HGA Light	(1) 67 (1) 86-HEA	16.50	16.50 [*]
			5.5	—
ESK-8YUC04	(1) 74-HGA (1) Light	{ (1) 94-HAA (2) 94-HFA }	0.03	0.03
			0.25	0.25 .06
ESK-5NNS10	(1) 74-HGA (1) Light	(1) 86-HEA	0.368	—
			0.03	0.03
ESK-5NPS02	(1) 74-HGA (1) Light	(1) 86-HEA	0.25	0.25 .06
			5.50	—
ESK-5NPS13	(1) 74-HGA	(1) 94-HFA (1) AGA (1) 62-HGA	0.03	0.03
			0.50	Residual trans: = 7.4 Fact trans: = 2
ESK-5NNS21	(1) 74-HGA (1) Light	(1) 86-HEA	0.03	0.03
			0.25	0.25 .06
ESK-5NNS06	(1) 74-HGA Light	(1) 86-HEA	5.50	—
			0.03	0.03
			0.25	0.25 .06
TOTAL SIZE AMPS				18.21 ^{17.14}
				0.66-1M
				17.16-R
18.21 x 1.5 = 27 Amps				


7



2BYS-SW6001B to 2CEC-PNL744 (P866, P867, P865)					
DWG No	STEADY STATE LOAD	TRANSIENT LOAD	AMPS	SIZE AMPS	
ESK-8SPG04	(1) 74-HGA (1) Light		0.03	0.03	
			0.25	0.25 .06	
			(1) 86-HEA	5.50	5.50
			(1) 86-HEA (1) 86-HEA	5.50 5.50	5.50 5.50
ESK-8SPU04	(1) 74-HGA (1) Light		0.03	0.03	
			0.25	0.25 .06	
			(1) 86-HEA	5.50	
			(1) 86-HEA	5.50	
			(2) 94-HFA	0.368	
			(1) 59-HFA	0.486	
			(1) 50-HGA	0.032	
			(1) 50-HGA	0.032	
ESK-8SPS03	(1) 74-HGA (1) Light		0.03	0.03	
			0.25	0.25 .06	
			(1) 63-HGA	0.027	
			(1) 30-HAA	0.022	
ESK-8SPM04	(1) 74-HGA (1) Light		0.03	0.03	
			0.25	0.25 .06	
			(1) 30-HAA	0.022	
			(1) 63-HGA	0.027	
ESK-8SPU03	(1) 74-HGA (1) Light		0.03	0.03	
			0.25	0.25 .06	
			(1) 86-HEA	5.50	
			(1) 86-HEA (2) 94-HFA	5.50 0.368	
TOTAL SIZE AMPS				17.9	

SEE P46

~~17.9 x 1.5 = 26.85~~



2BYS-SWGDIA to 2CEC-PNL744 (P864)				
DWG. No.	STEADY ST		AMPS	SIZE AMPS
ESK-8SPU02	(1) 74-HGA		0.03	0.03
	(1) Light		0.25	0.25 .06
		S (2) 94-HFA	0.368	-
		P (2) 86-HEA	11.00	11.00 *
ESK-8SPU06	(1) 74-HGA Light		0.03	0.03
			0.25	0.25 .06
		(1) AMX-HFA	0.486	-
TOTAL SIZE AMPS				11.56

6.40
17.25
17.16
28.13
68.54

ALL 20 AMP
RANDOM
LOAD FOR FGCC

$11.56 \times 1.5 = 17.34 \text{ Amp}$

0.63 IM
28.13 R

REASON FOR REVISION 5


ALL ASSUMPTIONS AND INPUT DATA ARE COMPLETE. ANY FUTURE CHANGES WILL BE INCORPORATED BY REVISING THIS CALCULATION.



REASON FOR REVISION 6

FINAL EMERGENCY BEARING OIL PUMP DATA, RECEIVED IN SOURCE 1-23; G.E. LETTER P19 THIS CALC., IS INCORPORATED IN EC-100. ALSO IN DEPTH REVIEW OF LOGIC CHANGED SWITCHGEAR d.c. loads.

.5
16.50
16.50
21.5
51.5



INTEROFFICE MEMORANDUM

J.O. OR W.D. NO 12177-EC-32-4

△ 000.00

SUBJECT

TOPICAL INFORMATION REPORT FOR TRANSFORMER AND BUS LOADING AND ASSIGNMENTS

DATE

May 10, 1982

FROM

TLOtt:JR

TO

All Electrical Engineers and Squad Leaders

CC

JCGabriel
KNKhanna
DFSabatini

The attached information will be issued as Topical Information Report by our Boston office before long.

In the meantime, I am sending this to you for your information.

This document will be used as a guide and not as a rigid standard.

T. L. Ott
T. L. Ott

Attachment



GENERAL

This design criteria is presented as a guide for both allowable bus loadings and assignments of loads to various plant loads. This criteria is meant as a guide to engineers for a standard Stone & Webster design. Finalization of this criteria is dependent on several factors. Among these are: client preferences and approval, economic studies and the complement of equipment to be powered. Whether at a later date assignment or loading criteria should be altered depend on such things as how far the plant design is completed, possible additional loads in the future, costs of adding new equipment, redesign of sills, tray systems, duct lines, and status of purchase orders and equipment production. However, the guidelines set forth in the following design criteria are a useful tool in designing an adequate and flexible distribution system.

Spare and future positions should be provided on all buses if possible. The number of each should be worked out with the client at an early stage. Floor sills should be extended to allow additional equipment to be added if necessary.

For most power plant work, the voltage of the medium voltage and low voltage buses is established early in the design of the plant. The number of medium voltage buses is dependent on several variables including requirements of the large mechanical systems, client preference, philosophy of plant operation and equipment economics, and in the case of nuclear plants - regulatory requirements.

The initial step is to ascertain what the electrical loads are and their power requirements. Then the maximum simultaneously running loads must be calculated for each bus and transformer contemplated. The engineer should use the motor and electric load list as well as logic descriptions, system descriptions, and consultation with the lead power engineer during this stage of design to ascertain the maximum coincident loading of each bus.


TRANSFORMERS

Power transformers should be conservatively sized to allow for future load growth. Station service transformers will generally be about 10 percent of total generator output for nuclear plants.

For fossil plants approximately 7 percent of generator output is used for station service. If a scrubber is required, another 3 percent will be used to power the scrubber auxiliaries.

As loads are defined further, the transformers sizes can be finalized allowing for worst case loading and providing at least 15 percent margin for future growth.

For criteria on sizing smaller transformers, see the information in low voltage load assignments below.



MEDIUM VOLTAGE BUSES

Generally in plants where both 15 kV class and 5 kV class buses are selected, motors above 2500 HP are assigned to the 15 kV class buses. Motors above 250 HP, up to 2500 HP, are assigned to the 5 kV class buses.

In plants where 7.5 kV class buses are utilized as the highest distribution voltage, motors above 4000 HP would be assigned this bus with motors 250 HP to 4000 HP being assigned to the 5 kV class buses.

These HP break points are only guidelines and economic studies should continue to be done for loads which are in question.

METAL CLAD SWITCHGEAR

Metal clad switchgear should not have a coincident loading above 60 to 70 percent of the main bus rating during the early stages of the project to allow for further load growth as the project progresses. If during the latter stage of the project the loads grow, it is best to keep the maximum switchgear bus loading to about 90 percent of the full load rating of the main breaker and bus under the worst operating condition.

To determine maximum running loads on metal clad switchgear early in the project, the electrical engineer should consult with the lead power engineer to determine maximum coincident loading on each bus. Be sure to consider - pumps out for maintenance, transformer failures and bus failures and the subsequent effect on the remaining buses in the analysis.


In the early stages nameplate horsepower should be used for the large motors. This builds in a little extra conservatism for possible increases in brake horsepower (BHP) requirements later. In the latter stages of the project, known BHP at runout conditions should be used.

LOW VOLTAGE BUSES

On low voltage distribution systems, several types of equipment are utilized to feed motor and other type loads. Load center secondary unit substations are used to feed loads directly, as well as providing a power source to MCC's and panelboards (if a separate panelboard system is used). Loads from 60 to 250 HP or 60-250 KVA are generally fed directly from a load center power circuit breaker. If loads in this size range require frequent starting and stopping, reversing control, or two speed control, consider the use of locally mounted starters equipped with nonautomatic breakers.

Loads from 1 HP to 50 HP or 1 to 50 KVA can be assigned to MCC's (some projects have elected to use separate 600 volt class panelboards in lieu of MCC feeder circuit breakers for non-motor loads. S&W's standard design, however, calls for these breakers to be mounted on the MCC). Motor operated valves of any size should be assigned to an MCC. When assigning low voltage loads, care should be taken to assure that auxiliaries to large motors (i.e., lube oil pumps) are on MCC's fed by the same power train as the pump motor itself.

Small loads less than 1 HP or 1 KVA should be assigned to 120 volt panelboards. (If automatic control is required, local starters or contactors should be utilized).




LOAD CENTERS

Since the low voltage loads change dramatically during the life of the project, it is good to have ample capacity in the load centers (LC's) early in the project's life. In the early stage of a project, it is usually a good practice to add connected, continuously running loads and multiplying by .80 for diversity and .90 for utilization (brake HP vs. nameplate HP) to arrive at an estimated load for directly connected loads; for MCC load estimates see the paragraph below. At later stages of the project, maximum running loads should not be greater than 80 percent of the self cooled transformer rating. Also, note that on double ended load centers, the total coincident LC load should not be greater than the highest rating of a single transformer so that one transformer can be out-of-service without forcing load shedding to occur. Transformers are usually not larger than 1000 KVA with a standard 5.75 percent impedance, because above this size either the available short circuit current can become too high for the LC feeder breakers ^{or} MCC's unless a higher impedance transformer is purchased. This inturn can cause voltage profile problems.

Motor control centers are placed for convenience in an area close to motor loads. This keeps cable distances short for voltage considerations and usually means that the total load on a given MCC can be kept fairly well below the standard 600 amp bus. In the early stages of a project, the loads should be held to about 300 amps maximum (400-500 amps on industrial projects). Whenever possible, loads of a common system should be grouped on the same MCC to try to assure system power continuity. Spares and spaces should be grouped to allow for future starters of varying sizes and types. The decision as to whether to allow loads on a MCC above the 300 amp target, or create another MCC, is a matter of judgement and should be discussed with the Lead Electrical Engineer. The standard S&W design calls for panelboards to be fed from the local MCC. Since these loads must also be added to the MCC load, some guidelines are listed below for panel loads.

The following is a list of typical assumptions for bus loading on MCC's, panelboards, and load centers.

1. Motor operated valves (MOV's) and motor operated doors can be ignored when reflecting MCC loads to the load center. For a particular MCC loading, use 20 percent of the total horsepower per MCC that are MOV's or doors.
2. Intermittent loads such as cranes, small compressors, sump pumps, elevators, motor space heaters, switchgear space heaters, etc., can be ignored when reflected to the load center unless the load is on for longer than one hour at a time. (Some judgement is required here and the Lead Electrical Engineer shall provide guidance for each application. On MCC's, add 20 percent of the total of these to the MCC load).
3. Lighting loads should be added on a watts per square foot basis initially until actual loads are known. The lighting specialist can provide estimates based on the type of lighting selected. Add one half amp per duplex receptacle.
4. Since other panelboard loads are unknown until much later, add the distribution transformer KVA until loads are better defined. Keep the number of these transformers reasonable. Consult the equipment specialist for past experience in this area.



5. Work with the building service engineers for an estimate of diversity for various areas of the plant if electric unit heaters are used as well as air conditioning.
6. Ignore welding and vacuum cleaner receptacles.
7. Add continuous loads on the MCC bus and multiply by .80 for diversity and .90 for utilization in the early stages. Later as the motor and load list information is complete, use all of the continuous coincident loads and multiply by .90 for utilization.

These guidelines should be discussed in detail with the Lead Electrical Engineer, and where appropriate, with the client to ensure project agreement before the equipment is purchased if possible.


LOADS CONNECTABLE TO DIESEL GENERATORS

Diesel generators are often used as emergency power sources. In nuclear plants they usually supply the 4160 volt standby buses. In fossil plants, they may feed either 4160 volt or low voltage buses. In nuclear plants, loads other than Class IE safety related loads are often either fed from Class IE buses with an automatic LOCA trip or are assigned to buses which are manually connectable to the diesel bus.

In fossil plants, loads that are important to an orderly shutdown or personnel safety are assigned to buses which can be fed by a diesel generator.

In general, the list below suggests possible candidates for assignment to buses which can be fed from a diesel generator.


1. Emergency lighting
2. Security systems
3. UPS systems/instrumentation buses
4. Battery chargers
5. Instrument air compressors
6. Fire protection systems
7. Scrubber agitators
8. Turning gears
9. Boiler controls
10. Loads which allow for orderly shutdown of the plant or prevent subsequent damage.



LOADS CONNECTABLE TO UPS SYSTEMS

Many factors are involved in assignments of loads to UPS buses vs. standard instrument and control buses. The assignment of many of the loads to UPS buses should be done in conjunction with the Controls engineers. Items such as the acceptability of power interruption, voltage variations, etc., make a joint effort here very important.

The above load assignment guidelines are a good starting point. When followed, they have been found to usually offer an economical and effective design. However, many factors can influence and change these general rules, such as client preference, or late changes in horsepower which would have changed the type equipment feeding the load, but due to transformer size limitations, etc., an exception may have to be made and the load remain on the existing bus. Also, discretion needs to be used with certain type loads, i.e., it might be preferable to have a 2 KW motor space heater rated at 120 volts and fed from a panelboard if 480 volt heaters are not available as standard.



INTEROFFICE CORRESPONDENCE

TO: <i>J Knudson</i>	LOCATION <i>5R</i>	SUBJECT / REFERENCE / J.O. NO. <i>12177</i> <i>Time of operation for DC motors</i> <i>for E BOP & ESOP</i>
FROM: <i>J Stencho</i>	LOCATION <i>5B</i>	

MESSAGE: —

GE- LSTG Letters dated 1 Sept 1976 and 30 Nov. 1976 for the River Bend Project are applicable to the NMAP2 Project.

The Batteries shall be designed for 30 min. for E BOP and 90 min. for ESOP

6/13/65
DATE

J Stencho
SIGNATURE


3317
TELEPHONE

REPLY:

DATE

SIGNATURE

TELEPHONE



INTEROFFICE CORRESPONDENCE

TO: J. STERNCHOS	LOCATION 5BL	SUBJECT / REFERENCE / J.O. NO. 12177 TIME OF OPERATION OF DC PUMPS EBOP & ESOP
FROM: J. KNUDSEN	LOCATION 5R	

MESSAGE: —

Attached are the G.E. letters concerning the subject pumps for the River Bend Station of Gulf States Utilities. Please write an IOC indicating that the content of these letters would apply to NMP2. Also we require your recommended operating times (duration of operation) for the pumps, as well as, whether, after an accident or otherwise, they could be expected to start. Also, if they operate other than continuous i.e. more than once during the battery 2 hour cycle, then we need this information. The project now requires all sources for ~~for~~ basing decisions used in cases. Please include whatever sources (other than IOC's) used to base your decisions.

Thanks,

6/11/85
DATE

John M. Knudsen 4496
SIGNATURE TELEPHONE


REPLY:

See attached

LC

6/13/85
DATE

J. Sternchos 3317
SIGNATURE TELEPHONE



INTEROFFICE CORRESPONDENCE PAGE 56

TO: AK Gural	LOCATION 5R	SUBJECT / REFERENCE / J.O. NO. ESOP operating time .12677
FROM: J Stenches	LOCATION 5B	ESOP

MESSAGE: -

after reviewing GE's letter dated 6/19/85 and the size of the CO₂ system, the information given in the River Bend Project is applicable. The ~~ESOP~~^{ESOP} will operate for 90 min. The 91A2 CO₂ system has 2 13 Ton CO₂ (Liquid) Tanks. Thus the purge time will be less than 60 min.

6/25/85
DATE

J Stenches
SIGNATURE


3317
TELEPHONE

REPLY:

DATE

SIGNATURE

TELEPHONE



APPARATUS AND ENGINEERING SERVICES OPERATION

GENERAL ELECTRIC COMPANY • ONE UNIVERSITY OFFICE PARK, 29 SAWYER ROAD • WALTHAM, MASSACHUSETTS 02254 • (617) 647-7200

EC-44

PAGE 57

June 19, 1985

Copy to:

SR

NIAGARA MOHAWK POWER CORPORATION
 Nine Mile Point Nuclear Station, Unit #2
 J.O. 12177 - Purchase Order No. 2
 Steam Turbine Generator Equipment
 Turbine No. 170X632
 Requisition 306-31261

JM Knudsen S&W
J Sternchos S&W

Mr. A. K. Gwal
 Stone & Webster Engineering Corporation
 P.O. Box 5200
 Cherry Hill, New Jersey 08034

Dear Sir:

As requested by Mr. J. M. Knudsen, I am forwarding our current station battery recommendations for the emergency bearing oil pump (DCM E11.601B) and the emergency seal oil pump (278A6692).


You will note that time is addressed in the case of the EBOP but not for the ESOP. This is because the time requirements for a successful coast-down are well known, but the events which must precede a safe ESOP shutdown are more difficult to time and are as follows:

1. The machine gas should be vented from operating pressure down to 2-5 PSIG. This can and should be done during coastdown.
2. The purging of hydrogen with carbon dioxide cannot commence until the shaft is at or near standstill because the rotor fans will mix the gases and produce erratic readings on the purge analyzer at the sample connection.
3. It will be necessary to admit approximately 7400 CU. FT. of CO₂ to achieve a safe gas mixture (<5% H₂ in CO₂). It is reasonable to assume that this can be done in 60 minutes with a 6 bottle manifold and 4 bottle changes made expeditiously. We do not know the limitations of a bulk CO₂ supply and CO₂ discharge tends to be self limiting depending on piping configuration because of the formation of solid carbon dioxide (dry ice) at points where rapid expansions take place. There is considerable discussion of the ramifications of handling carbon dioxide in the turbine-generator instruction

STONE & WEBSTER

JUN 24 1985

DOCUMENT CONTROL



book, volume II, tab 29, GEK-45944.

4. The final and perhaps most difficult variable is operations priorities at the time of the event.

In summary, a 2 hour run time for the ESOP is probably appropriate, but all of the foregoing must be considered.


Yours very truly,



T. J. Grady Project Application Engineer
NEW ENGLAND DISTRICT

Attachment


TJG:s1b:305.1




DC Voltage Range of Motor and Starter for
the Emergency Bearing Oil Pump (E3OP)

The motor for the emergency bearing oil pump has a nameplate voltage of 120 vdc or 240 vdc depending upon the voltage of the customer's station battery. The motor, motor starter and emergency bearing oil pump are suitable for operation in the voltage range of 105 vdc to 140 vdc (or 210 vdc to 280 vdc). The station battery should have sufficient capacity to start and operate the E3OP, along with all other loads on the battery, for the period of time required to shut the turbine down safely upon a trip concurrent with a loss of power to the a-c driven oil pumps.

For purposes of establishing the required battery capacity, the load due to the E3OP should be based on the assumption that, in starting, the motor will draw 5 times full load current for 10 seconds. During this period and for 10 minutes thereafter, the voltage at the motor terminals must remain above 105 vdc (210 vdc for 240 vdc systems). Between 10 and 30 minutes after starting of the E3OP, the voltage must remain above a linear reduction with time to 90 vdc (180 vdc for 240 vdc systems) at the end of 30 minutes after starting. After 30 minutes, further drop off in voltage is permissible. Should the voltage drop below approximately 80 vdc (160 vdc for 240 vdc systems), the starter will drop out and shut down the E3OP motor. This must not be permitted to occur for at least an additional 15 minutes if there is any possibility that full condenser vacuum might be maintained, prolonging the time required for the turbine to coast to a standstill. This might be the case if power to the condenser cooling water pumps is maintained while power to the a-c driven lube oil pumps is lost.





STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET


▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>60</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46


CIRCUIT BREAKERS TRIPPING
ON BUS UNDERVOLTAGE

<u>SWGR I.D.</u>	<u>CUBICLE</u>	<u>ESK</u>
2NPS-SWG001	1-3	5NPS01-13
	1-6	5RCS01-8
	1-7	5CNM04-10
	1-8	5FWS01-10
	1-9	5CWS01-10
	1-10	5CWS03-9
	1-11	5CWS05-9
	1-12	5CNM06-11
2NPS-SWG002	2-2	5ABM01-8
	2-3	5ABM02-7
2NPS-SWG003	3-4	5RCS02-8
	3-5	5CNM05-10
	3-7	5FWS02-10
	3-8	5CWS06-9
	3-9	5CWS04-9
	3-10	5CWS02-9
	3-12	5FWS04-8
	3-14	5NPS04-13
2NNS-SWG011	11-4	5CCS01-9
	11-6	5HDL01-7
	11-7	5CNM01-6
	11-8	5CNM03-8
2NNS-SWG012	12-2	5HDL03-9
	12-4	5CCS03-9
	12-5	5CCP01-9



STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5016.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>61</u> 
J.O. OR W.O. NO. 12177	DIVISION & GROUP ELECTRICAL	CALCULATION NO. EC-44	OPTIONAL TASK CODE N/A	

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46

2NNS-SWG013

13-2

5CNM07-9

13-3

5CNM02-7

13-4

5HDL02-9

13-8

5CCS02-9

13-9

5CCP04-4

2NNS-SWG014

14-6

5CCP06-4

14-7

5RDS01-8

14-9

5CCP03-8

2NNS-SWG015

15-2

5RDS02-8

15-4

5CCP02-8

15-6

5CCP05-4

TOTAL SWITCHGEAR BREAKERS = 36

TOTAL 600V LOAD CENTER BREAKERS = 49

7